Docusign Envelope ID: 82598C47-981F-4F0A-82C3-EDD9660347C0

75\PI\1015
DF3
ZS 75660
NOTE 5
DF3-VBF400-ISO_21
ZS 75661
DF3-VBF400-ISO_22
NOTE 5
TI 03
FI 75662
FIT 75662
FE 75662
450X400
400x300
M
400x300
NOTE 3
DF3-VBF400-ISO_23
DF3-VCV400-NRV_24
75-706-DCW-PE16-400-SI
PI 75663
DF3-VBF250-ISO_25
TI 04
DF3-VB50-ISO_26
C/TAILS LINE TO A/B DAMS
75\Pi\xx
TI 05
DF3-VBF250-ISO_27
DF3-VB50-ISO_28
A TAILS LINE TO D/A DAMS
75\Pi\xx
TI 08
DF3-VBF250-ISO_29
DF3-VB50-ISO_30
C/TAILS LINE TO A/B DAMS
75\Pi\xx
TI 09
DF3-VBF250-ISO_31
DF3-VB50-ISO_32
TBC
75\Pi\xx
TI 10
DF3-VBF250-ISO_33
NOTE 6
DF3-VB50-ISO_34
A TAILS LINE TO C PADDOCK
75\Pi\xx
TI 06
DF3-VBF400-ISO_35
NEW DN400 SCOUR TO TOE DRAIN
75\Pi\xx
3
F30 TAILS - STATION 02
FIM II. TAIL VALVES STATION
(SPAGHETTI JUNCTION).
75\Pi\xx
C TAILS LINE
75\Pi\xx
A TAILS LINE
DECANT DAM 4
2000-F75-PID-PR-40004
DECANT RETURN
75-8532-PW-PE12.5-500
500VBFE1L1 (45001)
500VCE1S1 (45002)
DECANT DAM 3
75\PI\1015
DECANT RETURN
75-8112-PW-PE12.5-450
450VBFE1L1 (45003)
450VCE1S1 (45004)
450x710
75-8112-PW-PE12.5-710
HYDROGEN PEROXIDE INLINE MIXER 3
2000-F75-PID-PR-25008
DECANT WATER
75-8112-PW-PE12.5-710
710x630
700VBFE1L1 (45005)
FI 75334
FQI 75334
FY 75334
FE 75334
FIT 75334
710x630
700VBFE1L1 (45006)
700VBFE1L1 (45007)
OE
SALINE WATER POND SOUTH
SALINE WATER POND NORTH
NEW DN355 OD PE100 PN16
OE
LOW CYANIDE WATER POND FIMISTON
HYDROGEN PEROXIDE INLINE MIXER 3
2000-75-PID-PR-40004
DECANT RETURN
75-8112-PW-PE12.5-710
75-5001-PW-PE12.5-355
KEARN'S CORNER
75\PI\5001
FLUSHING WATER
EXISTING 75-TK-01 CYANIDE WATER TANK
NOTE 4
DN50
DF3-VB50-ARV_07
NOTE 7
NOTE 4
DN50
DF3-VB50-ARV_06
FI 7531A
FIT 7531A
FE 7531A
NOTE 1
KV 75668
HS 75668
HS 75669
KV 75669
DF3-VBF300-CTV_04
DF3-VBF300-CTV_03
DF3-VBF350-ISO_02
DF3-VBF350-ISO_01
ϕ450
DF3-VB450-ISO_10
ZS 75667
TI 11
TI 14
TI 15
450x280
TI 12
355x280
TI 13
DF3_355PE
75-8112-PW-PE12.5-710

LEGEND
EXISTING
NEW
FUTURE
DECOMMISSIONED
DECOMMISSIONED

KCGM GROWTH PROJECT
DRAWING NO.
2000-F75-PID-PR-40032

REV	DATE	DESCRIPTION	CHECK	TECH APP
0	05DEC24	APPROVED FOR CONSTRUCTION	CS	TvB

NOTES:
1. REUSE EXISTING FLOWMETER.
2. ALL VALVES ARE PREFIXED WITH "F75DCW3". FOR PURPOSES OF CLARITY THIS WILL BE OMITTED FROM P&ID.
3. LOW CYANIDE WATER FLUSHING DUTIES
4. VENT VALVE TO BE POSITIONED AT HIGH POINT SOUTH OF DAMS.
5. POSITIONERS TO BE ADDED TO MANUAL VALVES 450 F2KV01H & F2KV01G
6. EXISTING BUTTERFLY VALVES TO BE RESITED UPSTREAM OF NEW TIE PIECE & KNIFE GATE VALVE
7. REUSE EXISTING SECTION OF DN450 PN16 PE100 HDPE PIPE (BURIED).

MK	DATE	REVISION	BY	CKD	APP
3	12.05.2020	REVISED - 'AS BUILT'.	T.R.		
2	07/07/17	FINAL AS BUILT	JS		
1	28/06/17	AS BUILT	JS		
0	2016-10-19	ISSUED FOR CONSTRUCTION	AB		

STANDARD DRAWING - STANDARD PIPING - ABBREVIATIONS, DRAWING NUMBERING & BASIC VALVE SYMBOLS
REFERENCE DRAWINGS: 00\SP\1003

DESIGNED	20/07/16
CHECKED	20/07/16
APPROVED	
PROJ.APP	

NTS
K417746

FIMISTON PLANT
WATER TREATMENT FIMISTON KALTAILS
DECANT DAM 3 PUMP UPGRADE
PROCESS & INSTRUMENT DIAGRAM

SIZE	DRAWING NUMBER	REV
A1	75\Pi\1016	3

KALGOORLIE CONSOLIDATED GOLD MINES PTY. LTD. ABN 009 377 619 003