FIMISTON STOCKPILE RECLAIM TUNNEL

NOTES:

1. FOR GENERAL NOTES REFER TO 2000-PID-PR-10001 TO 10007.
2. ALARM CHECK VALVE.
3. ABOVE 15CV03 PRIOR TO RECYCLE CRUSHER BUILDING.
4. TAG SIGHTED ON HYDRANT CABINET 'SE10'.
5. AT WALL OF MERCURY STORAGE SHED.
6. REFER DRAWING 75/P/G7 FOR OVERALL FIRE WATER ROUTE, VALVE SCHEDULE & HYDRANT LAYOUT.
7. PROCESS CONTROL SYSTEM CONNECTIONS NOT SHOWN, OR WHERE SHOWN NOT CONFIRMED.

HOLDS:

1. ISOLATION VALVE NOT FOUND. MAY BE BURIED UNDER ROAD.
2. CLIENT TO CONFIRM INSTRUMENT TAG NUMBER.
3. NO U/G PIPEWORK SIGHTED OR CONFIRMED.
4. TBA - BY CLIENT.

50VB 77V
25VB 76V
DN25 STEEL TYP.
15-0039-FW-ST-50
25VB 25V
80x50
100x80
100x50
15-0038-FW-ST-50
NOTE 3
FS XXX
FS XXX
PS XXX
HOLD 2
NOTE 2
150x100
150VG 6V LO
FH39 FH
FH08 FH
15-0036-FW-ST-80
15-0037-FW-ST-80
15-0035-FW-ST-150
19-0040-FW-ST-150
75-0057-FW-XX-XXX
HOLD 3
FIRE WATER NETWORK (150VGE1C427)
2000-F75-PID-PR-25003
FIRE WATER

FIRE WATER NETWORK (32V)
2000-F75-PID-PR-60036
FIRE WATER
75-0088-FW-XX-XXX
HOLD 3
71-0002-FW-ST-150
150VG 33V LO
150VG 08V LC
150VG 07V LC
80VG 34V LC
71-0003-FW-ST-80
FH14
26-0004-FW-ST-150
150VG 69V LO
26-0005-FW-ST-80
26-0006-FW-ST-80
FH15
FH17
71-0102-FW-ST-25
HOLD 4 FHRXXX
71-0008-FW-ST-100
FH13
HOLD 1
75-0002-FW-XX-XXX
HOLD 3

10CV02A HEAD END
10CV02A TAIL END TRANSFER TOWER
10CV02A TAIL END TRANSFER TOWER
10CV02A TAKE UP TOWER
25VB
10-0042-FW-ST-25
10-0044-FW-ST-25
10-0045-FW-ST-25
NOTE 4
FH20 FH
10-0100-FW-ST-100
ST PE
10-0041-FW-PE-63
25VB
10-0009-FW-ST-150
150VG 10V LO
FH18 FH
10-0010-FW-ST-80
FH19 FH
71-0011-FW-ST-80
80VG 45V LO
FH22 FH
10-0046-FW-ST-80
10-0047-FW-ST-032
HOLD 4 FHRXXX
10-0105-FW-ST-25
10-0048-FW-ST-25
80VG 12V LC
FH32 FH
ROM PAD NEAR PRIMARY CRUSHER CONTROL ROOM
10-0049-FW-ST-150
HOLD 2 XX XXXX
100VG 78V
10-0050-FW-ST-100
100x50
50x25
25VB
NEXT TO F10CR10 OUTSIDE CRUSHER VAULT
10-0051-FW-ST-50
DN25 STEEL TYP.
F10CV01 SPRINKLERS
DRAIN
DN15
15VB
10-0052-FW-ST-50

HOLD 3 75-0088-FW-XX-XXX
30-0012-FW-ST-80
80VG 13V LO
40x25
40VB
HOLD 4 FHRXXX
TOP OF CIL 1
30-0013-FW-ST-40
TOP OF CIL 2
80VG 43V LO
FH16 FH
30-0014-FW-ST-25
30-0101-FW-ST-40
30-0015-FW-ST-40
15V
TOP OF CIL 3
80SCV 49V LC
FH42 FH
80DA
30-0017-FW-ST-80
75-0016-FW-XX-XXX
HOLD 3
80VG 14V LO
30-0018-FW-ST-80
80VG 95V LO
81-0020-FW-ST-80
81-0019-FW-ST-25
81-0053-FW-ST-80
81-0016-FW-ST-80
FH43 FH
66-0022-FW-ST-80
80VG V97
80x25
NOTE 5 EXT., INT.
66-0023-FW-ST-25
66-0022-FW-ST-25
F66FW02
F66FW03

F78-FW02
F78-FW01
25VB 78-IP-107
25VB 78-IP-108
78-0030-FW-ST-25
78-0029-FW-ST-25
78-0031-FW-ST-25
F78-FW03
78-0032-FW-ST-100
100VG
FH F78-FW04
150x100
100VBF
HOLD 2 XX XXXX
100VBF 78-IP-109 LO
78-0033-FW-ST-100
CARBON FILTER 2 (F78-FI-72)
2000-F78-PID-PR-60005
FIRE WATER
78-0034-FW-ST-100
CARBON FILTER 1 (F78-FI-71)
2000-F78-PID-PR-60004
FIRE WATER
F78-FW05 FH
78-0028-FW-ST-100
100VG 90V LO
PI XXXX
HOLD 2
15VB
78-0055-FW-ST-150
150x50
50VB
FH51 FH
30-0026-FW-ST-80
78-0027-FW-ST-150
150VG 91V LO
78-0025-FW-ST-200
200VG 93V LO
200VG 92V LO
FH FH11
30-0054-FW-ST-80
75-0056-FW-XX-XXX
HOLD 3
FIRE WATER NETWORK (FH07)
2000-F75-PID-PR-60036
FIRE WATER

2025.04.17 10:13:15+08'00'
2025.04.17 11:08:31+08'00'
2025.04.17 11:40:50+08'00'