


Test Report	 Et Hølscher og CG Jensen selskab	
Project	Hotel Joyn	
Sub Project		
Well	PU03	
Date	01.10.20	
Start Time	10:10	
End Time	13:10	
Water Meter Before	25.92	m3
Water Meter After	28.89	m3
Total m3	2.97	m3
Reference Level	2.912	mDVR90
Water Level	3.88	m
Water level in Reference	-0.97	mDVR90
Time Initial Dip	10:10	
Bottom Well	11.64	m
Q_max (m3/h)	0.52	m3/h
Q_max (m3/s)	0.00	m3/s
Maximum Drawdown	-7.113000	mDVR90
Drawdown after 6 minutes stop	-4.45	mDVR90
Drawdown after 60 minutes stop	-0.80	mDVR90
Difference max drawdown / drawdown after 60min	6.31	m
Specific Capacity	0.0817	Q/m
Delta s (over decade)	3.65	m
Transmissivity	0.000007	m2/s
Efficiency/Virkningsgrad	18.33	%
Link to view interactive data	https://mainops.azurewebsites.net/TrackItems/StepTestReport/10?	%

Test Manual Measurements

Time	Flow	m3	Dip	Comment
10:10:00	0.9	25.92	3.88	
12:10:00	1.85	27	8.1	
13:00:00	1.6	28.89	10.18	

Time Series Data Graph

Pump Level Moni1 Level Moni2 Level Flow Rate

