

SOP.ENAG: PRESSURISATION OF FUEL GAS SYSTEM

AIM: To detail the procedure for safe pressurisation of ENAG fuel gas system.

† Number of People Involved 2

① Target Time 23mins

Procedure Overview What is done	Instructions and Explanations How it is Done	Reasons Why it is done	Key Point Images Instruction to accompany the photo
1. Zero Fuel gas scrubber pressure Controller Output Takt Time: 3mins. Cycle Time: 3mins.	Confirm Reset for ALL standing Trip alarms at DCS C&E prior to commencement of task. 1.1 At DCS HMI, take the control mode of Fuel gas scrubber pressure Faceplate 145PICA-100 (Train 1), 145PICA-200 (Train 2) into Manual (MAN). 1.2 Give the Output 0% (zero percent).	To prevent sudden / over-pressurization of Fuel gas scrubber during pressurization stage.	Manual (MAN) Mode button on Faceplate
2. Perform Inlet SDV local reset Takt Time: 5mins Cycle Time: 8mins	2.1 Field Operator should push the local reset button for 45-UZV-110A (Train 1), 45-UZV-210A (Train 2). 2.2 Confirm the valve position indicator has moved to "OPEN".	To complete Fuel gas system trip reset logic	
3. Line up Gas Lift Inlet Manifold to the Fuel Gas System Takt Time: 10mins Cycle Time: 18mins	3.1 Open the manual valve 45-BV- 003 3.2 Gradually turn counter-clockwise the Scrubber inlet manual valve to "fully open" position for the desired Fuel Gas Train.	To introduce gas into Fuel gas scrubber	Local Reset Button Valve Position Indicate
4. Pressurize Fuel gas scrubber. Takt Time: 5mins Cycle Time: 23mins	4.1 At DCS HMI, take the control mode of Fuel gas scrubber pressure Faceplate 145PICA-100 (Train 1), 145PICA-200 (Train 2) into Automatic (AUTO). 4.2 Ramp up the Set point in steps of 1Barg, up to 3.0 Barg allowing the PV settle at each step. 4.3 Leave the Set point at 3.0 – 3.5 Barg.	To ensure smooth pressurization of Fuel gas scrubber.	Inlet valve in fully open position Automatic (AUTO) Mode button on Faceplate Set point Ramp-up button

Doc No :	Rev: 0	Date Issued:
Approved:	Name/ Area:	Signature 3508 (8
Page 1 of 2	Review Date:	Printed copies are uncontrolled



SOP.ENAG: PRESSURISATION OF FUEL GAS SYSTEM

✓ Pre-Checks Things to Do Before Starting the Process		Key Point Images	
 ☐ Hold toolbox meeting. ☐ Ensure that gas processing area is on stream. ☐ Check drain valves are closed and spades in place of the control of the	on the fuel gas unit as shown in UEFS.		
★ Tools and Materials Things You Need Before Starting the Process	Step	Key Point Images	
Gas tester Fire retardant coverall, safety shoes, hand gloves, eye goggle. Communication radios (Ex).	All All		
† † Peopl Who Is Required to Bo	le e Notified	Key Point Images	
☐ Operations Team Leader ☐ Oth ☐ Operations Personnel in Flow Station	ers carrying out activities within the location		

Doc No :	Rev: 0	Date Issued:	7 - 0.7
Approved:	Name/ Area: C - TIMEH	Signature 2	183118
Page 2 of 2	Review Date:	Printed copies are uncontrolled	1



SOP.ENAG: START-UP OF FUEL GAS SUPER HEATER

AIM: To detail the procedure for safe start-up of ENAG fuel gas system super heater.

Procedure Overview What is done	Instructions and Explanations How it is Done	Reasons Why it is done	Key Point Images Instruction to accompany the photo
1. Ensure the Gas Generator is running Takt Time: 5mins. Cycle Time: 5mins.	Confirm Reset for ALL standing Trip alarms at DCS C&E prior to commencement of task. 1.1 Physically confirm that at least one Gas generator is running.	To achieve a positive gas flow across the heater.	
2. Perform Thyristor manual reset Takt Time: 5mins Cycle Time: 10mins	2.1 At the Thyristor Local Control Panel (LCP) in the Switchgear room, turn the "FAULT RESET" knob key clockwise and release.	To complete super heater system trip reset logic.	Turn knob key clockwise and release
3. Zero Super heater Temperature Controller output Takt Time: 3mins Cycle Time: 13mins	3.1 At DCS HMI, take the control mode of Fuel Gas Super Heater Faceplate 145TICA-101 (Train 1), 145TICA-201 (Train 2) into Manual (MAN) 3.2 Give the Output 0% (zero percent) value.	To prevent sudden / over-heating of Fuel gas Super heater during temperature building stage.	Manual (MAN) Mode button on Faceplate
4. Start Super heater Takt Time: 3mins Cycle Time: 16mins	4.1 At DCS HMI, call up Super heater Start/Stop Faceplate 145E-101 (Train 1), 145E-201 (Train 2) 4.2 Click on the START button.	To initiate Fuel gas Super heater.	START button on Faceplate
5. Build temperature to operating value Takt Time: 10mins Cycle Time: 26mins END	5.1 At DCS HMI, take the control mode of Fuel Gas Super Heater Faceplate 145TICA-101 (Train 1), 145TICA-201 (Train 2) into Automatic (AUTO). 5.2 Ramp up the Set point in steps of 1deg C, up to 35deg C, allowing the PV settle at each step. Leave the Set point at 35deg C.	To ensure smooth temperature gradient up to operating temperature.	Automatic (AUTO) Mode button on Faceplate Set point Ramp-up button

Doc No :	Rev: 0	Date Issued: O
Approved:	Name/ Area: C TAMEN	Signature:
Page 1 of 2	Review Date:	Printed copies are uncontrolled



SOP.ENAG: START-UP OF FUEL GAS SUPER HEATER

✓ Pre-Checks Things to Do Before Starting the Process		Key Point Images	
 ☐ Hold toolbox meeting. ☐ Ensure that gas processing area is on stream. ☐ Check drain valves are closed and spades in place of the control of the	on the fuel gas unit as shown in UEFS.		
★ Tools and Materials Things You Need Before Starting the Process	Step	Key Point Images	
☐ Gas tester ☐ Fire retardant coverall, safety shoes, hand gloves, eye goggle. ☐ Communication radios (Ex).	All All		
♦ ♦ Peopli Who is Required to Be		Key Point Images	
☐ Operations Team Leader ☐ Oth ☐ Operations Personnel in Flow Station	ners carrying out activities within the location		

Doc No :	Rev: 0	Date Issued:
Approved:	Name / Area: C - CANCEN	Signature:
Page 2 of 2	Review Date:	Printed copies are uncontrolled



SOP.ENAG: START-UP OF INSTRUMENT AIR COMPRESSOR

AIM: To detail the procedure for safe start-up of ENAG Instrument Air Compressor System.

† Number of People Involved 2

⊕ Target Time <u>27mins</u>

Procedure Overview What is done	Instructions and Explanations How it is Done	Reasons Why it is done	Key Point Images Instruction to accompany the photo
1. Reset Instrument Air compressor from Local Display Panel Takt Time: 5mins. Cycle Time: 5mins.	Confirm Reset for ALL standing Trip alarms at DCS C&E prior to commencement of task. 1.1 Physically confirm that at least one Gas OR Emergency Diesel Generator is running. 1.2 Use the navigation buttons to navigate to the "STOP" warning sign, select it. 1.3 Use the navigation buttons to navigate to the "Reset" Tab at the bottom of screen, select it.	To clear all standing alarms and give permissive to start the system.	STOP Warning sign Reset Tab
2. Select Lead / Lag Compressor Takt Time: 3mins Cycle Time: 8mins	2.1 At the Air Compressor I/O Panel, use the Auto Sequence button, select A-Mode if system is powered by Diesel Generator (any mode can be selected when system is powered by the Gas generators)	Only Instrument air compressor A is connected to diesel generator and should be selected as Lead.	Select mode using the Auto Sequence button
3. Put the Compressors in REMOTE mode Takt Time: 2mins Cycle Time: 10mins	3.1 At the Air Compressor I/O Panel, using the Compressor LOCAL/REMOTE knob, select REMOTE for both compressor A and B.	To transfer compressor control to DCS HMI.	Compressor LOCAL / REMOTE knobs
4. Put the Air Dryers in REMOTE mode Takt Time: 2mins Cycle Time: 12mins	4.1 At the Air Compressor I/O Panel, using the Dryer STOP / RUN knob, select RUN for both Dryers A and B.	To grant Local Override permissive to start Dryers when Compressor loads in REMOTE mode with control from DCS HMI.	Dryer STOF RUN knobs RUN positio
5. Toggle Compressor Faceplate Control mode Takt Time: 15mins Cycle Time: 27mins	5.1 At DCS HMI, toggle the control mode of Compressor Faceplate 146A-101 (Compressor A), 146A-201 (Compressor B) from CAS to AUTO and back to CAS. 5.2 Confirm that the Lead Compressor has started and Loaded. 5.3 Monitor the system and confirm that the Lead compressor Unloads and Loads at the correct pressures as indicated at DCS HMI.	To ensure the compressors Load and Unload automatically at the set regulation pressures.	Confirmed Cascade (CAS) Mode on Faceplat

Doc No :	Rev: 0	Date Issued:
Approved:	Name/ Area: C . TAMEN	Signature:
Page 1 of 2	Review Date:	Printed copies are uncontrolled



SOP.ENAG: START-UP OF INSTRUMENT AIR COMPRESSOR

✓ Pre-Checks Things to Do Before Starting the Process		Key Point Images	
 ☐ Hold toolbox meeting. ☐ Ensure that power generation system is online. ☐ Check drain valves are closed on the Instrument Air 	Compressor / Dryer unit as shown in UEFS.		
★ Tools and Materials Things You Need Before Starting the Process	Step	Key Point Images	
Gas tester Fire retardant coverall, safety shoes, hand gloves, eye goggle. Communication radios (Ex).	All All		
# People Who is Required to Be		Key Point Images	
☐ Operations Team Leader ☐ Oth ☐ Operations Personnel in Flow Station	ers carrying out activities within the location		

Doc No :	Rev: 0	Date Issued: ()
Approved:	Name/ Area: C · OFMON	Signature:
Page 2 of 2	Review Date:	Printed copies are uncontrolled