	ImoR 3 Booster Compressor Instrument Panel Upgrade - Commissoining Works	anel Upgrade - Commissoining Works
	ACTIVITY	NUMBER OF DAYS (October 2015)
		8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26
	Commissioning Activities	
_	Check functionality of Governor / Actuator and resolve any issue	
2	Check functionality of other controls	
ω	Check HMI synchronization status	
4	Resolve any mismatch on HMI synchronization if any.	
GI	Prelube Unit and ramp up to max. no-Load speed level	
თ	Test run unit unloaded and record pressures and temperatures	
7	Test run unit loaded and record pressures and temperatures	
œ	Commence 72-Hrs Test-Run	
9	Stabilize Unit on-load and confirm parameters (pressures and temperatures etc.) Ok	
10	Hand-over Unit to Asset team	
1	Demobilize from site	

Name: Osasona, Sazy	ızy	Name:	Wahua, Nkesi I SPDC-UIO/G/PNEL1 <nkesi.wahua@shell.com></nkesi.wahua@shell.com>
Designation Manager, AG	Mahager, AGG Reliability Improv. Project, AGG Improvement Project	Designation (	Operations Manager, Land 1/East, Asset Land East
Signature	San S	Signature	percein
Date S. Mr.	10/2015	Date / 8	N 5196 AI