|            |   | IMO AGG POWER CHALLENGE RECOVERY PLAN  |
|------------|---|--|
| UNITS      | ACTIVITY  | 17-Mar 18-Mar 19-Mar 21-Mar 22-Mar 23-Mar 23-Mar 25-Mar 27-Mar 28-Mar 29-Mar 30-Mar 31-Mar 01-Apr 02-Apr 03-Apr 05-Apr 05-Apr 05-Apr 06-Apr 08-Apr |
| Gas Gen A  | Alternator coupling repairs and Alienment   |  |
|            | Personnel mobilize to site and commence 1 work.   |  |
|            | 2 Carry out 250hrs inspection   | 1  |
|            | Carry out Generator alignment/replacement of burnt coupling bushing with Gen B, test run and commission |  |
| 9          | ENGINE MINOR REPAIR, ALTERNATOR RUBBER  |  |
|            | Sourcing for Cranishaft oil seal  |  |
|            | 2 Sourcing for Alternator coupling rubber   |  |
|            |   |  |
|            | 4 Effect engine repair  |  |
|            | 5 Install and Align Alternator  |  |
|            | 6 Install Alternator coupling rubber  |  |
|            | 7 Complete repairs, test and commission unit.   |  |
|            |   |  |
| Gas Gen C  | Cylinder 7 Repair   |  |
|            | 1 Personnel mobilize to site and troubleshoot Gen C   |  |
|            | 2 Source for defective components and replace   |  |
|            | 3 Complete repairs, test and commission unit.   |  |
|            |   |  |
| Diesel Gen | Generator Radiator Repair   |  |
|            | Seeking/secure BFM approval and Issue PO to the Contractor  |  |
| -4         |   |  |
|            | 3 Make up radiator and return it to IMOR  |  |
| 7          | A Replace radiator, align and commission  |  |
|            |   | Completed Completed Not started Started  |

Ungoing (III) Not started

Approved by: Ani Friday
Head Maintenance Execution Land East

Note: IMOR AGG will be up once two Gas Gens are available

Prepared by: Adenuga Olufemi Field Team Leader (Operations), PH2, Ops. Land 1