

[Table 1: 2024 EDM Headlines](#)
[Table 2: 2024 EDM Summary Statistics](#)
[Table 3: 2024 EDM Device Operation](#)
[Table 4: 2024 Storm Overflow Spill Performance](#)
[Table 5: 2024 Storm Overflow Spill Reasons](#)
[Table 6: 2024 EDM Storm Overflow Annual Return Data Entry](#)

Table 1: 2024 EDM Headlines	Anglian Water (AW)	Dwr Cymru Welsh Water (BCWW) (in English)	Norfolk and Northampton Water (NWN)	Severn Trent Water (STW)	South West Water (SWW)	Southern Water (SW)	Thames Water (TW)	United Utilities (UU)	Wessex Water (WSSX)	Yorkshire Water (YWS)	Water Company Total	Water Compar- Average
Total no. storm overflows listed in the annual return in 2024	1,444	128	1,560	2,459	1,370	978	590	2,270	1,295	2,191	14,285	-
Total no. active storm overflows listed in the annual return in 2024	1,444	126	1,559	2,448	1,362	977	588	2,270	1,295	2,185	14,254	-
Total no. storm overflows with EDM commissioned	1,444	126	1,559	2,448	1,362	977	588	2,270	1,295	2,185	14,254	-
% active storm overflows listed with EDM commissioned	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	-	100%
Total no. storm overflows with spill data in 2024	1,435	124	1,551	2,445	1,361	971	585	2,244	1,295	2,171	14,182	-
Average no. spills per storm overflow with spill data in 2024	30.6	41.1	26.3	25.4	41.3	30.2	39.4	34.7	33.9	31.4	-	31.8
Average duration (hrs) per monitored spill event in 2024	10.2	6.2	6.0	7.3	9.7	10.4	12.9	5.8	9.2	6.3	-	8.0

Table 2: 2024 EDM Summary Statistics												
	Anglian Water (AW)	Dwr Cymru Welsh Water (DCWW) (in England)	Northumbrian Water (NW)	Severn Trent Water (ST)	South West Water (SWW)	Southern Water (SW)	Thames Water (TW)	United Utilities (UU)	Wessex Water (WSX)	Yorkshire Water (YW)	Water Company Total	Water Average
Total no. number of monitored spill events in 2024	43,919	5,101	40,792	62,085	56,173	29,355	23,061	77,817	43,931	68,164	450,398	-
Average no. spills per storm overflow with spill data in 2024	30.6	41.1	26.3	25.4	41.3	30.2	39.4	34.7	33.9	31.4	-	31.8
Total duration (hrs) of monitored spill events in 2024	448,938	31,770	246,587	454,155	544,439	304,537	298,081	450,778	404,880	430,263	3,614,428	-
Average duration (hrs) per monitored spill event in 2024	10.2	6.2	6.0	7.3	9.7	10.4	12.9	5.8	9.2	6.3	-	8.0
% storm overflows spilled 510 times in 2024	38.9%	25.0%	41.5%	44.9%	36.6%	45.5%	37.4%	37.0%	33.4%	35.7%	-	39.0%
Percentage time operating [spilling] during 2024 per overflow (average)	3.6%	2.9%	1.8%	2.1%	4.6%	3.6%	5.8%	2.3%	3.6%	2.3%	-	2.9%

[illegible]

Table 4: 2024 Storm Overflow Spill Performance	Anglian Water (AWIS)	Dwr Cymru Welsh Water (DCWW) (in England)	Northumbrian Water (NWW)	Severn Trent Water (STW)	South West Water (SWW)	Southern Water (SW)	Thames Water (TW)	United Utilities (UU)	Wessex Water (WSSW)	Yorkshire Water (YWS)	Water Company Total	Water Company Average
% with EDM installed & provided count data - with 0 spill count (did not spill)	10.5%	4.8%	13.2%	15.3%	14.8%	14.5%	10.3%	11.9%	11.1%	10.2%	-	12.5%
% storm overflows with spill data - recorded 21 spills or count	89.5%	95.2%	86.8%	84.7%	85.2%	85.5%	89.7%	88.1%	88.9%	89.8%	-	87.5%
% recorded 5 spills or less	28.2%	17.7%	31.4%	34.4%	28.9%	36.4%	29.6%	28.4%	26.9%	26.3%	-	29.8%
% recorded 10 spills or less	38.9%	25.0%	41.5%	44.9%	36.6%	45.5%	37.4%	37.0%	33.4%	35.7%	-	39.0%
% recorded 10 spills	61.1%	75.0%	58.5%	55.1%	63.4%	54.5%	62.6%	63.0%	66.6%	64.3%	-	61.0%
% recorded 20 spills or more	48.4%	61.3%	46.9%	41.7%	53.4%	44.2%	49.9%	51.9%	55.0%	50.8%	-	49.0%
% recorded 40 spills or more	27.7%	38.7%	26.2%	22.6%	37.8%	27.7%	34.7%	33.6%	33.5%	29.7%	-	29.8%
% recorded 60 spills or more	15.3%	25.8%	11.3%	12.8%	27.1%	18.5%	24.1%	20.9%	18.8%	16.5%	-	17.6%
% recorded 100 spills or more	5.7%	11.3%	2.8%	4.0%	12.0%	6.5%	12.1%	7.9%	6.2%	5.8%	-	6.5%
% recorded 200 spills or more	0.3%	0%	0.4%	0.4%	1.3%	0.6%	1.2%	0.2%	0.3%	0.2%	-	0.4%

Table 5: 2024 Storm Overflow Spill Reasons	Anglian Water (AWS)	Dwr Cymru Welsh Water (DWCW) (in England)	Northumbrian Water (NW)	Sewer Trent Water (STW)	South West Water (SWW)	Southern Water (SW)	Thames Water (TW)	United Utilities (UU)	Wessex Water (WSSA)	Yorkshire Water (YWS)	Water Company Total	Water Company Average
Please note these metrics are in development. In 2024 there is some inconsistency in approach by different Water & Sewerage Companies												
No. monitored storm overflows that spilled >60 in one year	216	29	174	303	364	178	140	459	232	353	2,448	-
Of those that spilled over SOAF thresholds of >60x in one year, % with a reason provided	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	-	100%
Of those that spilled over SOAF thresholds of >60x in one year, what % due to exceptional weather throughout the year?	88.9%	0%	0%	57.1%	20.9%	23.6%	80.7%	26.8%	97.8%	0%	-	38.6%
Of those that spilled over SOAF thresholds of >60x in one year, what % due to other operational (incl. asset maintenance)?	11.1%	37.9%	33.3%	8.6%	37.1%	67.4%	12.9%	9.4%	1.7%	14.7%	-	20.1%
Of those that spilled over SOAF thresholds of >60x in one year, what % due to hydraulic capacity reasons?	0%	27.6%	66.7%	34.3%	26.4%	8.4%	2.1%	62.1%	0.4%	84.4%	-	37.8%
Of those that spilled over SOAF thresholds of >60x in one year, what % N/A - Ongoing investigation for primary reasons?	0%	34.5%	0%	0%	15.7%	0.6%	4.3%	1.7%	0%	0.8%	-	3.5%

Storm overflows are permitted to operate due to rainfall and/or snowmelt. The root cause for high spill frequency can be attributed to three main reasons over and above response to typical rainfall. These are fully defined in the Storm Overflow Assessment Framework (SOAF) and summarised below:

exceptional weather: This does not refer to individual rainfall events, but rather the rainfall across the reporting year. Two datasets can be used to determine whether rainfall in the reporting year was "exceptional" or not (over & above typical rainfall) – (1) Environment Agency water situation reports or (2) local rainfall records.

If rainfall was exceptional and deemed the primary reason for high spill count then this is indicated in the annual return (Column W).

Asset Maintenance: Where the asset (storm overflow) and potentially parts of the upstream & downstream sewer network have not operated as designed/expected, high spill counts (over 60 times per year) can be caused

If asset maintenance is deemed the primary reason for high spill count this is indicated in the annual return (column W). The different asset maintenance categories are listed in the EDM dataset README guide Appendix A.

Hydraulic capacity: If the reason for a high spilling storm overflow (over 60 times per year) is neither "exceptional weather" nor "asset maintenance" then the reason is classified under the "Hydraulic capacity" category.

This indicates there is insufficient capacity (conveyance or storage) in the sewer network to cope with the wastewater flow plus typical rainfall entering the sewer network

Link to: [Storm Overflow Assessment Framework \(SOAF\)](#)

[illegible]