

Roma Firefighting Equipment Pty
64 Spencer Street
Roma, QLD 4455
Ph: 07 4622 6999 Fax:
ABN 48118763812

Asset Record - Job No. 697
Huracan
151 Warooby Lane
Roma Qld 4455

Inspection Date: 31/07/2024
Contact: John Hollingworth
Phone:

Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012

| Asset ID | Building/ Area Name | Location | Size | Type | Rating/Flow | Brand | Date | Service | Pass / Fail |
|----------|---------------------|----------|-------|------|-------------|-----------|------------|-----------|-------------|
| 3773 | Shed | South | 9.0kg | DCP | 6A:80BE | Flamestop | 30/07/2024 | 6 Monthly | Pass |
| 3774 | Shed | North | 9.0kg | DCP | 6A:80BE | Flamestop | 30/07/2024 | 6 Monthly | Pass |

Asset Register - First Aid Kit

| Asset ID | Building/ Area Name | Location | Type | Comments | Date | Service | Pass / Fail |
|----------|---------------------|----------|--------------------|----------------------|------------|-----------|-------------|
| 4047 | Shed | Workshop | General Wall Mount | | 30/07/2024 | 6 Monthly | Pass |
| 4048 | Shed | Workshop | Eye Wash Station | 2x 500ml Exp: oct 26 | 30/07/2024 | 6 Monthly | Pass |

Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012

| Asset ID | Building/ Area Name | Location | Size | Type | Rating/Flow | Brand | Date | Service | Pass / Fail |
|----------|---------------------|-----------------------|-------|------|-------------|----------|------|-----------|-------------|
| 3775 | Vehicles | 630-ZOP, Toyota Hilux | 1.0kg | DCP | 1A:10BE | Eversafe | | 6 Monthly | Not Tested |

Asset Register - First Aid Kit

| Asset ID | Building/ Area Name | Location | Type | Comments | Date | Service | Pass / Fail |
|----------|---------------------|-----------------------|---------------------|----------|------|-----------|-------------|
| 4049 | Vehicles | 630-ZOP, Toyota Hilux | Unknown - Blue Case | | | 6 Monthly | Not Tested |

Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012

| Asset ID | Building/ Area Name | Location | Size | Type | Rating/Flow | Brand | Date | Service | Pass / Fail |
|----------|---------------------|-----------------------|-------|------|-------------|----------|------------|-----------|-------------|
| 3776 | Vehicles | 595-YNM, Toyota Hilux | 1.0kg | DCP | 1A:10BE | Eversafe | 30/07/2024 | 6 Monthly | Pass |

Asset Register - First Aid Kit

| Asset ID | Building/ Area Name | Location | Type | Comments | Date | Service | Pass / Fail |
|----------|---------------------|-----------------------|---------|----------|------------|-----------|-------------|
| 4050 | Vehicles | 595-YNM, Toyota Hilux | Unknown | | 30/07/2024 | 6 Monthly | Pass |

Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012

| Asset ID | Building/ Area Name | Location | Size | Type | Rating/Flow | Brand | Date | Service | Pass / Fail |
|----------|---------------------|------------------------|-------|------|-------------|----------|------------|-----------|-------------|
| 3777 | Vehicles | 076-SZQ, Nissan Navara | 1.0kg | DCP | 1A:10BE | Eversafe | 30/07/2024 | 6 Monthly | Pass |

Roma Firefighting Equipment Pty
64 Spencer Street
Roma, QLD 4455
Ph: 07 4622 6999 Fax:
ABN 48118763812

Asset Record - Job No. 697

Huracan
151 Warooby Lane
Roma Qld 4455

Inspection Date: 31/07/2024
Contact: John Hollingworth
Phone:

| Asset Register - First Aid Kit | | | | | | | |
|--------------------------------|---------------------|------------------------|---------|----------|------------|-----------|-------------|
| Asset ID | Building/ Area Name | Location | Type | Comments | Date | Service | Pass / Fail |
| 4051 | Vehicles | 076-SZQ, Nissan Navara | Unknown | | 30/07/2024 | 6 Monthly | Pass |

| Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012 | | | | | | | | | |
|--|---|---------------------|-------|------|-------------|-----------|------------|----------|-------------|
| Asset ID | Building/ Area Name | Location | Size | Type | Rating/Flow | Brand | Date | Service | Pass / Fail |
| 3778 | Vehicles | XQ26HC, Isuzu Truck | 1.5kg | DCP | 2A:30BE | Flamestop | 30/07/2024 | 5 Yearly | Fail |
| Notes | Expired. Replaced With New, DOM Feb 24. | | | | | | | | |

| Asset Register - First Aid Kit | | | | | | | |
|--------------------------------|---------------------|---------------------|---------------------|----------|------------|-----------|-------------|
| Asset ID | Building/ Area Name | Location | Type | Comments | Date | Service | Pass / Fail |
| 4052 | Vehicles | XQ26HC, Isuzu Truck | Unknown - Blue Case | | 30/07/2024 | 6 Monthly | Pass |

| Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012 | | | | | | | | | |
|--|---------------------|----------------------|-------|------|-------------|----------|------------|-----------|-------------|
| Asset ID | Building/ Area Name | Location | Size | Type | Rating/Flow | Brand | Date | Service | Pass / Fail |
| 3779 | Vehicles | 806-YCA, Isuzu Truck | 1.0kg | DCP | 1A:10BE | Eversafe | 30/07/2024 | 6 Monthly | Pass |

| Asset Register - First Aid Kit | | | | | | | |
|--------------------------------|---------------------|----------------------|---------|----------|------------|-----------|-------------|
| Asset ID | Building/ Area Name | Location | Type | Comments | Date | Service | Pass / Fail |
| 4053 | Vehicles | 806-YCA, Isuzu Truck | Unknown | | 30/07/2024 | 6 Monthly | Pass |

| Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012 | | | | | | | | | |
|--|---------------------|----------|-------|------|-------------|----------|------------|-----------|-------------|
| Asset ID | Building/ Area Name | Location | Size | Type | Rating/Flow | Brand | Date | Service | Pass / Fail |
| 18963 | Truck XB14GD | | 1.0kg | DCP | 1A:10BE | Eversafe | 30/07/2024 | 6 Monthly | Pass |

| Asset Register - First Aid Kit | | | | | | | |
|--------------------------------|---------------------|----------|------------|----------|------------|-----------|-------------|
| Asset ID | Building/ Area Name | Location | Type | Comments | Date | Service | Pass / Fail |
| 18964 | Truck Rego XB14GD | Inside | Green Case | | 30/07/2024 | 6 Monthly | Pass |

Roma Firefighting Equipment Pty
64 Spencer Street
Roma, QLD 4455
Ph: 07 4622 6999 Fax:
ABN 48118763812

Asset Record - Job No. 697
Huracan
151 Warooby Lane
Roma Qld 4455

Inspection Date: 31/07/2024
Contact: John Hollingworth
Phone:

| Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012 | | | | | | | | | |
|--|---------------------|----------|-------|------|-------------|--------|------------|-----------|-------------|
| Asset ID | Building/ Area Name | Location | Size | Type | Rating/Flow | Brand | Date | Service | Pass / Fail |
| 18966 | Truck XB86IC | | 4.5kg | DCP | 6A:80BE | Presto | 30/07/2024 | 6 Monthly | Pass |

| Asset Register - First Aid Kit | | | | | | | | | |
|--------------------------------|---------------------|----------|----------|------------------------|------------|---------|-------------|--|--|
| Asset ID | Building/ Area Name | Location | Type | Comments | Date | Service | Pass / Fail | | |
| 18967 | TRUCK XB86IC | | Red Case | Lot 26560 EXP 30/06/25 | 30/07/2024 | | Pass | | |

Description Of Work

Routine Six Monthly Inspection & Maintenance of Fire Protection Equipment Completed 31/07/2024.

Scope of Work

Asset Type Portable and Wheeled Fire Extinguishers - Service Level 6 Monthly - Qty 7
Asset Type Portable and Wheeled Fire Extinguishers - Service Level 5 Yearly - Qty 1
Asset Type First Aid Kit - Service Level 6 Monthly - Qty 7

| Comments / Recommendations |
|----------------------------|
| |

QBCC: 1114149 ECL: 68290

Technician (Print Name): Sharneel Prasad

Licence No.

15367925

Customer (Print Name): Matthew Auld

Technician (Signature):



Customer (Signature):



Roma Firefighting Equipment Pty

64 Spencer Street

Roma, QLD 4455

Ph: 07 4622 6999 Fax:

ABN 48118763812

Asset Record - Job No. 697

Huracan

151 Warooby Lane

Roma Qld 4455

Inspection Date: 31/07/2024

Contact: John Hollingworth

Phone: