64 Spencer Street Roma, QLD 4455

Ph: 07 4622 6999 Fax:

ABN 48118763812

# Asset Record - Job No. 5255

#### Huracan

151 Warooby Lane Roma Qld 4455

**Inspection Date:** 23/07/2025 Contact:

John Hollingworth

Phone:

Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012										
Asset ID	Building/ Area Name	Location	Size	Туре	Rating/Flow	Brand	Date	Service	Pass / Fail	
3773	Shed	South	9.0kg	DCP	6A:80BE	Flamestop	23/07/2025	5 Yearly	Fail	
Failure Points	Extinguisher has reach	ed end of life	<u>'</u>	<u> </u>	'					
Notes	Failed and replaced with new one 9kg evasafe. DOM JUN 25,6A.80BE									
3774	Shed	North	9.0kg	DCP	6A:80BE	Flamestop	23/07/2025	5 Yearly	Fail	
Failure Points	Extinguisher has reached end of life			<u> </u>	'					
Notes	Failed.and replaced with new one 9kg evasafe, DOM JUN 25, 6A.80BE									

Asset Register - First Aid Kit									
Asset ID	Building/ Area Name	Location	Туре	Comments	Date	Service	Pass / Fail		
4047	Shed	Workshop	General Wall Mount		23/07/2025	Yearly	Pass		
4048	Shed	Workshop	Eye Wash Station	2x 500ml Exp: oct 26	23/07/2025	Yearly	Pass		

Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012										
Asset ID	Building/ Area Name	Location	Size	Туре	Rating/Flow	Brand	Date	Service	Pass / Fail	
22205	Vehicles	630-ZOP, Toyota Hilux	1.0kg	DCP	1A:10BE	Eversafe	23/07/2025	Yearly	Pass	

Asset Register - First Aid Kit									
Asset ID	Building/ Area Name	Location	Туре	Comments	Date	Service	Pass / Fail		
4049	Vehicles	630-ZOP, Toyota Hilux	Unknown - Blue Case		23/07/2025	Yearly	Pass		

Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012										
Asset ID	Building/ Area Name	Location	Size	Туре	Rating/Flow	Brand	Date	Service	Pass / Fail	
22206	Vehicles	595-YNM, Toyota Hilux	1.0kg	DCP	1A:10BE	Eversafe	23/07/2025	Yearly	Pass	

Asset Register - First Aid Kit									
Asset ID	Building/ Area Name	Location	Type	Comments	Date	Service	Pass / Fail		
4050	Vehicles	595-YNM, Toyota Hilux	Unknown		23/07/2025	Yearly	Pass		

64 Spencer Street Roma, QLD 4455

Ph: 07 4622 6999 Fax:

ABN 48118763812

## Asset Record - Job No. 5255

### Huracan

151 Warooby Lane Roma Qld 4455 Inspection Date: 23/07/2025

**Contact:** John Hollingworth

Service

6 Monthly

Date

Pass / Fail

Not Tested

Phone:

Asset Regis	ster - Portable and \	Wheeled Fire Ex	tinguishers - AS18	51.2012					
Asset ID	Building/ Area Name	Location	Size	Туре	Rating/Flow	Brand	Date	Service	Pass / Fa
25062		076SZQ	1.0kg	DCP	1A:10BE	Evasafe	23/07/2025	Yearly	Pass
Asset Regis	ster - First Aid Kit								
Asset ID	Building/ Area N	ame Locat	ion	Туре	Comi	nents	Date	Service	Pass / Fa
4051	Vehicles		ZQ, Nissan Navara	Unknown			23/07/2025	Yearly	Pass
Asset Regis	ster - Portable and \	Wheeled Fire Fx	tinguishers - AS18	51 2012					
Asset ID	Building/ Area Name	Location	Size	Туре	Rating/Flow	Brand	Date	Service	Pass / Fa
3779	Vehicles	806-YCA, Isuzu Truck	1.0kg	DCP	1A:10BE	Eversafe		Yearly	Not Teste
Asset Regis	ster - First Aid Kit								
Asset ID	Building/ Area N	ame Locat	ion	Туре	Type Comments		Date	Service	Pass / Fai
4053	Vehicles	806-Y	CA, Isuzu Truck	Unknown				Yearly	Not Teste
Asset Regis	ster - Portable and \	Wheeled Fire Ex	tinguishers - AS18!	51.2012					
Asset ID	Building/ Area Name	Location	Size	Туре	Rating/Flow	Brand	Date	Service	Pass / Fa
18966	Truck XB86IC		4.5kg	DCP	6A:80BE	Presto		Yearly	Not Teste
Asset Regis	ster - First Aid Kit								
Asset ID	Building/ Area Name Location		ion	Туре	Comi	Comments		Service	Pass / Fa
18967	TRUCK XB86IC			RFE red bag	Lot 20	6560 EXP 30/06/25		Yearly	Not Teste
Asset Regis	ster - Portable and \	Wheeled Fire Ex	tinguishers - AS18!	51.2012					
Asset ID	Building/ Area	Location	Size	Type	Rating/Flow	Brand	Date	Service	Pass / Fai

#### **Description Of Work**

Name

Asset ID

22204

Routine 12 monthly inspection and maintenance of fire protection equipment July 2025

Location

TRUCK XB86IC

Size

9.0kg

Type

DCP

Rating/Flow

10A:80BE

Brand

Flamestop

**Comments / Recommendations** 

64 Spencer Street Roma, QLD 4455

Ph: 07 4622 6999 Fax:

ABN 48118763812

# Asset Record - Job No. 5255

**Huracan** 151 Warooby Lane Roma Qld 4455 **Inspection Date:** 23/07/2025

John Hollingworth

Contact: Phone:

Asset Type Portable and Wheeled Fire Extinguishers - Service Level 5 Yearly - Quantity 2
Asset Type First Aid Kit - Service Level Yearly - Quantity 7
Asset Type Portable and Wheeled Fire Extinguishers - Service Level Yearly - Quantity 5
Asset Type Portable and Wheeled Fire Extinguishers - Service Level 6 Monthly - Quantity 1

QBCC: 1114149 ECL: 68290			
Maintenance Complies with QDC, MP6.1. (Where Applicable)			
Technician (Print Name):	Licence No.	Customer (Print Name):	

Page 3/4

64 Spencer Street Roma, QLD 4455

Ph: 07 4622 6999 Fax:

ABN 48118763812

\_\_\_\_\_

## Asset Record - Job No. 5255

Huracan

151 Warooby Lane Roma Qld 4455 **Inspection Date:** 23/07/2025

**Contact:** John Hollingworth

Phone: