

**MAINTENANCE RECORD - Fire Safety Equipment Page 1 of 1**

Customer:	Huracan	Service Due:	New Customer		Location:	151 Warooby Lane (4th House on Left)					
Phone:	0414 717 907	Serviced Completed:	22/05/20		5	Roma Qld 4455					
Contact:	John Hollingworth	Serviced by:	Hayden Tovey								
Email:	jhollingworth@huracan.com.au		Po Box 1070 Roma QLD 4455								
Comments:											
Induction Required? No Yes Details:					JSA/SOP Required? No Yes Reference No:						
Standard P.P.E. Additional Requirements:					Permit Required? No Yes Permit No:						
Driving: Tar Dirt Track Animals Water 4WD Flag Approval					Journey Management: No Yes Phone. No: 0457677974						
Other Hazards / Environmental / Cultural heritage:											
Equip. No.	Location	Size	Type	Rating/Flow	Brand	D.O.M.	Last P.T.	Service	Comments	A/E	
	Shed South	9.0kg	DCP	6A:80BE	Flamestop	Feb-14	Feb-14	4			
FIRST AID	Workshop First Aid Kit (General)	Check OK	✓	Restocked		Replaced					
		9.0kg	DCP	6A:80BE	Flamestop	Feb-14	Feb-14	4			
	630-ZOP Toyota Hilux	1.0kg	DCP	1A:10BE	Eversafe	Jan-20	Jan-20	Inspect	Supplied in April		
FIRST AID	630-ZOP Toyota Hilux	Check OK	✓	Restocked		Replaced					
	595-YNM Toyota Hilux								No Extinguisher, Supply 1.0kg E/		
FIRST AID	595-YNM Toyota Hilux	Check OK		Restocked		Replaced			No FA Kit, Supply Small Remote		
	076-SZQ Toyota Hilux	1.5kg	DCP	2A:30BE	Chubb	Jul-12	Jul-12	Inspect	No Hose, Due PT, Unviable, Supply		
FIRST AID	076-SZQ Toyota Hilux	Check OK		Restocked	✓	Replaced			Report 7163		
	983-WLR Tilt Tray	2.3kg	DCP	2A:40BE	Chubb	Aug-12	Aug-12	4			
FIRST AID	983-WLR Tilt Tray	Check OK		Restocked		Replaced			No FA Kit, Supply Travel Kit HG Case		
	XQZ6HC Isuzu Truck	1.5kg	DCP	2A:30BE	Flamestop	Mar-19	Mar-19	2			
FIRST AID	XQZ6HC Isuzu Truck (Blue Case)	Check OK	✓	Restocked		Replaced					
	806-XCA Isuzu Truck	1.0kg	DCP	1A:10BE	Eversafe	May-18	May-18	2			
FIRST AID	806-XCA Isuzu Truck	Check OK	✓	Restocked		Replaced					
	XQ89BG Isuzu Truck	1.0kg	DCP	1A:10BE	Eversafe	May-18	May-18	2			
FIRST AID	806-XCA Isuzu Truck (Green Kit)	Check OK		Restocked	✓	Replaced			Report 7164		
FIRST AID	General Wall Mount	Check OK		Restocked		Replaced			Supplied on 19/05/2020		
FIRST AID	Braun Eye Wash Wall Mount	Check OK		Restocked		Replaced			Supplied on 19/05/2020		
A/W - Water Foam - Fluorine Free Foam CO2 - Carbon Dioxide DCP - Dry Chemical Powder W/C - Wet Chemical NAF - NAF PIII F/B - Fire Blanket FHR - Fire Hose Reel											
HYD - Fire Hydrant W/M - Water Mist R&R - Repair & Repressurise Service Levels 1 - Six Monthly 2 - Annual 4 - Five Yearly 5 - Recharge After Use											
Maintenance Complies with QDC, MP6.1.		✓	Equipment is in proper working order				✓	Licence Number		1114149	
I have authorised and accepted the work detailed above and have noted the hazard / observation / incident reported.										Signature	Date
Did you encounter other hazards on the job? No Yes Have you completed a Hazard Report? No Yes							Admin: Report Number		Filed Yes		
An INCIDENT / NEAR MISS occurred. An Incident Report was completed and a copy given to the Client							Admin: Report Number		Filed Yes		