

INTAKE-ARBITER -- FREE-COOLING DECISION REPORT

Data centres over-cool, continuously, because nobody can promise them the hours ahead. A chiller plant needs hours of notice to change mode, and a thermometer only ever reports NOW -- so the mechanical chillers keep running through hours that outside air could have cooled for free. FortyGuard closes that gap with heat intelligence 2 m above the ground, the height a ground-mounted condenser actually breathes. This agent turns that forecast into an hour-by-hour schedule carrying a calibrated safety bound.

THE SITE

Location Google, SC -- station KSAV, America/New_York
Committed pair OSM 1069388141 -> 1069388147
Google / Google
Facade gap 99.2 m between the two halls
Weather record 43,716 real hourly records from KSAV
Plume physics 576 steady-state solves on this site's own footprints; worst intake rise 0.3240 C at 210 deg

FortyGuard data: weather and geometry are this site's own; the four measured FortyGuard level offsets and the N-26 coverage record are Ashburn's, because only Ashburn has forecast/outcome day pairs. Quote the hours for this site; quote the coverage for Ashburn.

THIS REPORT IS A SNAPSHOT, NOT THE LIVE PAGE

The interface recomputes the decision for whatever configuration a reader selects. This file was generated at build time for the ONE configuration named below, chosen because it is the configuration in which this site's agent does the most while still changing mode at least once. If the numbers on screen differ from the numbers here, the configuration differs -- compare the two lists before concluding anything else.

Day 2021-01-11 (safe_sector)
Plant limit 18.0 C
Notice required 6 h
Forecast skill 0.00 relative to persistence
Level anchor sensor
Condenser bank longest facade
Switch budget 2 mode changes per day
Minimum dwell 3 h
Max dew point 15.0 C (Green Grid WP#46 p.6)

WHAT THE AGENT DID ON THIS DAY

The agent ran free cooling for 4 of 24 hours with 2 mode changes. The reactive incumbent took 11 hours -- 7 more -- but declared 0 unsafe hours against the agent's 0. 10 hours were safe but still ran chillers, because the schedule could not afford them.

Agent 4 of 24 hours free cooling, 2 mode change(s), 0 unsafe hour(s)
Incumbent 11 of 24 hours free cooling, 2 mode change(s), 0 unsafe hour(s)
10 hour(s) passed every gate and still ran chillers, because the schedule could not afford them

EVERY HOUR, AND THE REASON FOR IT

hh	mode	safe	binding	bound	limit	actual	margin
00	FREE	yes	-	4.567	18.0	5.560	3.230
01	FREE	yes	-	5.091	18.0	6.110	2.901
02	FREE	yes	-	5.091	18.0	3.890	2.280
03	FREE	yes	-	5.730	18.0	5.002	2.610
04	mechanical	no	refusal	5.681	18.0	4.440	2.337
05	mechanical	yes	-	5.655	18.0	6.110	2.070
06	mechanical	yes	-	6.180	18.0	7.220	2.284

07	mechanical	no	refusal	7.371	18.0	7.780	1.829
08	mechanical	no	refusal	8.463	18.0	8.890	2.955
09	mechanical	yes	-	12.950	18.0	10.562	4.054
10	mechanical	yes	-	15.047	18.0	13.330	4.732
11	mechanical	no	dry-bulb	18.386	18.0	13.330	4.936
12	mechanical	no	dry-bulb	20.626	18.0	14.440	5.092
13	mechanical	no	dry-bulb	21.170	18.0	14.440	5.283
14	mechanical	no	dry-bulb	19.531	18.0	15.560	4.182
15	mechanical	no	dry-bulb	18.421	18.0	15.000	3.571
16	mechanical	no	dry-bulb	18.426	18.0	14.440	3.078
17	mechanical	yes	-	16.183	18.0	13.890	3.222
18	mechanical	yes	-	15.098	18.0	13.330	3.113
19	mechanical	yes	-	13.426	18.0	12.780	3.165
20	mechanical	no	refusal	13.496	18.0	12.220	3.285
21	mechanical	yes	switch budget	12.901	18.0	12.220	3.671
22	mechanical	yes	switch budget	12.857	18.0	12.220	4.118
23	mechanical	yes	switch budget	12.851	18.0	12.220	3.989

bound = the agent's 90 %-nominal upper bound on intake air, forecast plus margin
actual = what the intake temperature turned out to be, from the station record
margin = group-conditional forecast error for that hour of day, plus plume spread

THE REASONING, HOUR BY HOUR

00:00 FREE-COOLING

Free cooling. The 90 %-nominal upper bound on intake air is 4.567 C, which is 13.433 C under the 18.0 C plant limit. That bound is the forecast plus a margin of 3.230 C, and the margin is measured, not chosen: 3.113 C of group-conditional forecast error for this hour of day, plus 0.1172 C for how much the plume could move if the wind direction is off by the amount FortyGuard's forecast is actually off by.

01:00 FREE-COOLING

Free cooling. The 90 %-nominal upper bound on intake air is 5.091 C, which is 12.909 C under the 18.0 C plant limit. That bound is the forecast plus a margin of 2.901 C, and the margin is measured, not chosen: 2.820 C of group-conditional forecast error for this hour of day, plus 0.0812 C for how much the plume could move if the wind direction is off by the amount FortyGuard's forecast is actually off by.

02:00 FREE-COOLING

Free cooling. The 90 %-nominal upper bound on intake air is 5.091 C, which is 12.909 C under the 18.0 C plant limit. That bound is the forecast plus a margin of 2.280 C, and the margin is measured, not chosen: 2.199 C of group-conditional forecast error for this hour of day, plus 0.0812 C for how much the plume could move if the wind direction is off by the amount FortyGuard's forecast is actually off by.

03:00 FREE-COOLING

Free cooling. The 90 %-nominal upper bound on intake air is 5.730 C, which is 12.270 C under the 18.0 C plant limit. That bound is the forecast plus a margin of 2.610 C, and the margin is measured, not chosen: 2.443 C of group-conditional forecast error for this hour of day, plus 0.1676 C for how much the plume could move if the wind direction is off by the amount FortyGuard's forecast is actually off by.

04:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

05:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 5.655 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more.

This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

06:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 6.180 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

07:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

08:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

09:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 12.950 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

10:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 15.047 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

11:00 MECHANICAL [dry-bulb]

Mechanical. The upper bound on intake air is 18.386 C against a 18.0 C limit, so it fails by 0.386 C. It would take a limit 0.386 C higher, or a bound 0.386 C tighter, to change this hour.

12:00 MECHANICAL [dry-bulb]

Mechanical. The upper bound on intake air is 20.626 C against a 18.0 C limit, so it fails by 2.626 C. It would take a limit 2.626 C higher, or a bound 2.626 C tighter, to change this hour.

13:00 MECHANICAL [dry-bulb]

Mechanical. The upper bound on intake air is 21.170 C against a 18.0 C limit, so it fails by 3.170 C. It would take a limit 3.170 C higher, or a bound 3.170 C tighter, to change this hour.

14:00 MECHANICAL [dry-bulb]

Mechanical. The upper bound on intake air is 19.531 C against a 18.0 C limit, so it fails by 1.531 C. It would take a limit 1.531 C higher, or a bound 1.531 C tighter, to change this hour.

15:00 MECHANICAL [dry-bulb]

Mechanical. The upper bound on intake air is 18.421 C against a 18.0 C limit, so it fails by 0.421 C. It would take a limit 0.421 C higher, or a bound 0.421 C tighter, to change this hour.

16:00 MECHANICAL [dry-bulb]

Mechanical. The upper bound on intake air is 18.426 C against a 18.0 C limit, so it fails by 0.426 C. It would take a limit 0.426 C higher, or a bound 0.426 C tighter, to change this hour.

17:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 16.183 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

18:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 15.098 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

19:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 13.426 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

20:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

21:00 MECHANICAL [switch budget]

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 12.901 C against a 18.0 C limit. The schedule is what forbids it: the switch budget of 2 changes per day is already committed elsewhere. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

22:00 MECHANICAL [switch budget]

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 12.857 C against a 18.0 C limit. The schedule is what forbids it: the switch budget of 2 changes per day is already committed elsewhere. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

23:00 MECHANICAL [switch budget]

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 12.851 C against a 18.0 C limit. The schedule is what forbids it: the switch budget of 2 changes per day is already committed elsewhere. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

Generated by INTAKE-ARBITER/src/report.py. Verified by being read back: the file was reopened after writing and every hour of the schedule, the headline counts and this site's own name were confirmed present.