

INTAKE-ARBITER -- FREE-COOLING DECISION REPORT

An agent that decides, hour by hour, whether outside air can cool a data centre.

THE SITE

Location AZ facility AZ_way_1456975949 -- station KFFZ, America/Phoenix
Committed pair OSM 1456975948 -> 1456975949
OSM way 1456975948 / OSM way 1456975949
Facade gap 118.8 m between the two halls
Weather record 41,919 real hourly records from KFFZ
Plume physics 576 steady-state solves on this site's own footprints; worst intake rise 0.4364 C at 315 deg

FortyGuard data: weather and geometry are this site's own; the four measured FortyGuard level offsets and the N-26 coverage record are Ashburn's, because only Ashburn has forecast/outcome day pairs. Quote the hours for this site; quote the coverage for Ashburn.

THIS REPORT IS A SNAPSHOT, NOT THE LIVE PAGE

The interface recomputes the decision for whatever configuration a reader selects. This file was generated at build time for the ONE configuration named below, chosen because it is the configuration in which this site's agent does the most while still changing mode at least once. If the numbers on screen differ from the numbers here, the configuration differs -- compare the two lists before concluding anything else.

Day 2021-02-28 (knife_edge)
Plant limit 21.0 C
Notice required 3 h
Forecast skill 0.50 relative to persistence
Level anchor sensor
Condenser bank longest facade
Switch budget 2 mode changes per day
Minimum dwell 3 h
Max dew point 15.0 C (Green Grid WP#46 p.6)

WHAT THE AGENT DID ON THIS DAY

The agent ran free cooling for 1 of 24 hours with 1 mode change. The reactive incumbent took 24 hours -- 23 more -- but declared 0 unsafe hours against the agent's 0.5 hours were safe but still ran chillers, because the schedule could not afford them.

Agent 1 of 24 hours free cooling, 1 mode change(s), 0 unsafe hour(s)
Incumbent 24 of 24 hours free cooling, 1 mode change(s), 0 unsafe hour(s)
5 hour(s) passed every gate and still ran chillers, because the schedule could not afford them

EVERY HOUR, AND THE REASON FOR IT

hh	mode	safe	binding	bound	limit	actual	margin
00	mechanical	no	refusal	11.085	21.0	11.540	1.069
01	mechanical	no	refusal	11.982	21.0	11.671	1.216
02	mechanical	no	refusal	11.147	21.0	10.146	1.103
03	mechanical	no	refusal	11.028	21.0	10.692	0.966
04	mechanical	yes	minimum dwell	10.836	21.0	9.469	0.949
05	mechanical	yes	minimum dwell	9.446	21.0	8.359	0.818
06	mechanical	no	refusal	10.645	21.0	8.094	1.193
07	mechanical	yes	-	10.736	21.0	8.196	1.363
08	mechanical	no	refusal	12.174	21.0	9.809	1.471
09	mechanical	yes	-	12.977	21.0	10.799	1.378
10	mechanical	no	refusal	14.658	21.0	13.890	1.288
11	mechanical	no	refusal	15.803	21.0	15.115	1.286

12	mechanical	no	refusal	15.780	21.0	15.115	1.042
13	mechanical	no	refusal	18.150	21.0	16.802	0.914
14	mechanical	no	refusal	18.073	21.0	16.670	0.721
15	mechanical	no	refusal	17.180	21.0	16.389	0.840
16	mechanical	no	refusal	17.414	21.0	16.110	0.776
17	mechanical	no	refusal	16.807	21.0	15.566	0.939
18	mechanical	no	refusal	14.943	21.0	13.908	1.146
19	mechanical	no	refusal	14.093	21.0	13.330	1.167
20	mechanical	yes	-	13.450	21.0	12.780	1.321
21	mechanical	no	refusal	12.149	21.0	11.688	1.265
22	mechanical	no	refusal	12.053	21.0	11.424	1.295
23	FREE	yes	-	10.836	21.0	8.919	1.303

bound = the agent's 90 %-nominal upper bound on intake air, forecast plus margin

actual = what the intake temperature turned out to be, from the station record

margin = group-conditional forecast error for that hour of day, plus plume spread

THE REASONING, HOUR BY HOUR

00:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

01:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

02:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

03:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

04:00 MECHANICAL [minimum dwell]

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 10.836 C against a 21.0 C limit. The schedule is what forbids it: the plant must hold its current mode for 3 h before changing again. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

05:00 MECHANICAL [minimum dwell]

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 9.446 C against a 21.0 C limit. The schedule is what forbids it: the plant must hold its current mode for 3 h before changing again. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

06:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

07:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 10.736 C against a 21.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

08:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

09:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 12.977 C against a 21.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

10:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

11:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

12:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

13:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

14:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

15:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing

a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

16:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

17:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

18:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

19:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

20:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 13.450 C against a 21.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

21:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

22:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

23:00 FREE-COOLING

Free cooling. The 90 %-nominal upper bound on intake air is 10.836 C, which is 10.164 C under the 21.0 C plant limit. That bound is the forecast plus a margin of 1.303 C, and the margin is measured, not chosen: 1.051 C of group-conditional forecast error for this hour of day, plus 0.2512 C for how much the plume could move if the wind direction is off by the amount FortyGuard's forecast is actually off by.

Generated by INTAKE-ARBITER/src/report.py. Verified by being read back: the file was reopened after writing and every hour of the schedule, the headline counts and this site's own name were confirmed present.