

## AGENTIC-ARBITER -- FREE-COOLING DECISION REPORT

Data centres over-cool, continuously, because nobody can promise them the hours ahead. A chiller plant needs hours of notice to change mode, and a thermometer only ever reports NOW -- so the mechanical chillers keep running through hours that outside air could have cooled for free. FortyGuard closes that gap with heat intelligence 2 m above the ground, the height a ground-mounted condenser actually breathes. This agent turns that forecast into an hour-by-hour schedule carrying a calibrated safety bound.

### THE SITE

Location Amazon Web Services, OH -- station KOSU, America/New\_York  
Committed pair OSM 1386016638 -> 1252196807  
Amazon Web Services / Amazon Web Services  
Facade gap 91.6 m between the two halls  
Weather record 43,575 real hourly records from KOSU  
Plume physics 576 steady-state solves on this site's own footprints; worst intake rise 0.3680 C at 265 deg

FortyGuard data: weather and geometry are this site's own; the four measured FortyGuard level offsets and the N-26 coverage record are Ashburn's, because only Ashburn has forecast/outcome day pairs. Quote the hours for this site; quote the coverage for Ashburn.

### THIS REPORT IS A SNAPSHOT, NOT THE LIVE PAGE

The interface recomputes the decision for whatever configuration a reader selects. This file was generated at build time for the ONE configuration named below, chosen because it is the configuration in which this site's agent does the most while still changing mode at least once. If the numbers on screen differ from the numbers here, the configuration differs -- compare the two lists before concluding anything else.

Day 2021-05-11 (clear\_cool)  
Plant limit 18.0 C  
Notice required 6 h  
Forecast skill 0.00 relative to persistence  
Level anchor sensor  
Condenser bank longest facade  
Switch budget 2 mode changes per day  
Minimum dwell 3 h  
Max dew point 15.0 C (Green Grid WP#46 p.6)

### WHAT THE AGENT DID ON THIS DAY

The agent ran free cooling for 1 of 24 hours with 1 mode change. The reactive incumbent took 11 hours -- 10 more -- but declared 0 unsafe hours against the agent's 0. 7 hours were safe but still ran chillers, because the schedule could not afford them.

Agent 1 of 24 hours free cooling, 1 mode change(s), 0 unsafe hour(s)  
Incumbent 11 of 24 hours free cooling, 2 mode change(s), 0 unsafe hour(s)  
7 hour(s) passed every gate and still ran chillers, because the schedule could not afford them

### EVERY HOUR, AND THE REASON FOR IT

| hh | mode       | safe | binding | bound | limit | actual | margin |
|----|------------|------|---------|-------|-------|--------|--------|
| 00 | mechanical | yes  | -       | 8.473 | 18.0  | 8.890  | 3.989  |
| 01 | mechanical | yes  | -       | 8.473 | 18.0  | 8.330  | 3.456  |
| 02 | mechanical | no   | refusal | 9.215 | 18.0  | 9.440  | 3.433  |
| 03 | mechanical | yes  | -       | 8.930 | 18.0  | 8.330  | 2.936  |
| 04 | mechanical | no   | refusal | 9.169 | 18.0  | 7.780  | 2.663  |
| 05 | mechanical | no   | refusal | 9.727 | 18.0  | 7.780  | 2.933  |
| 06 | mechanical | no   | refusal | 9.587 | 18.0  | 7.780  | 2.597  |

|    |            |     |               |        |      |        |       |
|----|------------|-----|---------------|--------|------|--------|-------|
| 07 | mechanical | yes | -             | 10.041 | 18.0 | 7.220  | 2.588 |
| 08 | mechanical | no  | refusal       | 13.482 | 18.0 | 8.330  | 3.046 |
| 09 | mechanical | no  | refusal       | 15.105 | 18.0 | 10.000 | 3.969 |
| 10 | mechanical | no  | refusal       | 17.310 | 18.0 | 10.560 | 5.077 |
| 11 | mechanical | no  | dry-bulb      | 19.514 | 18.0 | 11.670 | 5.923 |
| 12 | mechanical | no  | refusal       | 20.636 | 18.0 | 12.780 | 6.092 |
| 13 | mechanical | no  | refusal       | 20.115 | 18.0 | 12.780 | 6.088 |
| 14 | mechanical | no  | refusal       | 19.135 | 18.0 | 12.780 | 4.857 |
| 15 | mechanical | no  | refusal       | 18.453 | 18.0 | 13.330 | 4.072 |
| 16 | mechanical | yes | -             | 16.766 | 18.0 | 13.890 | 3.444 |
| 17 | mechanical | no  | refusal       | 15.668 | 18.0 | 12.780 | 2.853 |
| 18 | mechanical | no  | refusal       | 15.092 | 18.0 | 11.110 | 2.787 |
| 19 | mechanical | no  | refusal       | 13.433 | 18.0 | 11.110 | 2.740 |
| 20 | mechanical | yes | minimum dwell | 12.238 | 18.0 | 8.330  | 2.919 |
| 21 | mechanical | yes | minimum dwell | 12.903 | 18.0 | 7.780  | 3.867 |
| 22 | mechanical | no  | refusal       | 13.408 | 18.0 | 7.223  | 4.205 |
| 23 | FREE       | yes | -             | 12.353 | 18.0 | 6.110  | 4.277 |

bound = the agent's 90 %-nominal upper bound on intake air, forecast plus margin  
actual = what the intake temperature turned out to be, from the station record  
margin = group-conditional forecast error for that hour of day, plus plume spread

## THE REASONING, HOUR BY HOUR

---

### 00:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 8.473 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

### 01:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 8.473 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

### 02:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

### 03:00 MECHANICAL

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 8.930 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

### 04:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

### 05:00 MECHANICAL [refusal]

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**06:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**07:00 MECHANICAL**

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 10.041 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

**08:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**09:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**10:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**11:00 MECHANICAL [dry-bulb]**

Mechanical. The upper bound on intake air is 19.514 C against a 18.0 C limit, so it fails by 1.514 C. It would take a limit 1.514 C higher, or a bound 1.514 C tighter, to change this hour.

**12:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**13:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**14:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a

figure it cannot stand behind.

**15:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**16:00 MECHANICAL**

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 16.766 C against a 18.0 C limit. The schedule is what forbids it: no relaxation of either the switch budget or the dwell would free it, so the surrounding hours are worth more. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

**17:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**18:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**19:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**20:00 MECHANICAL [minimum dwell]**

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 12.238 C against a 18.0 C limit. The schedule is what forbids it: the plant must hold its current mode for 3 h before changing again. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

**21:00 MECHANICAL [minimum dwell]**

Mechanical EVEN THOUGH THIS HOUR IS SAFE. Every gate passes -- the bound is 12.903 C against a 18.0 C limit. The schedule is what forbids it: the plant must hold its current mode for 3 h before changing again. This is the one explanation a thermostat cannot give, because a thermostat has no plan to be constrained by. It is also why the decision is a schedule and not a comparison: spending a mode change here would cost a better one later.

**22:00 MECHANICAL [refusal]**

Mechanical, and the reason is a REFUSAL rather than a temperature. At this wind bearing a building sits between the condensers and the air intake. The dispersion model has no representation of a building standing in the flow, so any number it produced here would be meaningless. The agent declines to certify the hour instead of returning a figure it cannot stand behind.

**23:00 FREE-COOLING**

Free cooling. The 90 %-nominal upper bound on intake air is 12.353 C, which is 5.647 C under the 18.0 C plant limit. That bound is the forecast plus a margin of 4.277 C, and the margin is measured, not chosen: 4.144 C of group-conditional forecast error for this hour of day, plus 0.1326 C for how much the plume could move if the wind

direction is off by the amount FortyGuard's forecast is actually off by.  
Generated by AGENTIC-ARBITER/src/report.py. Verified by being read back: the file was  
reopened after writing and every hour of the schedule, the headline counts and this  
site's own name were confirmed present.