TEST REPORT NW-PR-2026-014
Calculation of thermal transmittance according to EN ISO 10077-1 and EN ISO 10077-2
Fictitious test report. Illustrative research data only.

Client	Nordwin Ikkunat Oy, Lahti
Product	W-100 Timber-Aluminium Casement
Report ID	NW-PR-2026-014
Replaces	NW-PR-2025-031
Date of issue	21 August 2026
Laboratory	Fictitious Building Physics Laboratory, Tampere

1. Specimen description
Single-sash inward-opening casement window, laminated pine frame with aluminium cladding.
Glazing: triple glazing 4-16-4-16-4, two low-e coatings, argon filled (90 %), warm-edge spacer.

2. Input values

Quantity	Symbol	Value	Unit
Thermal transmittance of glazing	Ug	0.5	W/(m2K)
Thermal transmittance of frame	Uf	1.2	W/(m2K)
Linear thermal transmittance, glazing edge	Psi_g	0.035	W/(mK)
Visible frame width	bf	112	mm

3. Result
For the reference size 1230 x 1480 mm (EN 14351-1, Annex E):
Uw = 1.1 W/(m2K)

For the test specimen size 1000 x 1200 mm the calculated value is Uw = 1.2 W/(m2K) (informative only).

4. Validity
The result applies to the product W-100 as described in section 1. This report replaces report NW-PR-2025-031.