TEST REPORT NW-PR-2025-031
Calculation of thermal transmittance according to EN ISO 10077-1 and EN ISO 10077-2
Fictitious test report. Illustrative research data only.

Client	Nordwin Ikkunat Oy, Lahti
Product	W-100 Timber-Aluminium Casement
Report ID	NW-PR-2025-031
Date of issue	14 March 2025
Laboratory	Fictitious Building Physics Laboratory, Tampere

1. Specimen description
Single-sash inward-opening casement window, laminated pine frame with aluminium cladding.
Glazing: triple glazing 4-14-4-14-4, one low-e coating, argon filled (90 %).

2. Result
For the reference size 1230 x 1480 mm (EN 14351-1, Annex E):
Uw = 1.2 W/(m2K)