



ADDENDUM
NO. **02**

DATE **06.24.2014**

PROJECT **VMDO Project No.1115, Renovation of Three Residence Halls**
PC# 217-17565-001

TO ALL BIDDERS: The following constitutes Addendum No. 01 to the Contract Documents dated May 19, 2014, for the Renovation of Three Residence Halls. This addendum shall be attached to the Contract Documents and shall be part thereof to the same extent as if it were originally included. The contractor shall be responsible for coordinating these changes as they affect other work in the Contract Documents. Bidders shall acknowledge receipt of this addendum on their bid form.

01 TOTAL FORM PAGES

00 TOTAL SPECIFICATION PAGES ATTACHED

00 TOTAL DRAWING SHEETS ATTACHED AS FOLLOWS: 00 8.5X11 00 11X17 00 30X42 00 OTHER

REVISIONS TO SPECIFICATIONS:

- | | |
|---------------------|--|
| Section No. 10 1423 | 1.1 Revise 3.4 Panel Signage Schedule to list Type J signs location as adjacent to Exit Stair doors and Type K sign location as Commons 007. |
| Section No. 06 6113 | 1.2 Add 2.2A-7. Integral overflow , for Cultured Marble vanity sinks. |
| Section No. 22 3300 | 1.3 In Section 2.2.A, change the word "pneumatic temperature control valve" to read " electric temperature control valve ". |
| Section No. 23 8200 | 1.4 Remove the words "or equal" in section 2.2A, 2.3A and 2.4A. |

REVISIONS TO DRAWINGS:

- | | |
|-----------------------|--|
| Sheet No. D101 | 2.1 Add General note 26. to demolish wood stud and chicken wire partitions in the attic of Bolling Hall. |
| Sheet No. A101 & A102 | 2.2 Add keynote 12 2113 Horizontal Louver Blind to all bedroom windows, typical. Provide blinds at all office, apartment and bathroom windows. |
| Sheet No. E400 | 2.3 Revise Typical Bedroom Plan Note #2 to say two-channel metallic surface raceway |

PRE-BID QUESTIONS:

1. Are blinds required in the common areas and stairway windows?
No, blinds are not required in the public lounges, corridors or stairways.
2. Do the walls at all corridors have to extent to the deck above to meet ½ Hr rated walls.
Yes, the contractor shall extend the rated corridor walls to the deck above to meet the fire rated design.
3. Where are the lighted handrails specified?
Refer to specification section 057300 for Decorative Metal Railings. Railing fabricator shall coordinate light fixture locations and rough in with electrician.
4. How does the precast jamb attach to the saw-cut masonry jamb referenced in detail 5 on sheet A400?
Provide Slotted Stone Strap Anchor with 3/8" Adhesive Anchor at each precast bed joint.

END OF ADDENDUM

1115\5_Docs\E_Addenda\1115 AD 02 062414.docx