



ADDENDUM

ADDENDUM NO. **03**

DATE **06.25.2014**

PROJECT **VMDO Project No.1115, Renovation of Three Residence Halls  
PC# 217-17565-001**

TO ALL BIDDERS: The following constitutes Addendum No. 03 to the Contract Documents dated May 19, 2014, for the Renovation of Three Residence Halls. This addendum shall be attached to the Contract Documents and shall be part thereof to the same extent as if it were originally included. The contractor shall be responsible for coordinating these changes as they affect other work in the Contract Documents. Bidders shall acknowledge receipt of this addendum on their bid form.

01 TOTAL FORM PAGES

00 TOTAL SPECIFICATION PAGES ATTACHED

00 TOTAL DRAWING SHEETS ATTACHED AS FOLLOWS: 00 8.5X11 00 11X17 00 30X42 00 OTHER

#### REVISIONS TO DRAWINGS:

Sheet No. A500

2.1 Add Door note **"8. PATCH AND PREPARE EXISTING FRAMES TO RECEIVE NEW DOOR HARDWARE."**

#### PRE-BID QUESTIONS:

- Please clarify whether ducts in attic and crawlspace require aluminum jackets for exterior ducts per 23 0700 sections 1.6G and 2.1G.

**Although piping and ductwork in attics and crawlspaces is considered "outside", the insulation is not exposed to the elements, so aluminum jacketing is not required.**

END OF ADDENDUM

1115\5\_Docs\E\_Addenda\1115 AD 03 062514.docx