

Post Project Report

Stanley Steemer



Stanley Steemer
120 Bayne Rd
Salem, VA 24153

September 3, 2023
Prepared by:
John Doe
ASCS, CVI, VSMR

3405 Candler's Mountain Rd
Suite F-255
Roanoke, VA 24502

This report fulfills the post cleaning requirement for the project completed by Stanley Steemer of Roanoke.

About Our Indoor Environment Services:

Stanley Steemer is a certified NADCA company. NADCA is a HVAC inspection, maintenance and restoration association. We comply with all NADCA residential and commercial HVAC system cleaning specifications and requirements.

Stanley Steemer is also a certified IICRC company. The IICRC is an organization that regulates and certifies individuals in the inspection, cleaning, and restoration industry. We comply with all IICRC regulations for standard of care.

Scope Of Work:

- Cleaning of all duct work associated with 5 VAV systems
- Cleaning turds up

Cleaning Methodology

- ✓ All work was supervised by NADCA certified ASCS.
- ✓ All systems were cleaned to NADCA standard ACR 2021.
- ✓ Cleanliness Verification Method 1 was performed per NADCA Standard ACR 2021 and system is Verified as Clean.
- ✓ Photographs were taken of before and after the cleaning process.
- ✓ System was cleaned to Project Specifications and went extremely well and according to plan. All efforts were made to minimize impact on facility and occupants. All work was completed by proposed deadline.
- ✓ The cleaning was performed with the system under negative pressure by attaching vacuum collection hoses from our Caddy Vac Truck Mounted Cleaning Equipment to the system.

Issues Discovered During Cleaning

No issues were discovered during the cleaning.
Tar build up.

Project Photo Documentation



HVAC Before



HVAC After



Supply Before



Supply After



Floor Before



Floor After



Floor After



Floor After



HVAC Before



HVAC After



Supply Before



Supply After



Floor Before



Floor After



Floor After



Floor After

ACR 2021 Follow up Inspection Standard of Care

Table 1
HVAC Cleanliness Inspection Schedule
(Recommended Intervals)

Building Use Classification	Air-handling Unit	Supply Duct	Return Duct / Exhaust Duct
Residential	1 year	2 years	2 years
Commercial	1 year	1 year	1 year
Industrial	1 year	1 year	1 year
Healthcare	1 year	1 year	1 year
Marine	1 year	2 years	2 years

We plan to follow up with you to schedule the subsequent cleanliness inspection at your convenience in accordance with NADCA ACR 2021 Table 1

We have verified this project as done. Please call us with any questions, and
Thank You for your business. 336-207-2674

Jason Fender
Stanley Steemer

Stanley Steemer Air Duct Cleaning of Roanoke
Dryer Vent Cleaning and Monitoring

Mold and Duct Encapsulation
Odor Control

