

GOVERNMENT OF TELANGANA
WQM LABORATORY, MB INTRA SUB-DIVISION SIDDIPET
Report on Chemical & Biological analysis of water
Name & Address of sender

1. Sample from: Delhi Secondary school, Near R&B and Huj House, Block Office Road to Ensanpally Road, Vil & Dist: Siddipet. 502103.


2. Collected date: 05.09.2026

3. Received date: 05.09.2026

4. Reported date: 07.09.2026

S.No	TEST	Bore water	BIS 10500-2012 Standards	
			Acceptable	Permissible
		Normal	Normal	-
1	Colour	Un objectionable	Un objectionable	-
2	Odour	0.0	0	5
3	Turbidity (NTU)	7.54	6.5	8.5
4	P ^H	485	500	2000
5	Total Dissolved Solids (TDS)			
	(The following Results expressed in milligrams per litre)			
6	Alkalinity a) Phenolphthalein		200	600
	as CaCO ₃ b) Methyl Orange	244	200	600
7	Total Hardness (as CaCO ₃)	280	300	600
8	Chloride (as Cl)	136	250	1000
9	Fluoride (as F)	0.89	0.5	1.5
10	Nitrate (as NO ₃)	13.7	0	45
11	Iron (as Fe)	0.23	0.3	1.0
12	Sulphate (as SO ₄)	44.56	200	400
13	Residual Chlorine (ppm)	-	0.2	2.0

Remarks:- 1). The above given Bore water Sample Chemically and Biologically Satisfactory. No Bacteriological Contamination found. It is Fit for Drinking purpose.


 Chemist/Microbiologist
 WQM Laboratory
 MB Intra, Sub Division Siddipet

Sd/-
 Dy. Executive Engineer
 MB Intra, Sub Division Siddipet