
EVENT
Transfer starts
BARRIER
Hose inspection at station
failed · Inspection did not reveal damage
EVENT
Hose release
POTENTIAL
Possible ignition
IMMEDIATE CAUSE
Damaged hose remained in use
BASIC CAUSE
Inspection conditions reduced visibility
MANAGEMENT SYSTEM FACTOR
Inspection planning needs review