



A 1st Choice Well Service & Appalachian Well Drilling

**61 Sunrise Ridge Road
Leicester, NC 28748
(828) 776-3781**

**www.a1stchoicewell.com
a1stchoicewell@gmail.com**

Well Inspection

Address: 38 Forest Knoll Drive, Weaverville, North Carolina

Realtor: Cameron Home Inspections

Enclosed is information about your well, surrounding area, water tank, and filtration systems if applicable. It is recommended that all drinking water wells are inspected every 1-3 years to ensure the system is functioning properly.

A drilled well is the most common type of dug well. The well is drilled using a drill bit and a hammer to reach aquifer. Once bedrock is reached, PVC or steel casing is seeded into the rock to prevent surface water from leaking into the aquifer. The well is then drilled further until aquifer is reached. Then, a submersible well pump is installed down in the well to pump water to the residence.

Drilling -

Well type: Drilled well

Well head condition: Good



Well head

Well head location: Left side of the driveway in woods

Well diameter: 6 1/4 inches

Vent tube: Yes

Hose bib: Yes

Well seal: Steel

Wire holes sealed: Yes

Is the well head 12 inches or more above ground? No, 8 inches

Well head covering: Metal plate

Well insulation condition: Good

Well tag: No

Well depth: Estimated 500 feet (estimated due to no well tag)

Static water level: 183.04 feet

Drilled Date: Unknown due to no well tag
Yield: Unknown due to no well tag
Casing condition above ground: Good
Casing type: PVC
Casing depth: Unknown due to no well tag
Type of pipe to house: PVC, 1 inch
Type of pipe to well pump: 1 inch, PVC
Distance from well to house: 120 feet

Well pump system-

Pump tag: No
Pump depth: Estimated 480 feet (estimated due to no pump tag)
Pump horsepower: 1 1/2- 2 horse power
Pump gallons per minute: 10 gallons per minute
Pump Type: Submersible
Date pump installed: Unknown due to no pump tag
Pump breaker: 20 amp
Pump amperage: 10 amps
Disconnect: Yes
Truck access: Yes

The pressure tank is what regulates the well pump to cut off and on when the water is turned on in the house. The pressure tank also helps with pressure in the home.

Pressure tank location: Basement
Type of pressure tank: Well-X-Trol
Pressure tank size: 32 gallon
Condition of pressure tank: Good
Pressure switch: 40/60
Pressure switch condition: Normal wear
Gauge Functioning: Yes

Blowoff valve: Yes

Cut off valve after the pressure tank: Yes

Air in pressure tank when no water pressure on the lines: 37 psi



32 gallon pressure tank

A draw down test describes the recovery rate at the time of the inspection. The draw down test only depicts the top portion of the well. It does not predict future well production, as this can change at anytime.

Draw down test start time: 10:27

Draw down test end time: 10:47

Draw down test start water level: 183.04 feet

Draw down test end water level: 317.04 feet

Draw Down test recovery gallons per minute: **2.45 gpm, considered low producing**

Any leaks detected: No

Filtration: Yes

Type: Sediment filter

Condition: **Cartridge needs to be replaced**

Maintenance: The filter cartridge needs to be changed every 1-3 months, estimated.



Soon down sediment filter

Whole house sediment filter

Type: Spin down Sediment filter

Maintenance: The filter needs to be flushed every 1-3 months, estimated.

Water analysis collected: No

Comments: The filter cartridge needs to be replaced. The well is low producing at 2.45 gallons per minute. We would recommend installing a pump saver to protect the Well pump if the Well runs dry. The estimated cost to make these repairs is \$650 plus tax.

Inspected by: Lee Gibson 6/30/26