DOCUMENT SINTETIC - generat pentru teste, date fictive

DATA CENTRE ENERGY EFFICIENCY REPORT 2025

Facility: Exemplu Data Centre Ilfov. Operator: Exemplu Data Services SRL. Reporting period: January 2025 – December 2025.

Indicator	Value
Total facility energy	12.420 MWh
IT equipment energy	9.000 MWh
Annualised PUE	1,38

Result: the annualised PUE: 1,38 was measured over the full reporting period according to EN 50600-4-2, using sub-metering at the UPS output.