HVAC_System:1 Device Template

For UPnP™ Device Architecture V 1.0

Status: Standardized DCP

Date: May 13th, 2003

This Standardized DCP has been adopted as a Standardized DCP by the Steering Committee of the UPnP Forum, pursuant to Section 2.1(c)(ii) of the UPnP Membership Agreement. UPnP Forum Members have rights and licenses defined by Section 3 of the UPnP Membership Agreement to use and reproduce the Standardized DCP in UPnP Compliant Devices. All such use is subject to all of the provisions of the UPnP Membership Agreement.

THE UPNP FORUM TAKES NO POSITION AS TO WHETHER ANY INTELLECTUAL PROPERTY RIGHTS EXIST IN THE STANDARDIZED DCPS. THE STANDARDIZED DCPS ARE PROVIDED "AS IS" AND "WITH ALL FAULTS". THE UPNP FORUM MAKES NO WARRANTIES, EXPRESS, IMPLIED, STATUTORY, OR OTHERWISE WITH RESPECT TO THE STANDARDIZED DCPS INCLUDING BUT NOT LIMITED TO ALL IMPLIED WARRANTIES OF MERCHANTABILITY, NON-INFRINGEMENT AND FITNESS FOR A PARTICULAR PURPOSE, OF REASONABLE CARE OR WORKMANLIKE EFFORT, OR RESULTS OR OF LACK OF NEGLIGENCE.

© 2001-2003 Contributing Members of the UPnPTM Forum. All Rights Reserved

Authors	Company
Larry Stickler	Honeywell
Andrew Fiddian-Green	Siemens Building Technologies

Contents

1. OVERVIEW AND SCOPE	
1.1. Change Log	
2. DEVICE DEFINITIONS	
2.1. DEVICE TYPE	∠
2.2. DEVICE MODEL	∠
2.2.1. Description of Device Requirements	
2.2.2. Relationships Between Services	
2.3. THEORY OF OPERATION	
3. XML DEVICE DESCRIPTION	3
4. TEST	4
List of Tables	
Table 1: Device Requirements	2

1. Overview and Scope

This device template is compliant with the Universal Plug and Play Architecture, Version 1.0.

HVAC_System:1 provides the following functionality:

- 1 to n ZoneThermostats are part of this device. If ZoneThermostats are added (or removed) a new device description is established and advertised.
- The ability to set or get system level operating and fan modes. This information can be different from similar information found in the ZoneThermostats
- Optionally an outdoor temperature sensor service

Add drawing here

1.1. Change Log

7/27/2000		Changes per 7/17/2000 meeting and conversion to .996 template
8/18/2000		Clean-up
8/30/00	v0.8	Clean-up following 8/27/00 meeting, advance to 0.8, add xml.
2/21/01		Move to 1.1 template, update to latest service versions, updated Theory of Operation and XML
5/1/2001	v0.87	Updated to v0.87
8/6/2001	v0.88	Spelling of "Setpoint" adjusted v0.88
[31 May 2002]	v0.9	Revision marks removed. Test chapter added.
[13 May 2003]	v1.0	Converted to Approved Standard.

2. Device Definitions

2.1. Device Type

The following device type identifies a device that is compliant with this template:

urn:schemas-upnp-org:device:HVAC System:1

2.2. Device Model

Products that expose devices of the type **urn:schemas-upnp-org:device:** <u>HVAC_System:1</u> must implement minimum version numbers of all required embedded devices and services specified in the table below.

Table 1: Device Requirements

DeviceType	Root	Req. or Opt. ¹	ServiceType	Req. or Opt. ¹	Service ID ²
HVAC_System:1	Root	R			
			HVAC_UserOperatingMode:1	R	SystemUserMode
			HVAC_FanOperatingMode:1	О	SystemFanMode
			FanSpeed:1	О	SystemFanSpeed
			TemperatureSensor:1	О	OutsideTemperature
			HVAC_SetpointSchedule:1	О	SystemSetpointSchedule
Non-standard devices embedded by a UPnP vendor go here.	TBD	X	TBD	TBD	TBD
HVAC_ZoneThermostat:1		At least one is required			
			Non-standard services embedded by an UPnP vendor go here.	X	TBD

 $^{^{1}}$ R = Required, O = Optional, X = Non-standard.

2.2.1. Description of Device Requirements

Any number of HVAC_ZoneThermostats may be included in the system device. Each time a ZoneThermostat is added the System device must go bye-bye and then re-advertise its existence via normal UPnP protocols.

HVAC_UserOperatingMode, HVAC_FanOperatingMode, FanSpeed, and HVAC_SetpointSchedule services are used in both the System device and the ZoneThermostat device. Their use is differentiated by use of the Service ID. In the System device these services indicate the system level operating modes.

² Prefixed by urn:<u>upnp-org</u>:<u>serviceId</u>: .

2.2.2. Relationships Between Services

N/a

2.3. Theory of Operation

A HVAC system includes all the heating and cooling equipment necessary to independently condition a whole house or a region of a house. Large homes may include several independent systems. Small homes may only have one system. Individual systems may be zoned.

A forced air system may typically include a furnace with heat exchangers and a fan or a blower, an air conditioning compressor unit, filters, duct work, temperature sensors, temperature setpoints, mode controls and in zoned systems electrically controllable valve or dampers.

Hydronic systems are usually zoned and may typically include a boiler, cooler, pumps, valves, radiators, temperature sensors, temperature setpoints and mode controls.

HVAC_Systemis a container for all the elements of a system. It is not necessarily a recognizable single physical device. All the elements are not necessarily exposed. This DCP is targeted at user control and does not expose operational details.

HVAC system may include independent controls for sub-regions or zones. This is called a Zoned HVAC System.

HVAC_System is the root device and includes system level services and one or more HVAC_ZoneThermostat Devices. The Thermostats provide the zone level controls. Binding of the Thermostats to the System is implied by the hierarchical design of the System device.

3. XML Device Description

```
<?xml version="1.0"?>
<root xmlns="urn:schemas-upnp-org:device-1-0">
  <specVersion>
    <major>1</major>
    <minor>0</minor>
  </specVersion>
  <URLBase>base URL for all relative URLs</urLBase>
  <device>
    <deviceType>urn:schemas-upnp-org:device:HVAC System:1</deviceType>
    <friendlyName>short user-friendly title</friendlyName>
    <manufacturer >manufacturer name</manufacturer>
    <manufacturerURL>URL to manufacturer site</manufacturerURL>
    <modelDescription>long user-friendly title</modelDescription>
    <modelName>model name</modelName>
    <modelNumber>model number</modelNumber>
    <modelURL>URL to model site</modelURL>
    <serialNumber>manufacturer's serial number
    <uDN>uuid: UUID</UDN>
    <UPC>Universal Product Code</UPC>
    <iconList>
      <icon>
        <mimetype>image/format</mimetype>
        <width>horizontal pixels</width>
        <height>vertical pixels/height>
        <depth>color depth</depth>
        <url><url><url><url><url></url></url>
      </icon>
      XML to declare other icons, if any, go here
    </iconList>
    <serviceList>
      <service>
        <serviceType>urn:schemas-upnp-org:service:
HVAC UserOperatingMode:1</serviceType>
        <serviceId>urn:upnp-org:serviceId:SystemUserMode
        <SCPDURL>URL to service description
        <controlURL>URL for control</controlURL>
        <eventSubURL>URL for eventing
      </service>
<service>
        <serviceType>urn:schemas-upnp-org:service:
HVAC FanOperatingMode:1</serviceType>
        <serviceId>urn:upnp-org:serviceId:SystemFanMode</serviceId>
        <SCPDURL>URL to service description</SCPDURL>
        <controlURL>URL for control</controlURL>
        <eventSubURL>URL for eventing
      </service>
<service>
        <serviceType>urn:schemas-upnp-org:service:FanSpeed:1/serviceType>
        <serviceId>urn:upnp-org:serviceId:SystemFanSpeed
        <<u>SCPDURL</u>>URL to service description</<u>SCPDURL</u>>
        <controlURL>URL for control</controlURL>
        <eventSubURL>URL for eventing
      </service>
© 2001-2003 Contributing Members of the UPnP<sup>TM</sup> Forum. All Rights Reserved.
```

```
<serviceType>urn:schemas-upnp-org:service:TemperatureSensor:1
       <serviceId>urn:upnp-org:serviceId:OutdoorTemperature</serviceId>
       <SCPDURL>URL to service description
       <controlURL>URL for control</controlURL>
       <eventSubURL>URL for eventing
     </service>
<service>
       <serviceType>urn:schemas-upnp-org:service:HVAC SetpointSchedule:1
</serviceType>
       <serviceId>urn:upnp-org:serviceId:SystemSetpointSchedule
       <SCPDURL>URL to service description
       <controlURL>URL for control</controlURL>
       <eventSubURL>URL for eventing
     </service>
     Declarations for other services defined by a UPnP Forum working
     committee (if any) go here
     Declarations for other services added by UPnP vendor (if any) go here
   </serviceList>
   <deviceList>
     Implementors shall insert one or more HVAC Thermostats here
Description of embedded devices added by UPnP vendor (if any) go here
   </deviceList>
   cpresentationURL>URL for presentation</presentationURL>
  </device>
</root>
```

4. Test

Testing of the UPnP functions Addressing, Discovery, Description, Control (Syntax) and Eventing are performed by the UPnP Test Tool v1.1 based on the following documents:

- UPnP Device Architecture v1.0
- The Device Definitions in chapter 2 of this document
- The XML Device Description in chapter 3 of this document
- The UPnP Test Tool device template test file: *HVAC System1.xml*
- The template documents for the services referenced by this device, together with their respective UPnP Test Tool service template test files.