



Republic of the Philippines  
Department of Environment and Natural Resources  
**ENVIRONMENTAL MANAGEMENT BUREAU**  
Regional Office No. VIII  
DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City  
Telefax: (053) 832-1088  
Email: [r8support@emb.gov.ph](mailto:r8support@emb.gov.ph) [emb8@yahoo.com](mailto:emb8@yahoo.com)  
Website: [r8.emb.gov.ph](http://r8.emb.gov.ph)



04 January 2022

**ENGR. JAMES PAUL L. YIAN**  
Resident Manager  
Leyte Agri Corporation  
Brgy. Ipil, Ormoc City

ENVIRONMENTAL MANAGEMENT BUREAU  
RELEASED BY: *[Signature]*  
DATE: 01/06/2022  
TIME: 8:26 am

Dear Sir:

This has reference to the compliance status of your air pollution source facilities with the requirements of Republic Act No.8749, otherwise known as the Philippine Clean Air Act of 1999, and its Implementing Rules and Regulations.

Under Memorandum Circular No. 2007-03, with the subject Policy on Compliance and Permitting for Industrial Facilities Relating to Air Quality, which states that source emission testing shall be required for different sources of air pollution to determine compliance with the emission standards. Office records showed that on March 02, 2020, PEASCORP conducted an emission test for your (1) unit 350HP Sterling Type Water Tube Boiler, and one (1) unit 1 MW Laly Brand Standby Genset. However, no emission testing was conducted in 2021 for the said facilities. Please be reminded that the above-cited facilities are considered large sources; hence, emission testing shall be conducted twice per year and once every second year respectively.

Relative thereof, you are hereby directed to subject your APSIs to a third-party emission testing and submit full report within ninety (90) days from the receipt of this notice. Failure to do so shall be deemed a violation of applicable rules and regulations.

For your immediate compliance.

Very truly yours,

*[Signature]*  
**REYNALDO B. BARRA, PME.**  
OIC-Regional Director