



Environmental Management Bureau
Regional Environmental Laboratory Region VIII

Brgy. Baras, Palo, Leyte

Certificate of Analysis

Department: ENVIRONMENTAL MONITORING AND ENFORCEMENT DIVISION-AMBIENT SECTION

Name/Source:	Robinsons Place Marasbaras (Compliance Monitoring)		
Address/Location:	Tacloban City		
Sampled by:	J. Salvador		
Date Arrived:	March 2, 2022 @ 2:11 PM	Date Acknowledged:	March 2, 2022 @ 2:12 PM
Date Analyzed:	March 2, 2022 @ 3:07 PM	Date Reported:	March 4, 2022 @ 4:47 PM

Chain of custody no.	Lab sample no.	Time of Collection	Sample type	Sample Information
2022-072	2208-235	March 2, 2022 @ 1:45 PM	effluent	water sample placed in 350mL plastic bottle labeled "Rob. Exp."
	2208-236	March 2, 2022 @ 1:54 PM	effluent	water sample placed in 350mL plastic bottle labeled "Rob. Main"

Environmental conditions during analysis:

Relative humidity: 47.4%

Temperature: 22.7 °C

CHARACTERISTICS:

Parameters	Lab sample no.	
	235	236
Fecal coliform, MPN/100 mL	2.0	1.6×10^4

Method Used: Fecal coliform - Multiple Tube Fermentation Technique

Reference: 9221E, Standard Methods for the Examination of Water and Wastewater, 23rd ed., 2017, AHA, AWWA, WEF

Remarks

1. This certificate of analysis is based on the sample as received by this office.
2. This certificate of analysis shall not be reproduced in full, without written approval from issuing laboratory.

Analyzed by:

REBEKAH V. SUPERALES

Technical Manager, Microbiology

Reviewed by:

APRILYN R. DAÑAS, RCh

Laboratory Manager

Reg. No. 0011659

Approved by:

MANUEL J. SACEDA JR.

OIC - Chief EMED

Noted by:

REYNALDO B. BARRA

OIC - Regional Director

Laboratory Unit

Email: embr8lab@yahoo.com

cc

Laboratory

Sampler

Records Unit