



Republic of the Philippines
Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU
Regional Office No. VIII
DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City
Telefax: (053) 832-1088
Email: r8support@emb.gov.ph emb8_emb8@yahoo.com
Website: r8.emb.gov.ph



28 March 2022

MS. ALMA V. SOLEDAD
SOM/Managing Head
Dynasty Management & Development Corp.
Gaisano Grand Catarman
Sitio, Macopa, Brgy. Macagtas
Catarman, Northern, Samar

ENVIRONMENTAL MANAGEMENT BUREAU
RELEASED BY: *[Signature]*
DATE: 3/30/2022
TIME: 8:40am

Dear Ma'am:

This refers to your letter received by this Office on 14 March 2022 requesting to allow for at least one (1) emission test for one Genset as a representation of the testing for all installed Gensets in your establishment.

Office records showed that your firm secured a Permit to Operate for Air Pollution Source Installation with reference code POA-2019-E-0848-0163 with validity until June 04, 2024, for the four (4) units 750 KW Stamford Brand Standby Generator Set. Under MC 2007-003, the said facilities require to undergo source emission testing once per year to verify compliance with DENR emission standards as provided under DAO 2000-81.

Relative thereof, please be informed that your request has been **DENIED**. Each facility has its operating conditions and specifications. The emission test result of one facility will not represent the others. Further, the EMB Central Office has no issued guidelines regarding the above-cited matter.

Please be guided accordingly.

Very truly yours,

[Signature]
REYNALDO B. BARRA, PME.
OIC-Regional Director