

Republic of the Philippines Department of Environment and Natural Resources

ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. VIII
DENR 8 Compium, Brgs. 2, Jones Evension, Tacloban City
Tel No. (053) 832-1088 (053) 832-2319
Email Address: cinbr8 records (item), gov.ph



May 23, 2022

MR. AUGUSTO A. BARBA II

Plant Manager Pulp Specialties Philippines Inc. Sitio Magbangon Brgy. Tinag-an Albuera Leyte RELE SIZE WEEN

Subject:

Approval of Source Emission Test (SET) Plan

Sir.

This refers to your letter requesting for the approval of SET plan for the One (1) unit 800 HP "Enertech" Boiler for PM, SOx, NOx & CO and One (1) unit 400 HP "Cyclotherm" Rice Hull Fed Biomass Boiler for PM and CO to be tested by Berksman Systems Inc. (BSI). Please be informed that same is approved with a directive to comply with the facility's requirements and sampling methodology as stated in the test plan and strictly observe the fuel used as indicated in its "Permit to Operate" APSIs. Change of fuel during testing is not allowed; results will be invalid.

Further, your Pollution Control Officer shall observe/check the conduct of the test and ensure that the DENR Accredited Third-Party Sampler strictly follows the following sampling requirements throughout the test:

- Equipment/apparatus available e.g., pumps, flasks, stop-cocks, and impingers are clean, operational, functional, and properly maintained;
- b. Chemicals used are not expired;
- c. Time of sampling must be strictly observed;
- d. No laptop or similar gadgets should be used during the sampling period; and
- The accredited QA/QC and the Team Leader, as the authorized personnel, should be at the facility during the conduct of actual sampling.

This Office will send technical personnel to witness the conduct of the test and observe the conditions of the facilities to be tested scheduled on 6-7 June 2022.

Please be reminded that the SET Report shall be submitted within thirty (30) days from the date of testing to include the operating condition of the source at the time of sampling (e.g., fuel consumed, temp., and mode of operation).

Be guided accordingly.

Very truly yours,

هم: المسكمة REYNALDO B. BARRA, PME OJC-Regional Director



DEPARTMENT OF ENVIRONMENT and NATURAL RESOURCES ENVIRONMENTAL MANAGEMENT BUREAU REGION 8

DENR Compound, Jones St., Brgy. 02, Tacloban City

EVALUATION OF SOURCE SPECIFIC TEST PLAN

Date Received: May 19, 2022 Date Evaluated: May 23, 2022

1. FACILITY INFORMATION

Name of Industry: Pulp Specialties Philippines Inc.

Industry Category: Pulp Milling

Plant Address: Sitio Magbangon Brgy. Tinag-an Albuera Leyte

Contact Person: Mr. Augusto A. Barba II

Position: Plant Manager

Contact Number: (053) 562-9561

Email Address: pur pspi@yahoo.com.ph

Permit to Operate Reference No: POA-2020-B-0837-0053 Issued On: March 05, 2020 Valid Until: Feb. 12, 2025

II. PRODUCTION INFORMATION and REQUIREMENT

The One (1) unit 800 HP "Enertech" Boiler and One (1) unit 400 HP "Cyclotherm" Rice Hull Fed Biomass Boiler should operate at least 90% or at the normal operating capacity during the time of testing.

III. AIR POLLUTION SOURCE INFORMATION

A. APSI: One (1) unit 800 HP "Enertech" Boiler

Rated Capacity: 800 HP

Type of Fuel Used: 50% Diesel & 50% Bunker Fuel Oil

Fuel Consumption: No. of Stack: 1 Stack Diameter: Stack Height:

Ave. Annual Operating Hours:

Year Installed: 2002

B. APSI: One (1) unit 400 HP "Cyclotherm" Rice Hull Fed Biomass Boiler

Rated Capacity: 400 HP Type of Fuel Used: Ricehull

Fuel Consumption: No. of Stack: 1 Stack Diameter: Stack Height:

Ave. Annual Operating Hours:

Year Installed: 2015



DEPARTMENT OF ENVIRONMENT and NATURAL RESOURCES ENVIRONMENTAL MANAGEMENT BUREAU REGION 8

DENR Compound, Jones St., Brgy. 02, Tacloban City

EVALUATION OF SOURCE SPECIFIC TEST PLAN

IV. TEST METHODOLOGY

Particulars	Test Date	Parameters	Test Method	Test Duration		Notes
One (1) unit 800 HP "Enertech" Boiler	June 6, 2022	Volumetric Flow rate (VFR)	USEPA Method 1-4	Three runs exhaust	(3) per	Performed concurrent with PM Test
		Carbon Dioxide (CO2)	USEPA Method 3 by Fyrite	Three runs exhaust	(3) per	Integrated Tedlar Bag sample during M5 Test
		Oxygen (O2)	USEPA Method 3 by Fyrite	Three runs exhaust	(3) per	Integrated Tedlar Bag sample during M5 Test
		Particulate Matter (PM)	USEPA Method 5	Three runs exhaust	(3) per	Performed with Method 5 set-up
		Sulfur Oxides (SOx)	USEPA Method 6	Three runs exhaust	(3) per	Simultaneous with Method 5
		Nitrogen Oxides (NOx)	USEPA Method 7	Three runs exhaust (Three trials/run	(3) per (3)	Three grab sample flasks collected per run
		Carbon Monoxide (CO)	USEPA Method 10 by NDIR	Three runs exhaust	(3) per	Integrated Tedlar bag sample during M5 Test
One (1) unit 400 HP "Cyclotherm" Rice Hull Fed Biomass Boiler	June 7, 2022	Volumetric Flow rate (VFR)	USEPA Method 1-4	Three runs exhaust	(3) per	Performed concurrent with PM Test
		Carbon Dioxide (CO2)	USEPA Method 3 by Fyrite	Three runs exhaust	(3) per	Integrated Tedlar Bag sample during M5 Test
		Oxygen (O2)	USEPA Method 3 by Fyrite	Three runs exhaust	(3) per	Integrated Tedlar Bag sample during M5 Test
		Particulate Matter (PM)	USEPA Method 5	Three runs exhaust	(3) per	Performed with Method 5 set-up
		Carbon Monoxide (CO)	USEPA Method 10 by NDIR	Three runs exhaust	(3) per	Integrated Tedlar bag sample during M5 Test

I. THIRD PARTY INFORMATION

Name of Accredited Third Party: Berksman Systems Inc. (BSI)

Address: 208 VAG Building, Ortigas Ave., Greenhills, San Juan City, Metro Manila

Name of QA/QC: Jose Arjay M. Santiago Name of Team Leader: Ceicel A. Allego

SAT Accreditation No.: 2022-66

Valid until: April 06, 2025



DEPARTMENT OF ENVIRONMENT and NATURAL RESOURCES ENVIRONMENTAL MANAGEMENT BUREAU REGION 8 DENR Compound, Jones St., Brgy. 02, Tacloban City

EVALUATION OF SOURCE SPECIFIC TEST PLAN

Name of Members:

1. Roy D. Pontillas 2. Jeffer P. Menchavez Field Technician Field Technician Field Technician

3. Rodel A. Armillas

II. REMARKS/RECOMMENDATIONS

 Recommended for the approval of test plan with condition of operating the One (1) unit 800 HP "Enertech" Boiler and One (1) unit 400 HP "Cyclotherm" Rice Hull Fed Biomass Boiler should operate at least 90% or at the normal operating capacity during the time of testing.

Emission test report shall be submitted to this office within thirty (30) days after the conduct of the test

Prepared by:

JOSEPH R. AURE/Engr. JANET T. POLEA Source Emission Monitoring Specialist/Engineer IV Recommending Approval:

ENGR. CARLOS A. CAYANONO Chief, WAQMS

Approved by:

P. Bo

FOR, MANUEL J. SACEDA JR. OIC-Chief, EMED

Noted by:

REYNALDO B. BARRA, PME OIC-Regional Director