

	Environmental Management Bureau
	<b>Regional Environmental Laboratory Region VIII</b>
	Brgy. Baras, Palo, Leyte
<b>Certificate of Analysis</b>	

Department: ENVIRONMENTAL MONITORING AND ENFORCEMENT DIVISION-AMBIENT SECTION

Name/Source:	RTR Hospital (Compliance Monitoring)		
Address/Location:	Calanipawan, Tacloban City		
Sampled by:	S. Silleza		
Date Arrived:	Feb 23, 2022 @ 2:48 PM	Date Acknowledged:	Feb 23, 2022 @ 2:49 PM
Date Reported:	Feb 28, 2022 @ 12:49 PM		

Chain of custody no.	Lab sample no.	Time of Collection	Sample type	Sample Information
2022-058	2208-194	Feb 23, 2022 @1:32 PM	Effluent	water sample placed in 1000-mL plastic bottle labeled "RTR Hospital"

Environmental conditions during analysis:

Relative humidity: 56.2%

Temperature: 23.4°C

Page 2 of 2

## CHARACTERISTICS:

Parameters	Date Analyzed	Lab sample no.
		194
BOD, mg/L	23-Feb-22	21.4

Method used: BOD - 5-Day BOD Test

Method detection limit (MDL):

BOD 0.1 mg/L

Reference: Standard Methods for the Examination of Water and Wastewater, 23rd ed., 2017, AHA, AWWA, WEF

Remarks

1. This certificate of analysis is based on the sample as received by this office.
2. This certificate of analysis shall not be reproduced in full, without written approval from issuing laboratory.
3. ND : "not detected", < MDL

Analyzed by:

**ARIEL B. SEVILLEN, RChT**  
Laboratory analyst, Chemistry  
Reg. No. 0003055

Certified by:

**APRILYN E. DAÑAS, RCh**  
Laboratory manager  
Reg. No. 0011659

Approved by:

**MANUEL J. SACEDA JR.**  
OIC - Chief EME

Noted by:

**REYNALDO B. BARRA**  
OIC - Regional Director

Laboratory Unit  
Email: embr8lab@yahoo.com

cc Laboratory  
Sampler  
Records Unit