

## Republic of the Philippines Department of Environment and Natural Resources

ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. VIII

DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City Telefax: (053) 832-2319

Email: r8support@emb.gov.ph emb8\_emb8@yahoo.com

Website: r8.emb.gov.ph



April 4, 2022

## MS. TRACY JOY C. LAUS

Pollution Control Officer Coca-Cola Beverages Philippines Inc. Brgy. 75, Fatima Village Tacloban City

Dear Ms. Laus,

Environmental Greetings!

This is to acknowledge your submission of Source Emission Test Report conducted on February 16-17, 2022, by Ostrea Mineral Laboratories Inc. for the One (1) unit 100 BHP Superior Boiler no. 2 and One (1) unit 1000 KW Caterpillar Diesel Engine Generator Set

Based on the evaluation, the test results comply with the applicable standard of the National Emission Standards for Source Specific Air Pollutants (NESSAP) of the DENR Administrative Order 2000-81 (Implementing Rules and Regulations of the Clean Air Act of 1999) of RA 8749.


It was recommended that the next schedule of Source Emission Testing of the One (1) unit 100 BHP Superior Boiler no. 2 and One (1) unit 1000 KW Caterpillar Diesel Engine Generator Set will be between January-December 2023.

For your information and guidance.

Thank you.

Very truly yours,

ENGR. REYNALDO B. BARRA
OIC. Regional Director



Action	Complete	Incomplete	Not Applicable	Remarks
Review/verify facility information				
Name	/			
Description	1			
Source Identification	<b>/</b>			
Pollutants tested				
✓ PM ✓ SO. ✓ NO. ✓ CO	Did not Pas	s Method 1		
Identification of source tested	1			
Date of test	/			
Report is certified by senior person	/			
Summary description of methods used	-		-	
Any variation to standard methods is explained			· ·	No variations
Summary of test results	~			A. 100 BHP Superior Boiler PM: 8.3 mg/Ncm SOx: 3 mg/Ncm NO <sub>x</sub> : 3 mg/Ncm CO: 99.3 mg/Ncm B. 1,000 KW Caterpillar Genset
				NOx: 213 mg/Ncm CO: 128.5 mg/Ncm
Discussion of test results:				Jan Arena may item
Comparison with standards	1	T		Passed
Any problems encountered during testing		-	1	
Likely cause of problems			1	
Impact of problems on test results			1	
Facility operating conditions:	***************************************			
Operating conditions/process are specified				A. 30% load
<b>5 - - - - - - - - - -</b>	~			B. 28.41%
Variations from conditions proposed in site-specific test plan explained			1	
Means of certifying operating conditions explained			1	
Control room log extracts/other data included	/			1
Sampling and analytical procedures				
Method 1 & 2				
Sampling points	/			
Cyclonic Flow Check	/			
Flue Gas Velocity	1			
Method 3 flue gas composition	1			
Method 4 flue gas moisture content	1			
Method 5/6 particulate matter & sulfur oxides		,		
Sample Collection	/			
Sample recovery	<b>/</b>			
Sample analysis	<b>✓</b>			
Method 7 Nitrogen Oxides			· · · · · · ·	
Sample collection	/			
Sample recovery	· ·	<del></del>	<b> </b>	
Sample analysis	<b>/</b>	1	l	1
Method 10 Carbon Monoxide	_			
Sample Collection	1		<del> </del>	<del> </del>
Sample recovery	/	<b>-</b>		
Sample Analysis		J	<u> </u>	
QA/QC Procedures		7	,	
Particulate & Sulfur	1			
Nitrogen Oxides	1		ļ	
Carbon Monoxide		<u> </u>	<u> </u>	
Raw field data sheets			·	
Method 1	1			A. D <sub>s</sub> : 0.31 m H: 10 m A. Ds: 0.29 m H: 8 m

Method 2	✓		
Method 3			A. %CO <sub>2</sub> : 8.0 ; %O <sub>2</sub> : 13.0
	✓		B. %CO2: 8.5 ; %O2: 12.5
Method 4	✓		
Method 5/6	~		
Method 7	~		
Analytical Laboratory Data			
Gravimetric Particulate Analysis	<b>✓</b>		
SO <sub>x</sub> Analysis Data	1		
SO <sub>x</sub> Audit Sample	<b>✓</b>		
NO <sub>x</sub> Analytical Data	/		
NO <sub>x</sub> Audit Sample Data	<b>/</b>		
Method 7 Spectrophotometer calibration data	1		
CO analysis data	1		
Chain of custody documentation	1		
vidence of equipment calibration			
5 point meter calibration	1		Calibrated 2/5/2022
meter box post test calibration data	-		Calibrated 02/16/2022
pitot tube inspection data	1		Calibrated 11/25/2021
nozzle calibration data			Calibrated 11/25/2021
thermocouple calibration data			Calibrated 03/29/2021
temperature display calibration data			Calibrated 01/28/2022
barometer calibration data			Calibrated 03/29/2021
balance calibration data			Calibrated 12/01/2021
NO <sub>x</sub> flask calibration data	1		Calibrated 08/08/2021
Orsat/Fyrite analysis audit data			Calibrated 12/01/2021
Others:		·	20,007,002
Test Participants Attendance	<b>/</b>		<del></del>
Permit to Operate			POA-2019-G-0837-0203 valid until
Permit to Operate	1		August 14, 2024
	N2		SAT # 2020-83 valid until June 25,
Certificate of Accreditation	<b>/</b>		2023
Spot-check at least two calculations from raw data.			
Spot-check at least two calculations from raw data.  State which and note comparison with report	1		
Calculation:			
			1
	- 20		
	1		
nput at least one run of field data into your calculation spreadsheet			
and verify results			
ond verify results	1		
	1470		
		1 1	

## Recommendations:

1 Emission test reports should be submitted 30 days after the conduct of test.

Evaluated by:

Source Emission Monitoring Specialist

Concurred By:

ENGR. CARLOS A.CAYANONO Chief, WAQMS

Noted by:

Approved by:

5,000

REYNALDO B. BARRA, PME DIC-Regional Drector