



01 March 2022

**JOHN JOVEN CHIONG**

Managing Head  
PASAR Corporation  
LIDE, Brgy. Libertad  
Isabel, Leyte

ENVIRONMENTAL MANAGEMENT BUREAU  
RELEASED BY:   
DATE: 3/03/2022  
TIME: 3:16 pm

Attention: **ENGR. EDMUNDO ESGUERRA**  
Pollution Control Officer

**NOTICE OF PARAMETER EXCEEDANCE/**  
**NOTICE OF TECHNICAL CONFERENCE**

Dear Sir;

This has reference to the result of effluent sampling conducted by our Technical Staff at your Firm last July 6, 2021. Result showed the following effluent concentrations:

Station	Arsenic (mg/L)	Nickel (mg/L)
BP 5	0.126	1.89
BP 6	0.242	1.73
DENR Standards, Class SC waters	0.04	0.3

Please be informed that the above results exceeded the DENR Standards for Class SC waters per Table 9.0, Effluent Standards of DENR Administrative Order No. 08, Series of 2016.

In this regard, you or your authorized representative is invited to a Technical Conference on **07 March 2022, 11 AM** at the EMB Regional Office VIII Conference Room. Your attendance is highly enjoined.

Very truly yours,

**REYNALDO B. BARRA, PME**  
OIC, Regional Director