

## Republic of the Philippines Department of Environment and Natural Resources

#### ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. VIII
DENR 8 Compound, Brgs. 2, Jones Extension, Taclohan City
Tet No. (053) 832-1088 / (053) 832-2319
Email Address. embr8. records/cemb.gov.ph



May 18, 2022

MR. CESAR C. BANAAG

SVP Manufacturing Philippine Phosphate Fertilizer Corporation LIDE, Isabel Leyte RELEASED GY Slas / Slas / Scan

Subject:

Approval of Source Emission Test (SET) Plan

Sir.

This refers to your letter requesting for the approval of SET plan for the One (1) unit of 25 MTPH Coal Fired Utility Steam Boiler (Boiler No.4) for PM, SOx, NOx, CO and Heavy Metals to be tested by Berksman Systems Inc. (BSI). Please be informed that same is approved with a directive to comply with the facility's requirements and sampling methodology as stated in the test plan and strictly observe the fuel used as indicated in its "Permit to Operate" APSIs. Change of fuel during testing is not allowed; results will be invalid.

Further, your Pollution Control Officer shall observe/check the conduct of the test and ensure that the DENR Accredited Third-Party Sampler strictly follows the following sampling requirements throughout the test:

- Equipment/apparatus available e.g., pumps, flasks, stop-cocks, and impingers are clean, operational, functional, and properly maintained;
- b. Chemicals used are not expired:
- c. Time of sampling must be strictly observed;
- d. No laptop or similar gadgets should be used during the sampling period; and
- e. The accredited QA/QC and the Team Leader, as the authorized personnel, should be at the facility during the conduct of actual sampling.

This Office will send technical personnel to witness the conduct of the test and observe the conditions of the facilities to be tested scheduled on 30-31 May 2022.

Please be reminded that the SET Report shall be submitted within thirty (30) days from the date of testing to include the operating condition of the source at the time of sampling (e.g., fuel consumed, temp., and mode of operation).

Be guided accordingly.

Very truly yours,

REYNALDØB. BARRA, PME

OIC-Regional Director



#### DEPARTMENT OF ENVIRONMENT and NATURAL RESOURCES ENVIRONMENTAL MANAGEMENT BUREAU REGION 8

DENR Compound, Jones St., Brgy. 02, Tacloban City

### EVALUATION OF SOURCE SPECIFIC TEST PLAN

Date Received: May 13, 2022 Date Evaluated: May 16, 2022

#### I. FACILITY INFORMATION

Name of Industry: Philippine Phosphate Fertilizer Corporation

Industry Category:

Plant Address: LIDE, Isabel Leyte Contact Person: Mr. Cesar C. Banaag

Position: SVP Manufacturing Contact Number: 0992-592-8763

Email Address:

Permit to Operate Reference No: 18-POA-J-0837-0246

Issued On: October 09, 2018 Valid Until: January 9, 2019

#### II. PRODUCTION INFORMATION and REQUIREMENT

The One (1) unit of 25 MTPH Coal Fired Utility Steam Boiler should operate at least

90% or at the normal operating capacity during the time of testing.

#### III. AIR POLLUTION SOURCE INFORMATION

A. APSI: One (1) unit of 25 MTPH Coal Fired Utility Steam Boiler

Rated Capacity: 25 MTPH
Type of Fuel Used: Coal
Fuel Consumption:
No. of Stack: 1

Stack Diameter: Stack Height:

Ave. Annual Operating Hours:

Year Installed:

#### IV. TEST METHODOLOGY

Particulars	Test Date	Parameters	Test Method	Test Duration		Notes
One (1) unit of 25 MTPH Coal Fired Utility Steam Boiler	May 30-31, 2022	Volumetric Flow rate (VFR)	USEPA Method 1-4	Three runs exhaust	(3) per	Performed concurrent with Method 29 Test
		Carbon Dioxide (CO2)	USEPA Method 3 by Fyrite	Three runs exhaust	(3) per	Integrated Tedlar Bag sample during M29 Test
		Oxygen (O2)	USEPA Method 3 by Fyrite	Three runs exhaust	(3) per	Integrated Tedlar Bag sample during M29 Test
		Particulate Matter (PM)	USEPA Method 5	Three runs exhaust	(3) per	Performed concurrent with Method 29 Test
		Nitrogen Oxides (NO <sub>x</sub> )	USEPA Method 7	Three runs exhaust	(3) per	Three grab samples in flasks collected per run
		Sulfur Dioxide (SO <sub>x</sub> )	USEPA Method 6	Three runs exhaust	(3) per	Simultaneous with Method 6



#### DEPARTMENT OF ENVIRONMENT and NATURAL RESOURCES ENVIRONMENTAL MANAGEMENT BUREAU REGION 8 DENR Compound, Jones St., Brgy. 02, Tacloban City

## EVALUATION OF SOURCE SPECIFIC TEST PLAN

Carbon Monoxide (CO)	USEPA Method 10 by NDIR	Three runs exhaust	(3) per	Integrated Tedlar Bag sample during M29 Test
Heavy Metals	USEPA Method 29	Three runs exhaust	(3) per	Performed with Method 29 set-up

#### V. THIRD PARTY INFORMATION

Name of Accredited Third Party: Berksman Systems Inc. (BSI)

Address: 208 VAG Building, Ortigas Ave., Greenhills, San Juan City, Metro Manila

Name of QA/QC: Jose Arjay M. Santiago Name of Team Leader: Ceicel A. Allego

SAT Accreditation No.: 2022-66

Valid until: April 06, 2025

Name of Members:

1. Roy D. Pontillas 2. Jeffer P. Menchavez Field Technician Field Technician Field Technician

# 3. Rodel A. Armillas

REMARKS/RECOMMENDATIONS

- 1. Recommended for the approval of test plan with condition of operating One (1) unit of 25 MTPH Coal Fired Utility Steam Boiler should operate at least 90% or at the normal operating capacity during the time of testing.
- 2. Emission test report shall be submitted to this office within thirty (30) days after the conduct of the test

Prepared by:

VI.

JOSEPH B AURE/Engr. JANET T. POLEA

Source Emission Monitoring Specialist/Engineer IV

Recommending Approval:

ENGR. CARLOS A. CAYANONG

Chief, WAQMS

Approved by:

Noted by:

OIC-Chief,

B. BARRA, PME DIC-Regional Director