

Republic of the Philippines Department of Environment and Natural Resources ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. VIII

DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City Telefax: (053) 832-1088

Email: r8support@emb.gov.ph emb8 emb8@yahoo.com Website: r8.emb.gov.ph



EMI DUME

March 30, 2022

HON. RENATO CABAEL

Municipal Mayor Municipality of Motiong

Thru: ENGR. DINDO B. CONGE

Municipal Engineer

MOTIONG WATER WORKS SYSTEM (Level III)

Motiong, Samar

Dear Mayor:

Environmental Greetings!

This has reference to the inspection conducted by our technical staff in your establishment on February 9 -10, 2022. The following are the findings and recommendations formulated, to wit:

TIME:

Findings:

- 1. The establishment is in normal operation during the conduct of survey. Their operation is mainly on water distribution only.
- 2. Main source of their water is from spring at Brgy. San Isidro, Paranas, Samar. Potential wastewater generation is from maintenance of their components of waterworks system such as cleaning of the reservoirs.

Recommendations:

1. It is advised that the waterworks system should secure Wastewater Discharge Permit from their maintenance discharge wastewater as per requirement from Section 14, Article 2, Chapter 2 of DAO 2005-10, IRR of RA 9275 also known as the Philippine Clean Water Act of 2004.

As such, you are hereby enjoined to comply with the above-cited recommendations in compliance with the requirements of the Environmental Laws and its Implementing Rules and Regulations of RA 9275 (Philippine Clean Water Act of 2004) within thirty (30) days from the receipt of this letter.

Failure to do so shall be deemed as violation of applicable rules and regulations. This Office will be compelled to take appropriate legal action against your establishment.

Please be guided accordingly.

Very truly yours,