



Republic of the Philippines
Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU
Regional Office No. VIII
DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City
Telefax: (053) 832-2319
Email: r8support@emb.gov.ph emb8@yahoo.com



07 March 2022

MS. ALMA V. SOLEDAD

Managing Head

Dynasty Management & Development Corp.

Gaisano Grand Catarman

Sitio, Macopa, Brgy. Macagtas

Catarman, Northern, Samar

ENVIRONMENTAL MANAGEMENT BUREAU
RELEASED BY: [Signature]
DATE: 3/10/2022
TIME: 9:05am

Dear Ma'am:

Environmental Greetings!


This has reference to your letter duly received by EMB Regional Office 8 on 21 February 2022 requesting an exemption to a Third-Party Source Emission Testing for your Standby Diesel Genset.

Please be informed that the Inter-Agency Task Force for the Management of Emerging Infectious Diseases (IATF-EID) approved the amendments to the guidelines on the nationwide implementation of the Alert Level System for Covid-19 response. The National Capital Region and 38 other areas were under Alert Level 1 from March 1 to 15. Under Alert Level 1, there are no restrictions in terms of indoor and outdoor capacities. Everyone can undertake intrazonal and interzonal travel without age limit and even comorbidities.

In this regard, your request for exemption has been denied. Please visit EMB's official website at www.emb.gov.ph -Air Quality Management for the list of DENR accredited 3rd Party Source Emission Testers. A total of twenty-two (22) firms with forty-four (44) teams to carry out the stack testing for PM, CO, NOx as NO2, and SOx as SO2.

Please be guided accordingly.

Very truly yours,


REYNALDO B. BARRA, PME.
OIC- Regional Director