



Republic of the Philippines
Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. VIII
DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City
Telefax: (053) 832-2319

Email: r8support@emb.gov.ph emb8_emb8@yahoo.com

Website: r8.emb.gov.ph



April 4, 2022

ENGR. JASPER I. CANETE
Chief Engineer/PCO
Robinsons North Tacloban
Brgy. 91 Abucay Tacloban City

ENVIRONMENTAL MANAGEMENT BUREAU
RELEASED BY:
DATE: 4/13/2022
TIME: 8:49am

Dear Sir,

Environmental Greetings!

This is to acknowledge your submission of Source Emission Test Report conducted on November 26, 27 & 29, 2021 by BSI (Formerly Berkman Systems, Inc.) for the Three (3) Unit's 1000 KW "Cummins" Diesel Engine Genset.

Based on the evaluation, the test results comply with the applicable standard of the National Emission Standards for Source Specific Air Pollutants (NESSAP) of the DENR Administrative Order 2000-81 (Implementing Rules and Regulations of the Clean Air Act of 1999). And in compliance for the Permit to Operate with reference number POA-2019-F-0837-0181 condition no. Ten (10) which states, *"The permittee shall conduct, third party emission test for the Three (3) units 1000 KW each "CUMMINS" brand generator set for CO & NOx, once per year as required under DENR EMB MC No. 2007-003, and submit result to EMB R8"*.

It ~~was~~^{is} recommended that the next schedule of Source Emission Testing of the **Three (3) Units 1000 KW Cummins Genset** will be between **January-December 2022**.

For your information and guidance.

Thank you.

Very truly yours,

ENGR. REYNALDO B. BARRA
OIC, Regional Director