



Republic of the Philippines
Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU
Regional Office No. VIII
DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City
Telefax: (053) 832-1088
Email: r8support@emb.gov.ph emb8@yahoo.com
Website: r8.emb.gov.ph




04 January 2022

KENNETH D. SY

Plant Manager

Tacloban Oil Mills, Inc.

Brgy. Opong, Tolosa, Leyte

ENVIRONMENTAL MANAGEMENT BUREAU
RELEASED BY: 
DATE: 01/06/2022
TIME: 8:24am

Dear Sir:


This has reference to the compliance status of your air pollution source facilities with the requirements of Republic Act No.8749, otherwise known as the Philippine Clean Air Act of 1999, and its Implementing Rules and Regulations.

Under Memorandum Circular No. 2007-03, with the subject Policy on Compliance and Permitting for Industrial Facilities Relating to Air Quality, which states that source emission testing shall be required for different sources of air pollution to determine compliance with the emission standards. Office records showed that on October 14, 2019, PEASCORP conducted an emission test for your (1) unit 300HP Kewanee Brand Boiler, and one (1) unit 450KW Cummins Brand Standby Genset. However, no emission testing was conducted in 2020 and 2021 for the said facilities. Please be reminded that the above-cited facilities are considered large and small sources respectively; hence, emission testing shall be conducted twice per year and once every two (2) years.

Relative thereof, you are hereby directed to subject your APSIs to a third-party emission testing and submit full report within ninety (90) days from the receipt of this notice. Failure to do so shall be deemed a violation of applicable rules and regulations.

For your immediate compliance.

Very truly yours,


REYNALDO B. BARRA, PME.
OIC-Regional Director