

Environmental Management Bureau

Regional Environmental Laboratory Region VIII

Brgy. Baras, Palo, Leyte

Certificate of Analysis

Department: ENVIRONMENTAL MONITORING AND ENFORCEMENT DIVISION-AMBIENT SECTION

Name/Source:	RTR Hospital (Compliance Monitoring)			
Address/Location:	Calanipawan, Tacloban City			
Sampled by:	S. Silleza			
Date Arrived:	Feb 14, 2022 @ 8:58 AM	Date Acknowledged:	Feb 14, 2022 @ 8:59 AM	
Date Reported:	Feb 18, 2022 @ 4:38 PM			

Chain of custody no.	Lab sample no.	Time of Collection	Sample type	Sample Information
2022-037	2208-125	Feb 14, 2022 @ 7:50 AM		water sample placed in 1000-mL plastic bottle labeled "RTR Hospital"

Environmental conditions during analysis:

Relative humidity: 54.1% Temperature: 22.3°C

CHARACTERISTICS:

Description	Data Analyzed	Lab sample no. 125	
Parameters	Date Analyzed		
True Color,TCU	14-Feb-22	5	
TSS mg/L	18-Feb-22	ND	
PO43- as P, mg/L	14-Feb-22	0.100	
NO3"as N, mg/L	14-Feb-22	0.31	
pH	14-Feb-22	7.62	
Temperature, °C	14-Feb-22	16.2	

Method used:

True color - Visual comparison method

TSS - Gravimetric Method, dried @ 103-105 ° C Phosphate(PO43") as P - Ascorbic acid method

Nitrate (NO 3") as N - Ion chromatography with Chemical Suppression of Eluent Conductivity

pH - Electrometric method

Temperature - Electrometric method

Method detection limit (MDL):

True color

5 TCU

TSS NO3-, mg/L 2.3 mg/L 0.069 mg/L

Reference:

Standard Methods for the Examination of Water and Wastewater, 23rd ed., 2017,

AHA, AWWA, WEF

Remarks

1. This certificate of analysis is based on the sample as received by this office.

2. This certificate of analysis shall not be reproduced in full, without written approval

from issuing laboratory. 3. ND: "not detected", < MDL

4. DL: detection limit

Analyzed by

ARIEL B. SEVILLENO, RChT

Laboratory analyst, Chemistry Reg. No. 0003055

Analyzed and Certified by:

APRILYNA DANAS, RCh

Laboratory Manager Reg. No. 0011659

SHEREY MAE D. BALAGO, RCh Laboratory/analyst, Chemistry

Reg. No. 0013722

Approved by:

MANUE

Noted by:

REYNALDO B. BARRA

DIC - Regional Director

CC

Laboratory Sampler Records Unit 06-09-21

REL8-REC-01