



Republic of the Philippines
DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
ENVIRONMENTAL MANAGEMENT BUREAU
Regional Office No. VIII
DENR Compound, Brgy. 2, Tacloban City

February 28, 2022

MS. DONNA N. ENERO
Proprietor
Enero's Restaurant
Bobon, Northern Samar

ENVIRONMENTAL MANAGEMENT BUREAU
RELEASED BY: 
DATE: 3/03/2022
TIME: 3:22pm

Dear Ms. Enero,

Environmental Greetings!

This has reference to the inspection and investigation conducted to your establishment regarding the complaint of an anonymous entity on the alleged disposal of wastewater and solid waste generated from your operation to the nearby body of water.

Result of the inspection has established that Enero's Restaurant has no Discharge Permit to cover the disposal of wastewater generated and the wastewater treatment facility needs to be improved to effectively keep its effluent within the standards.

Further, in reference to the above-cited findings, the inspection team have come up with the following recommendations:

- 1. The establishment must secure Discharge Permit for wastewater generated as per requirement under Section 14 of RA 9275 or the Clean Water Act of 2004 and pay the corresponding charges for operating without such permit;*
- 2. The proponent must design and implement an effective water pollution facility such as wastewater strainer and multiple water filter boxes to ensure that the effluent to be discharge on land and on body of water will pass the standard parameter set forth specific for the kind of business activities;*
- 3. That the said water pollution facilities shall be implemented by the proponent within 15 days after the date of inspection as per commitment of the proponent;*
- 4. That the EMB and PENRO shall conduct follow up inspection after the 15 days commitment of the proponent and make report of its compliance.*

In this regard, you are hereby mandated to implement the following recommendations within the specified timeline you have committed with the Inspection Team during the afore-said undertakings.

For your information and immediate compliance.


ENGR. REYNALDO B. BARRA
OIC Regional Director