

Event study: physical time scale of valve response

a

Causal ΔT vs matched control ($^{\circ}\text{C}$)

- Open valve (n=37)
- Close valve, sign-flipped (n=37)
- Physical lag 60–90 s

-0.59 $^{\circ}\text{C}$ @ 120 s

Time after valve step (s)

