FINAL REPORT

ENERGY PLUS & OPEN STUDIO BUILDING ENERGY ANALYSIS


TECHNICAL ENVIRONMENTAL SYSTEMS

POLITECHNICO DI MILANO
PIACENZA

SANSKRITI JINDAL KARAN ANAND SHREY KAUSHIK

1. BUILDING MODEL DESCRIPTION

INFORMATION	VALUE	UNIT
Total Building Area	1978.00	[m2]
Gross Roof Area	1878.00	[m2]
Gross Wall Area	3240.00	[m2]
Window Opening Area	636.00	[m2]
Gross Window-Wall Ratio	19.63	[%]



2. Site to Source Energy Conversion Factors

Туре	Site – Source Conversion Factor
Electricity	3.167
District Cooling	1.056
District Heating	3.613

3. Locations under Consideration

S.No.	City	Country	Geographi	cal Location		CI	imatic Co	ndition	
			Latitude	Longitude	Туре	Tempe (Averaç		Precipitation (Average mm)	Relative Humidity (Average %)
						Max.	Min.		

1.	Piacenza	Italy, Europe	44.92	9.73	Humid Subtropical	17.3	7.0	890	80
2.	New Delhi	India, Asia	28.58	77.20	Humid Subtropical and Semi-Arid	31.2	19.0	790	54
3.	San Francisco	California, Northern America	37.62	-122.4	Warm Summer Mediterranean Climate	17.7	7.8	600.7	74.5

4. Building Model



Fig. 1: Building model View

Fig. 2: Building model Plan




Fig. 3: Thermal Zones

The building is an office space.

It has in total of 8 Thermal Zones as presented.


Many spaces fall under same thermal zone (for maintaining same temperature)


Total building area is divided into three floors as shown with 1878 sq. m. on first and second floor and 989 sq. m. on third floor.


The building model is oriented with its main axis along East West Axis – to have maximum South Sun (being in Northern Hemisphere).

5. Final Analysis Table


		PIACENZA ITALY	NEW DELHI INDIA	SAN FRANCISCO CALIFORNIA, USA
Base model	UNITS			•
Electricity (Interior Lighting + Interior Equipment)	[GJ]	435.05	435.05	435.05
Conversion factor		3.167	3.167	3.167
Total Electricity Value	[GJ]	1377.80	1377.80	1377.80
District Heating	[GJ]	1097.44	89.03	592.16
Conversion factor		3.613	3.613	3.613
Total Heating Value	[GJ]	3965.05	321.67	2139.47
District Cooling	[GJ]	131.69	1061.34	26.00
Conversion Factor		1.056	1.056	1.056
Total Cooling Value	[GJ]	139.06	1120.78	27.46
		5481.92	2820.25	3544.73
TOTAL SOURCE ENERGY		5482.23	2819.90	3544.90










		PIACENZA ITALY	NEW DELHI INDIA	SAN FRANCISCO CALIFORNIA, USA
First Alteration	UNITS			
Electricity (Interior Lighting + Interior Equipment)	[GJ]	435.05	435.05	435.05
Conversion factor		3.167	3.167	3.167
Total Electricity Value	[GJ]	1377.80	1377.80	1377.80
District Heating	[GJ]	980.46	98.82	548.81
Conversion factor		3.613	3.613	3.613
Total Heating Value	[GJ]	3542.40	357.04	1982.85
District Cooling	[GJ]	180.88	1211.89	57.49
Conversion Factor		1.056	1.056	1.056
Total Cooling Value	[GJ]	191.01	1279.76	60.71
		5111.21	3014.60	3421.36
TOTAL SOURCE ENERGY		5111.48	3014.20	3421.52









		PIACENZA ITALY	NEW DELHI INDIA	SAN FRANCISCO CALIFORNIA, USA
Second Alteration	UNITS			
Electricity	[GJ]	435.05	435.05	435.05
(Interior Lighting + Interior Equipment)				
Conversion factor		3.167	3.167	3.167
Total Electricity Value	[GJ]	1377.80	1377.80	1377.80
District Heating	[GJ]	1026.94	102.07	645.98
Conversion factor		3.613	3.613	3.613
Total Heating Value	[GJ]	3710.33	368.78	2333.93
•				
District Cooling	[GJ]	198.42	1354.09	28.84
Conversion Factor		1.056	1.056	1.056
Total Cooling Value	[GJ]	209.53	1429.92	30.46
•				
		5297.67	3176.50	3742.19
TOTAL SOURCE ENERGY		5297.94	3176.06	3742.39








ITALY



Third Alteration	UNITS			
Electricity	[GJ]	435.05	435.05	435.05
(Interior Lighting + Interior Equipment)				
Conversion factor		3.167	3.167	3.167
Total Electricity Value	[GJ]	1377.80	1377.80	1377.80
District Heating	[GJ]	1167.28	96.10	574.11
Conversion factor		3.613	3.613	3.613
Total Heating Value	[GJ]	4217.38	347.21	2074.26
District Cooling	[GJ]	195.63	1197.12	56.98
Conversion Factor		1.056	1.056	1.056
Total Cooling Value	[GJ]	206.59	1264.16	60.17
		5801.77	2989.17	3512.23
TOTAL SOURCE ENERGY		5802.09	2988.79	3512.38









PIACENZA


NEW DELHI

SAN FRANCISCO

		ITALY	INDIA	CALIFORNIA, USA
Fourth Alteration	UNITS			•
Electricity	[GJ]	435.05	435.05	435.05
(Interior Lighting + Interior Equipment)				
Conversion factor		3.167	3.167	3.167
Total Electricity Value	[GJ]	1377.80	1377.80	1377.80
District Heating	[GJ]	985.08	91.10	627.48
Conversion factor		3.613	3.613	3.613
Total Heating Value	[GJ]	3559.09	338.25	2267.09
District Cooling	[GJ]	192.74	1163.67	28.07
Conversion Factor		1.056	1.056	1.056
Total Cooling Value	[GJ]	203.53	1245.89	29.64
		5140.43	2935.78	3674.53
TOTAL SOURCE ENERGY		5140.67	2935.41	3674.74







6. CONCLUSION

NOTE

For same building area and same orientation and similar climatic conditions, building model performs differently, thus leading to different values for **Heating and Cooling**, whereas **Total Electrical Consumption** remains same that involves **Interior Lighting** and **Interior Equipment loads**.

Total Electricity Consumption Value constant for all Simulations = 435.05 [GJ] * 3.167 = 1377.80 [GJ]

- As per the simulation performed on the designed building model taking into consideration different locations in the northern hemisphere and similar climatic conditions, it can be read that least amount of energy is consumed for heating and cooling the building at New Delhi, India.
- After changing wall properties, schedule (hours of operation) and roof properties also, building consumes least amount of energy at New Delhi.
- Thus, the designed building model shall perform best and save maximum amount of energy and cost if designed in New Delhi, than in Piacenza and San Francisco.

BASE MODEL


ENVELOPE


Base Surface		Net Area
Construction	ASHRAE 189.1-2009 ExtRoof IEAD ClimateZone 1	1878.04
	ASHRAE 189.1-2009 ExtWall Mass ClimateZone 1	2603.99
Sub-Surface		
Construction	ASHRAE 189.1-2009 ExtWindow ClimateZone 1	636.01
Wall to Window Ratio		Total (%)
	Gross Window-Wall Ratio	19.63 ` ´


CONSTRUCTION DESCRIPTION


189.1-2009 - CZ1 - Office ASHRAE 189.1-2009


ExtWall Mass ClimateZone 1 1IN STUCCO 8IN CONCRETE HW WALL INSULATION [31] 1/2IN GYPSUM
































FIRST MODULATION

ENVELOPE


Base Surface		Net Area
Construction	ASHRAE 189.1-2009 ExtRoof IEAD ClimateZone 1	1878.04
	MyConstruction- ExtWall Mass ClimateZone4	2603.99
Sub-Surface		
Construction	ASHRAE 189.1-2009 ExtWindow ClimateZone 1	636.01
Wall to Window Ratio		Total (%)
	Gross Window-Wall Ratio	19.63


CONSTRUCTION DESCRIPTION


My Construction Set-1 - CZ1 - Office 1


MyConstruction- ExtWall Mass ClimateZone4


1IN STUCCO 8IN CONCRETE HW 2 WALL INSULATION [44] 1/2IN GYPSUM
































SECOND MODULATION


ENVELOPE


Base Surface		Net Area
Construction	ASHRAE 189.1-2009 ExtRoof IEAD ClimateZone 1	1878.04
	MyConstruction- ExtWall Mass ClimateZone4	2603.99
Sub-Surface		
Construction	ASHRAE 189.1-2009 ExtWindow ClimateZone 1	636.01
Wall to Window Ratio		Total (%)
	Gross Window-Wall Ratio	19.63


CONSTRUCTION DESCRIPTION


My Construction-2 Set-1 - CZ1 - My ExtWall2 Mass Office 2 ClimateZone 4


MAT-CC05 4 HW CONCRETE 8IN Concrete HW Wall Insulation [42] 1/2IN Gypsum


















MONTHLY REPORT









MONTHLY REPORT







THIRD MODULATION

ENVELOPE

Base Surface
Construction

ASHRAE 189.1-2009 ExtRoof IEAD ClimateZone 1
My ExtWall2 Mass ClimateZone 4

Sub-Surface
Construction

ASHRAE 189.1-2009 ExtWindow ClimateZone 1

Wall to Window Ratio

Net Area
1878.04
2603.99

1878.04
2603.99

1878.04
2603.99

Total (%)

Gross Window-Wall Ratio Total (%)
19.63

CONSTRUCTION DESCRIPTION


MAT-CC05 4 HW CONCRETE MyConstruction2Set1-My ExtWall2 Mass CZ1-Office 2 ClimateZone 4 8IN Concrete HW Wall Insulation [42] 1/2IN Gypsum My Schedule Set 1 -My building Large Office Priority1 ClosedOffice - CZ1-3 Bldg Occ 1 Priority2 8 am - 12 pm default 8 am - 6 pm My Schedule-1 - Conference -Large Office Bldg Occ-Priority1 **CZ1-3** conference Priority2 8 am. – 12 pm


Priority2 8 am. – 12 pm default 2 pm – 6 pm


My People Definiton -1 - 1.2 m²/person


ClosedOffice - CZ1-


People Definition2- Office - 0.434800 people / m² **Conference - CZ1-3**
































FOURTH MODULATION

ENVELOPE

	Net Area
My ExtRoof IEAD ClimateZone 2	1878.04
My ExtWall2 Mass ClimateZone 4	2603.99
·	
ASHRAE 189.1-2009 ExtWindow ClimateZone 1	636.01
	Total (%)
Gross Window-Wall Ratio	19.63
	My ExtWall2 Mass ClimateZone 4 ASHRAE 189.1-2009 ExtWindow ClimateZone 1

CONSTRUCTION DESCRIPTION

MyConstruction2Set1- CZ1-Office 2	My ExtWall2 Mass ClimateZone 4	MAT-CC05 4 H 8IN Concrete H Wall Insulation 1/2IN Gypsum	
My Construction-3 Set-1 - CZ1 - Office 3	My ExtWall2 Mass ClimateZone 4 My ExtRoof IEAD	" Roof Membran	0.2
	ClimateZone 2	Roof insulation	~ -
	Climatezone 2	F16 acoustic til	
My Cahadula Cat 4	My building Lorge Office		E I
My Schedule Set 1 - ClosedOffice - CZ1-3	My building Large Office Bldg Occ 1	Priority1	
	-	Priority2	8 am – 12 pm
		default	8 am – 6 pm
My Schedule-1 - Conference - CZ1-3	Large Office Bldg Occ- conference	Priority1	·
		Priority2	8 am. – 12 pm
		default	2 pm – 6 pm
My People Definiton -1 - ClosedOffice - CZ1-	1.2 m ² /person		

0.434800 people / m²

ANNUAL OVERVIEW

Conference - CZ1-3

People Definition2- Office -

