project/ Building_Simulation

professor/ najafi behzad

members/ pletneva tatiana [10687319]
         ahmadi ali   [10703882]
         gaini angela   [10488321]
         vij jagrit   [10654065]

building_information/

Building type: commercial/office
Total Building Area: 3787.96   m2

zones;thermal_zones/

ELEC/MECH ROOM 6

CLOSED OFFICE 8

CONFERENCE ROOM 4

CONFERENCE ROOM 4

CLOSED OFFICE 8

CORRIDOR 5

CORRIDOR 5

RESTROOM 2

STAIRS 3

RESTROOM 2

STORAGE 7

IT ROOM 9

LOBBY 1

ELEC/MECH ROOM 6

north

north

- 189.1-2009 - Office - ClosedOffice - CZ1-3
- 189.1-2009 - Office - Conference - CZ1-3
- 189.1-2009 - Office - Corridor - CZ1-3
- 189.1-2009 - Office - Lobby - CZ1-3
- 189.1-2009 - Office - IT_Room - CZ1-3
- 189.1-2009 - Office - Storage - CZ1-3
- 189.1-2009 - Office - Restroom - CZ1-3
- 189.1-2009 - Office - Stair - CZ1-3
- 189.1-2009 - Office - Elec/MechRoom - CZ1-3

basic_wall/

	[m] thickness	[W/m*K] conductivity	[kg/m3] density	[J/kg*K] specific heat	thermal absorptance	solar absorptance	visible absorptance	[m2*C/W] R-value
1IN Stucco	0.025300	0.691800	1858.0	837	0.900000	0.920000	0.920000	0.036
8IN Concrete HW	0.203300	1.729600	2243.0	837	0.900000	0.650000	0.650000	0.12
Wall insulation [44]	0.110400	0.043200	91.0	837	0.900000	0.500000	0.500000	2.56
1/2IN Gypsum	0.012700	0.160000	784.9	830	0.900000	0.400000	0.400000	0.079

* R_value = thickness/conductivity

* U_value = 1/R_total

R_total: 2.795 [m2*C/W]

U_value: 0.357 [W/m2*C]

	Abu_Dhabi, UAE/		New_Delhi, India/		Oslo, Norway/	
	24.43°N,54.65°E		28.58°N,77.20°E		24.43°N,54.65°E	
average outdoor temperature [annual]	26.8	[°C]	24.6	[°C]	6.6	[°C]
heating consumption [end use]	87597	[kBtu]	238319	[kBtu]	3424084	[kBtu]
	25.6	[MWh]	69.8	[MWh]	1003.4	[MWh]
cooling consumption [end use]	1943044	[kBtu]	1556335	[kBtu]	11175	[kBtu]
	569.4	[MWh]	456.1	[MWh]	3.2	[MWh]
electricity: [end use]						
/interior lighting	414537	[kBtu]	414537	[kBtu]	414537	[kBtu]
	121.4	[MWh]	121.4	[MWh]	121.4	[MWh]
/interior equipment	261598	[kBtu]	261598	[kBtu]	261598	[kBtu]
	76.6	[MWh]	76.6	[MWh]	76.6	[MWh]

Heating consumption is 92.7 % HIGHER
Cooling consumption is 22.1 % LOWER
with respect to the Abu Dhabi case

Heating consumption is 190 % HIGHER
Cooling consumption is 198 % LOWER
with respect to the Abu Dhabi case

	[m] thickness	[W/m*K] conductivity	[kg/m3] density	[J/kg*K] specific heat	thermal absorptance	solar absorptance	visible absorptance	[m2*C/W] R-value
◼ basic_wall [type_1]/								
1IN Stucco	0.025300	0.691800	1858.0	837	0.900000	0.920000	0.920000	0.036
8IN Concrete HW	0.203300	1.729600	2243.0	837	0.900000	0.650000	0.650000	0.12
Wall insulation [44]	0.110400	0.043200	91.0	837	0.900000	0.500000	0.500000	2.56
1/2IN Gypsum	0.012700	0.160000	784.9	830	0.900000	0.400000	0.400000	0.079

R_total: 2.795 [m2*C/W]
U_value: 0.357 [W/m2*C]

◼ type_2/								
1IN Stucco	0.025300	0.691800	1858.0	837	0.900000	0.920000	0.920000	0.036
5IN Concrete HW	0.127000	1.729600	2243.0	837	0.900000	0.650000	0.650000	0.074
Wall insulation [44]	0.110400	0.043200	91.0	837	0.900000	0.500000	0.500000	2.56
F16 Acoustic tile	0.019100	0.060000	368.0	590	0.900000	0.300000	0.300000	0.32
1/2IN Gypsum	0.012700	0.160000	784.9	830	0.900000	0.400000	0.400000	0.079

R_total: 3.069 [m2*C/W]   >>   Total resistance is 9.3 % HIGHER
U_value: 0.325 [W/m2*C]   U_value is 9.3 % LOWER, with respect
                                     to the basic wall [type_1]

◼ type_3/								
G05 25mm wood	0.025400	0.150000	608.0	1630	0.900000	0.500000	0.500000	0.17
12IN Concrete HW	0.203300	1.729600	2243.0	837	0.900000	0.650000	0.650000	0.118
Wall insulation [44]	0.110400	0.043200	91.0	837	0.900000	0.500000	0.500000	2.56
Wall insulation [44]	0.110400	0.043200	91.0	837	0.900000	0.500000	0.500000	2.56
1/2IN Gypsum	0.012700	0.160000	784.9	830	0.900000	0.400000	0.400000	0.079

R_total: 5.487 [m2*C/W]v   >>   Total resistance is 65.0 % HIGHER
U_value: 0.182 [W/m2*C]   U_value is 65.0 % LOWER, with respect
                                     to the basic wall [type_1]

basic_wall [type_1]/

87597	[kBtu]
25.6	[MWh]
1943044	[kBtu]
569.4	[MWh]

heating consumption [end use]

cooling consumption [end use]

type_2/

88261	[kBtu]
25.8	[MWh]
1973452	[kBtu]
578.3	[MWh]

type_3/

90365	[kBtu]
26.4	[MWh]
1907349	[kBtu]
558.9	[MWh]

Heating consumption is 0.7 % HIGHER
Cooling consumption is 0.19 % LOWER
with respect to the basic wall [type_1]

Heating consumption is 3.0 % HIGHER
Cooling consumption is 1.8 % LOWER
with respect to the basic wall [type_1]

1IN Stucco
8IN concrete HW
Wall insulation [44]
1/2IN Gypsum

1IN Stucco
5IN concrete HW
Wall insulation [44]
F16 Acoustic tile
1/2IN Gypsum

G05 25mm Wood
12IN Concrete HW
Wall insulation [44]
Wall insulation [44]
1/2IN Gypsum

■ basic_wall [type_1]/

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total	
cooling [Mbtu]	9.08	21.09	52.0	100.76	220.42	281.73	345.75	361.49	282.15	167.45	80.4	20.74	1943.04	

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total	
heating [Mbtu]	33.87	20.75	11.34	.77	0	0	0	0	0	0	2.63	18.24	87.6	

■ type_2/

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total	
cooling [Mbtu]	9.0	20.94	51.78	100.45	219.91	281.03	344.89	360.58	281.35	166.91	79.99	20.59	1937.45	

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total	
heating [Mbtu]	34.05	20.91	11.44	0.79	0	0	0	0	0	0	2.68	18.39	88.26	

■ type_3/

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total	
cooling [Mbtu]	8.66	20.28	50.87	98.86	216.7	277.18	339.93	355.63	277.1	163.87	78.25	20.03	1907.34	

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total	
heating [Mbtu]	34.56	21.45	11.73	0.86	0	0	0	0	0	0	2.93	18.83	90.16	

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
average outdoor air dry bulb [F]	64.4	67.9	72.0	79.8	87.5	91.1	94.0	94.6	90.6	83.4	75.8	68.2

■ basic_wall [type_1]/

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
cooling Load [MBtu]	9.08	21.09	52.0	100.76	220.42	281.73	345.75	361.49	282.15	167.45	80.4	20.74
heating Load [MBtu]	33.87	20.75	11.34	0.77	0.0	0.0	0.0	0.0	0.0	0.0	2.63	18.24

■ type_2/

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
cooling Load [MBtu]	9.0	20.94	51.78	100.45	219.91	281.03	344.89	360.58	281.35	166.91	79.9	20.59
heating Load [MBtu]	34.05	20.91	11.44	0.79	0.0	0.0	0.0	0.0	0.0	0.0	2.68	18.39

■ type_3/

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
cooling Load [MBtu]	8.66	20.28	50.87	98.86	216.7	277.18	339.93	355.63	277.1	163.87	78.25	20.03
heating Load [MBtu]	34.56	21.45	11.73	0.86	0.0	0.0	0.0	0.0	0.0	0.0	2.93	18.83

This simulation project shows, that differences in enegry consumption of the building depend on the cilmate zone, as well as on the construction materials used.

Concerning the software, OpenStudio allows us to easily calculate various cosumptions & loads of the building at the early design stage. This provides an opportunity to prevent extra costs.