



University of Khartoum

Faculty of Mathematical Sciences and Informatics

AI-Based Smart Load Shedding and Energy Management System for Developing Countries

GRIDGUARD KHARTOUM

GRADUATION PROJECT FINAL REPORT

A graduation project presented to the Faculty of Mathematical Sciences and Informatics, University of Khartoum, in partial fulfilment of the requirements for the degree of Bachelor of Computer Science.

SUBMITTED BY

Murtada Asim Ibrahim Bakhit (18-317)

Suliman Elawad Suliman Babiker (18-310)

Abdalhay Abass Mobarak Abass (15-306)

SUPERVISED BY

Dr. Abubakr Siraj

October 2026

Declaration

We declare that this project, entitled "AI-Based Smart Load Shedding and Energy Management System for Developing Countries", is our original work, carried out under the supervision of Dr. Abubakr Siraj at the Faculty of Mathematical Sciences and Informatics, University of Khartoum. This work has not previously been submitted for another degree or professional qualification, and sources consulted are acknowledged.

Murtada Asim Ibrahim Bakhit (18-317) - Signature: _____

Suliman Elawad Suliman Babiker (18-310) - Signature: _____

Abdalhay Abass Mobarak Abass (15-306) - Signature: _____

Date: _____

Dedication

To our families, whose patience and support made this work possible.

To the people of Sudan, whose resilience in the face of energy hardship inspired this study.

To our supervisor, Dr. Abubakr Siraj, for guidance and encouragement.

Abstract

Electricity shortages create a distribution problem as well as a shortage of generation. Allocating the same supply differently can change interruption durations, protect essential services and distribute unequal burdens between communities. This study develops and evaluates GridGuard Khartoum, an AI-assisted load-shedding and energy-management system combining software simulation, history-only demand prediction, priority rules, constrained optimization, reinforcement learning and an offline application. Khartoum State provides the geographic setting; all demand and supply traces are synthetic.

The simulation represents seven localities, five sectors and 24 hourly decisions under Mild, Moderate and Severe shortages. Hospital, Water and Bakery demand receives explicit priority. The main experiment compares Fixed Rotation, Constrained Optimization and Proximal Policy Optimization (PPO) on identical fresh scenarios. PPO and Constrained Optimization share 128 Critical Only/Full Service assignments and the same supply-feasibility rule. PPO uses 46 features available at decision time and Fairness Rule demonstrations before reinforcement learning. Five independent runs each complete 3,000 iterations, followed by validation selection and evaluation on 960 fresh matched conditions. Critical interruption, service fairness, utilization and direct duration disparities are reported separately from the training score.

Across 960 fresh matched conditions, PPO averaged 0.00 critical-interruption locality-hours, 97.02% service fairness and 97.02% utilization. Fixed Rotation recorded 102.05, 87.76% and 71.23%, respectively; the constrained optimizer recorded 0.00, 94.78% and 97.41%. PPO's daily-reward difference from the optimizer was +0.0499 [+0.0406, +0.0577] (97.5% interval). Utilization falls by 0.40 percentage points and switching increases, so the full declared optimizer-comparison criterion is not met. A post-hoc matched audit finds improved allocation over a critical-aware rotating rule. Against the Fairness Rule teacher, PPO gains 0.0102 daily reward but loses 0.308 utilization percentage points and 16.68 served MWh per day; the pooled gain is concentrated in Severe shortage. Stress tests verify partial critical-service fallback when the supply cannot cover critical demand. A separate fresh 960-condition audit of the same five runs finds that fine-tuning and validation selection add 0.1801 daily reward over imitation alone, while serving 77.20 fewer MWh per day. Higher mean Jain fairness does not ensure higher final service to the worst-served locality.

A separate forecasting experiment compares Ridge AR(3), persistence and a three-hour trailing mean on unseen synthetic targets. Ridge AR(3) has the lowest error on all four measures, but forecasts are not controller inputs. The application presents locality context, matched replay and verified results offline. The contribution is an inspectable decision-support system and outcome-specific evidence, not a real-grid controller or a general proof that learning surpasses optimization.

Keywords: load shedding; energy management; PPO; constrained optimization; critical services; fairness; prediction; Khartoum.

الملخص

تتناول هذه الدراسة توزيع الكهرباء أثناء نقص الإمداد من خلال تطوير نظام «جريد جارد الخرطوم» لدعم القرار. يجمع النظام المحاكاة والتنبؤ بالطلب وقواعد أولوية الخدمات الأساسية والتحسين المقيد والتعلم المعزز، مع تطبيق مكتبي يعمل دون اتصال بالإنترنت. تمثل ولاية الخرطوم الإطار الجغرافي للدراسة، لكن بيانات الطلب والإمداد جميعها اصطناعية وليست قياسات للشبكة الفعلية.

تمثل المحاكاة سبع محليات وخمسة قطاعات وقرارات ساعية لمدة أربع وعشرين ساعة، تحت ثلاثة مستويات للنقص. تقارن الدراسة خوارزمية التحسين القريب للسياسة «PPO» بالتناوب الثابت والتحسين المقيد على الظروف نفسها. يشترك PPO والتحسين المقيد في مئة وثمانية وعشرين تخصيصا ممكنا وقيد لحماية طلب المستشفيات والمياه والمخابز عندما يسمح الإمداد. تستخدم السياسة ستا وأربعين سمة متاحة عند اتخاذ القرار، ويبدأ التدريب بتقليد قاعدة للإنصاف ثم بالتعلم المعزز. أجريت خمس عمليات تدريب مستقلة، لكل منها ثلاثة آلاف تكرار، واختيرت السياسات باستخدام مجموعة تحقق منفصلة قبل اختبار تسعمئة وستين حالة متطابقة.

بلغ متوسط PPO صفرا من ساعات انقطاع الخدمات الأساسية على مستوى المحليات، و97.02% للإنصاف و97.02% لاستغلال الإمداد. حقق النظام المقيد معيار المقارنة المعلن مقابل التناوب الثابت، لكن حماية الخدمات الأساسية تعود إلى القيد الصريح وليست دليلا منفردا على فائدة التعلم. مقارنة بالتحسين المقيد الذي يعظم مكافأة الساعة الحالية، زاد PPO متوسط الإنصاف بمقدار 2.24 نقطة مئوية والمكافأة اليومية بمقدار 0.0499، بفاصل ثقة معدل بنسبة 97.5% من 0.0406 إلى 0.0577. في المقابل انخفض استغلال الإمداد بمقدار 0.40 نقطة مئوية وزاد تبديل مستويات الخدمة، ولذلك لم يتحقق معيار التحسن الكامل المشروط بمؤشرات الخدمة. هذه النتائج لا تثبت تفوق التعلم على التحسين لجميع الأهداف أو على تخطيط أمثل لليوم الكامل.

أضاف تحليل لاحق مقارنات على حالات الاختبار نفسها. تحسن تخصيص PPO مقارنة بقاعدة تناوب تحمي الطلب الأساسي. وأمام قاعدة الإنصاف المستخدمة لتوليد أمثلة التدريب، زادت المكافأة اليومية بمقدار 0.0102، لكن انخفض استغلال الإمداد بمقدار 0.308 نقطة مئوية والطاقة المقدمة بمقدار 16.68 ميغاواط ساعة يوميا. تركزت زيادة المكافأة في النقص الحاد؛ ولا يمثل التحليل اختبارا تأكيديا مستقلا جديدا. وأكدت اختبارات الإجهاد استمرار انقطاعات جزئية للخدمات الأساسية عندما يقل الإمداد عن طلبها.

خفض نموذج الانحدار الذاتي المنتظم «Ridge AR(3)» خطأ التنبؤ بالطلب الاصطناعي مقارنة باستمرار آخر قيمة ومتوسط الساعات الثلاث السابقة. لا تدخل هذه التنبؤات في سياسة التحكم. تتمثل مساهمة المشروع في نظام قابل للفحص ونتائج محددة النطاق توضح المفاضلات، وليس في إثبات الجاهزية التشغيلية لشبكة كهربائية حقيقية.

وفي تدقيق منفصل على تسعمئة وستين حالة جديدة، زادت مرحلة التعلم المعزز واختيار السياسة بالتحقق المكافأة اليومية بمقدار 0.1801 مقارنة بتهيئة التقليد الخاصة بكل تشغيل، لكنها قدمت طاقة أقل بمقدار 77.20 ميغاواط ساعة يوميا. ولا يضمن ارتفاع متوسط مؤشر جاين للإنصاف تحسن الخدمة النهائية للمحلية الأقل حصولا عليها. تقيس هذه المقارنة المرحلة كاملة، ولا تعزل أثر خوارزمية PPO عن الاختيار والحساب الإضافي.

الكلمات المفتاحية: فصل الأحمال؛ إدارة الطاقة؛ التعلم المعزز؛ التحسين المقيد؛ الخدمات الأساسية؛ الإنصاف؛ الخرطوم.

Contents

Declaration 2

Dedication 3

Abstract 4

Arabic abstract 5

List of figures 9

List of tables 10

List of abbreviations 11

1 Introduction 12

1.1 Background and problem . . . 12

1.2 Aim, objectives and research questions . . . 12

1.3 Scope and contribution . . . 13

2 Related work 14

2.1 Traditional scheduling and optimization . . . 14

2.2 Machine learning and demand forecasting . . . 14

2.3 Reinforcement learning for load shedding . . . 15

2.4 Microgrid energy management . . . 15

2.5 Resilience and critical-service priority . . . 16

2.6 Humanitarian consequences of interruption . . . 16

2.7 Developing-country conditions and Sudan . . . 16

2.8 Fairness, equity and evaluation . . . 17

2.9 Position of this study 17

3 Methodology 18

3.1 Simulation units and temporal resolution 18

3.2 Synthetic demand 18

3.3 Available supply and shortage levels 19

3.4 Service tiers and dispatch 19

3.5 Fixed Rotation 20

3.6 Shared critical-service constraints 20

3.7 Constrained Optimization 21

3.8 Decision process, observation and network 21

3.9 Reward and learning objective 22

3.10 Demonstrations and training procedure 24

3.11 Learned demand prediction 25

4 Application implementation 26

4.1 Architecture and execution 26

4.2 The desktop workflow 26

4.3 Offline geography and result handling 28

4.4 Verification approach 28

5 Experimental design and results 29

5.1 Matched control evaluation 29

5.2 Validation selection and longer training 29

5.3 Outcome definitions 30

5.4 Uncertainty and decision criteria 31

5.5 Main controller results 32

5.6 Shortage levels and learning progression 35
5.7 Post-hoc matched baseline and feasibility audit 40
5.8 Learned forecasting results 42
5.9 Locality service and the learning-stage audit 43
5.10 Computation and verification 46

6 Discussion **47**

6.1 What AI and optimization contribute 47
6.2 Critical protection and fair service 47
6.3 Data and physical limitations 48
6.4 Learning and evaluation limitations 49
6.5 Implications for further work 49

7 Conclusion **50**

Appendix A Supporting studies and reproducibility **51**

A.1 Earlier comparisons 51
A.2 Research objectives and evidence 51
A.3 Exact synthetic generator 51
A.4 Evidence and reproducibility 52

Appendix B Source code and review package **54**

References **55**

List of figures

Figure 3.1. Research workflow 18

Figure 4.1. Desktop overview 27

Figure 4.2. Live Scenario inspection 27

Figure 5.1. Main controller outcomes 33

Figure 5.2. Paired PPO effects against Constrained Optimization 34

Figure 5.3. Validation learning trajectories 37

Figure 5.4. TensorBoard training diagnostics 38

Figure 5.5. Between-run validation variance 39

Figure 5.6. Held-out forecasting error 43

Figure 5.7. Locality service at the end of the day 44

List of tables

Table 1. Independent illustrative locality and sector parameter groups. 18

Table 2. Shortage construction. 19

Table 3. PPO training configuration. 24

Table 4. Validation and final-test scenario splits in the original focused study. 29

Table 5. Evaluation outcomes, units and interpretation. 30

Table 6. Final-test controller outcomes on 960 matched conditions; PPO averages five selected runs. 32

Table 7. Final-test interruption durations and disparities, averaged after calculation within each episode. 32

Table 8. Final-test paired effects: PPO - Fixed Rotation; adjusted 97.5% intervals. 33

Table 9. Final-test paired effects: PPO - Constrained Optimization; adjusted 97.5% intervals. 34

Table 10. Final-test outcomes by shortage; 320 matched conditions per level and equal PPO run weights. 36

Table 11. Same-run final-test daily reward: iteration 600 versus the validation-selected actor. 40

Table 12. Final-test effects of selected actors minus same-run iteration-600 actors; descriptive 95% intervals. 40

Table 13. Post-hoc matched baseline audit on the original 960 conditions; PPO is the equal mean of five frozen actors. 41

Table 14. Post-hoc PPO effects against the two added baselines; mean differences and descriptive paired 95% intervals. 41

Table 15. Infeasible-critical-floor stress test; means over 320 demand conditions in each family. 42

Table 16. Forecast error on 320 held-out demand traces; 235,200 locality-sector and 6,720 system targets. 42

Table 17. Fresh matched effects of selected PPO minus its own behavior-cloning initialization; mean differences and descriptive pointwise 95% intervals. 45

Table 18. Six procedures on the 960 fresh matched conditions; BC and PPO weight the five runs equally. 45

Table 19. Training cost and validation-selected checkpoints; reward is from validation, not the final test. 46

Table 20. Data required for future physical and operational validation. 48

Table 21. Parameters of the unnormalized synthetic sector profiles. 52

List of abbreviations

Abbreviation	Meaning
AI	Artificial intelligence
API	Application programming interface
BC	Behavior cloning
CI	Confidence interval
CPU	Central processing unit
CUDA	Compute Unified Device Architecture
GAE	Generalized advantage estimation
GPU	Graphics processing unit
GUI	Graphical user interface
KL	Kullback-Leibler divergence
MAE	Mean absolute error
MDP	Markov decision process
MW / MWh	Megawatt / megawatt-hour
PPO	Proximal Policy Optimization
pp	Percentage points
ReLU	Rectified linear unit
RL	Reinforcement learning
RMSE	Root mean square error
SD	Sample standard deviation
SHA-256	Secure Hash Algorithm, 256-bit digest

1 Introduction

1.1 Background and problem

When demand exceeds available electricity, some consumption must be reduced or interrupted. A schedule cannot remove the physical deficit, but it can change its consequences. Different allocations may preserve essential facilities, avoid prolonged interruptions or use supply that a rigid schedule leaves unrequested. These are distinct objectives: serving more energy does not automatically distribute it fairly, and equal blackout durations do not necessarily mean adequate service.

Sudan provides the setting for this software study of electricity allocation under shortage. Hospitals, water facilities and bakeries motivate explicit priorities. Residential and commercial demand also matter because critical protection does not settle how remaining supply should be shared. The World Bank (2025) describes electricity-sector disruption and the importance of energy access for essential facilities in Sudan. It provides context, not the hourly measurements used in this experiment.

The project asks how prediction, rules, optimization and learning can support shortage allocation. These methods answer related but different questions. Forecasting estimates later demand from observed history. Priority rules specify protected services. Optimization finds the best admissible assignment for a defined objective and horizon. Reinforcement learning seeks a policy whose sequence of decisions produces a favorable accumulated outcome. An informative comparison must identify what each method knows, can choose and is asked to improve.

GridGuard represents chronic hourly shortage rather than a sub-second voltage or frequency emergency. Actions affect later cumulative service ratios and switching history, creating a sequential allocation problem without storage. Unused electricity cannot be carried forward. Any advantage of learning must therefore appear in measured service and scheduling outcomes; it cannot be assumed from the use of a neural network.

1.2 Aim, objectives and research questions

The aim is to develop and evaluate an offline decision-support system for electricity allocation under shortage. Seven objectives form one workflow: study shortage with Sudan as the motivating context; model supply, demand and sectors; develop AI-assisted decision support; protect critical services; test prediction, rules, optimization and reinforcement learning where appropriate; compare with a traditional fixed schedule; and evaluate downtime, fairness and distribution efficiency.

The study addresses five research questions:

1. How can synthetic scenarios represent supply, locality demand and service priorities transparently?
2. Does a learned history-only forecast improve next-hour prediction over simple baselines?
3. How do PPO and Constrained Optimization change critical interruption, service fairness, utilization and blackout-duration inequality relative to Fixed Rotation?
4. Under matching critical constraints, does PPO improve declared outcomes over the optimizer, and what tradeoffs remain?
5. How can an offline interface explain the decisions and evidence clearly?

These questions evaluate AI without requiring a predetermined advantage over other methods. A result favoring a transparent optimizer is useful. An improvement on one outcome is also useful when its scope

and costs are explicit. Direct duration measures assess blackout inequality alongside Jain service fairness; the two are not treated as interchangeable.

1.3 Scope and contribution

The model covers seven localities, five sectors, three shortage levels and a 24-hour horizon. Demand profiles and shortage parameters are illustrative assumptions. A shared supply pool replaces network power flow. There are no feeders, losses, voltage or frequency dynamics, storage or restoration transients. Administrative boundaries provide geographic orientation, not electrical service territories.

The contribution is an inspectable comparison framework connecting repeatable simulation, learned prediction, explicit critical constraints, exact current-hour optimization, trained PPO and separate service measures. It identifies when a learned objective improves and when the service costs prevent the declared claim from passing. This is an implemented case study, not a new PPO algorithm. The reduction in critical interruption against an unprotected schedule is not presented as the central learning contribution. Matched inputs support procedure comparisons, while independent runs expose training variability and the follow-up audit tests stronger transparent alternatives.

The Fixed Rotation comparison evaluates the complete system. It cannot assign every improvement to learning because Fixed Rotation lacks Critical Only actions and a critical-feasibility mask. PPO and Constrained Optimization, by contrast, share the same feasible assignments and information available at decision time. That comparison is stronger for assessing learned scheduling, while still not establishing superiority over a full-day optimum or every optimization method. Section 5.7 (p. 40) adds a post-hoc matched comparison with the Fairness Rule teacher and a critical-aware rotating baseline; it does not reclassify that follow-up as part of the original confirmatory design.

2 Related work

2.1 Traditional scheduling and optimization

The chapter has nine connected subsections: eight literature themes followed by a synthesis positioning this study. It begins with conventional load shedding and optimization. Emergency protection and recurring rationing solve different problems. Larik et al. (2019) review under-voltage shedding, distinguishing static and dynamic, open-loop and closed-loop approaches. This informs the need to specify the control task, but transient performance measures cannot be transferred directly to a daily simulator without voltage dynamics.

Heggie et al. (2018) study rationing during long-term shortage, emphasizing repeated allocation and its efficiency consequences. This is closer to GridGuard's setting. Fixed rotation is inspectable and easy to explain, but a predetermined service block can ignore changing demand and the accumulated burden of earlier interruptions. It is a useful baseline, not the strongest possible conventional policy.

Optimization supplies a necessary stronger comparison. Sarwar et al. (2020) formulate priority-aware load shedding through mixed-integer programming for islanded distribution systems. Poudel and Dubey (2019) connect critical-load restoration to distributed resources and network restrictions. Together these studies show that explicit priorities and adaptive decisions are compatible with mathematical optimization; learning is not the only mechanism available.

The literature does not justify declaring all optimization too slow. Cost depends on the formulation, horizon, scale and implementation. GridGuard has seven locality decisions, so exhaustively scoring 128 constrained assignments is practical. This optimizer is exact for its current-hour objective. The research question is whether a learned sequence improves full-day outcomes, not whether PPO exceeds the exact maximum of the identical one-step problem.

2.2 Machine learning and demand forecasting

Ramchurn et al. (2012) frame the smart grid as a broad challenge for AI, connecting coordination and uncertainty across distributed decisions. Glavic (2019) distinguishes power-system operating tasks and illustrates why a learning method's relevance depends on the state, objective and restrictions. A method useful for a market, building or emergency-control task is not automatically useful for fair shortage allocation.

Forecasting is a separate AI contribution. Nti et al. (2020) review electricity-load forecasting methods and evaluation. Bedi and Toshniwal (2018) investigate empirical-mode decomposition with deep learning. Convolutional, recurrent and ensemble approaches offer further alternatives for exploiting temporal structure, but complexity alone does not establish superiority for a particular dataset.

GridGuard uses compact ridge autoregression with three hourly lags for every locality-sector pair. Its inputs, coefficients and training-only normalization can be inspected directly. Persistence and a trailing mean provide transparent comparisons. Every method must predict the same target hours; otherwise differences in warm-up or forecast horizon could be mistaken for a model improvement.

The forecasting experiment answers a prediction question. PPO receives current observations and accumulated history, not a forecast or future trace. Improved forecast accuracy therefore cannot explain a measured controller gain. Integrating predictions into planning would require another matched experiment, including forecast errors and comparable information for competing controllers.

2.3 Reinforcement learning for load shedding

Reinforcement learning connects observations, actions and state transitions through an accumulated reward. Huang et al. (2020) investigate learned emergency control, including under-voltage shedding. Wang et al. (2021) use dueling deep Q-learning for emergency shedding in microgrids. Chen et al. (2023) apply PPO to frequency restoration in a modified IEEE 39-bus system. These are relevant precedents for learned decisions, while their physical tasks differ from hourly rationing.

GridGuard contains no voltage trajectory, frequency deviation or electrical graph. It therefore cannot reproduce transient-stability or response-time claims from those studies. Its sequential effects arise through cumulative service ratios and switching history. The policy must be assessed against those mechanisms rather than the broader promise of emergency-control research.

Schulman et al. (2017) introduce PPO's clipped policy objective and minibatch updates. The actor assigns probabilities to discrete allocation choices, while the critic estimates expected return from the current state. Performance depends on observations, reward, initialization and training; the algorithm's name provides no guarantee that it will beat a transparent rule.

García and Fernández (2015) distinguish changing the learning objective from restricting exploration. A finite reward penalty does not make an unsafe action impossible. GridGuard therefore imposes critical protection through an action mask, separately from reward weights. Huang and Ontañón (2022) support using the same valid-action distribution during sampling and policy updates. This consistency is essential when PPO recomputes probabilities for stored actions.

Fairness Rule demonstrations initialize the actor before PPO training. That prior knowledge changes the interpretation: the system is imitation followed by reinforcement learning, not learning from scratch. A favorable comparison against Fixed Rotation does not isolate the benefit of PPO fine-tuning. Section 5.7 (p. 40) compares the current frozen policies with this teacher on matched conditions; Appendix A retains the earlier, separate teacher comparison, including its negative result.

Section 5.9 (p. 43) additionally compares each selected policy with its own imitation-only initialization on new matched conditions, separating the measured learning-stage change from the broader comparison with its teacher.

2.4 Microgrid energy management

Microgrid studies provide related examples of sequential energy decisions. Ji et al. (2019) investigate daily microgrid operation through deep reinforcement learning, while Vázquez-Canteli and Nagy (2019) review demand-response algorithms and modeling choices. Storage, flexible consumption and prices can create substantial opportunities to trade present service against future benefits.

GridGuard adopts sequential allocation with a simpler physical model. It has no battery, price signal, energy trading or controllable generation. Time coupling comes from service history and tier changes. Learning's potential planning advantage is therefore narrower than in a system that can store electricity for later demand. An observed result must be explained by the mechanisms actually present.

This literature also raises the transfer problem. A policy that succeeds in simulation may fail under different demand patterns or equipment restrictions. Synthetic experimentation is useful for controlled comparison, but repetition does not validate the environment. The simulator's assumptions remain part of every conclusion.

2.5 Resilience and critical-service priority

Resilience research concerns maintaining and restoring important functions during disruption. Rosales-Asensio et al. (2022) investigate metrics that weight critical electricity customers according to the system and operator context. Poudel and Dubey (2019) connect restoration priority to feasible resources and network constraints. These studies support explicit priorities while requiring the protected quantity and its delivery mechanism to be defined.

Afzal et al. (2020) distinguish established reliability concepts from resilience under major disruptions and review assessment frameworks. Their network-restoration setting supports the need to define the scope of protection; this single-day allocation simulator does not model damage recovery or measure whole-grid resilience.

GridGuard designates Hospital, Water and Bakery as critical to represent essential health, water and food services. Critical Only supplies their entire modeled sector demand. This is not a measurement of any particular facility's minimum operating load. A real hospital may contain essential and deferrable consumption, and real feeders may connect several sectors that cannot be independently switched.

Protection is also conditional on supply. If total critical demand fits, the mask permits only assignments that request all of it within capacity. If it does not fit, the all-Critical-Only fallback still experiences shortage. The evaluation records that infeasibility rather than reporting unconditional critical protection.

2.6 Humanitarian consequences of interruption

Irwin et al. (2020) review relationships between electricity access, reliability and health in low- and middle-income countries. They report relevant associations while rating the overall evidence quality as weak. Nduhuura et al. (2021) study household outage impacts in Accra and their association with household circumstances. These sources motivate attention to essential services and uneven burdens without establishing quantitative health benefits for this controller.

The project measures supplied critical energy, critical interruption duration, zero-service blackouts and locality allocation. It does not estimate mortality, clinical risk, food security or economic loss. The same interrupted hour may have different consequences for different facilities and people. Operational priorities would require richer data and stakeholder participation.

Locality averages also conceal internal differences. The model has no household income, vulnerability or backup-generator access. Better locality-level fairness therefore describes the represented allocation, not equality of every consequence experienced by residents.

2.7 Developing-country conditions and Sudan

Studies of Sudan connect chronic shortage to infrastructure, finance and unequal access. Al-Rikabi et al. (2025) discuss Sudan's renewable-energy situation, and Basheir and Abdelrahman (2022) analyze the electricity crisis and energy-transition choices. The World Bank (2025) provides additional context for essential-service access. These are contextual sources rather than measurements of the modeled localities.

National statistics in those documents are tied to their dates and source definitions. They do not calibrate the experiment's 700 MW nominal demand scale, sector shares or locality weights. The Moderate and Severe shortage windows are controlled scenarios, not reproductions of a documented Khartoum day.

Fresh synthetic traces permit repeatable comparison while remaining insufficient for operational calibration.

Familiar locality names and administrative geometry make the geographic setting understandable. They do not establish electricity-network topology. This separation supports an honest Sudan-inspired study without turning geographic context into an unsupported claim of physical fidelity.

2.8 Fairness, equity and evaluation

Jenkins et al. (2016) distinguish distributional, recognition and procedural dimensions of energy justice. This explains why total delivered energy is incomplete: who receives service, whose needs count and how decisions are governed all matter. GridGuard measures a narrow distributional component and names critical services explicitly. It does not implement participatory governance or claim to resolve energy justice.

Oluwasuji et al. (2020) provide a close comparison for fair allocation under recurring shortage. They formulate household connections as mixed-integer programs with utilitarian, egalitarian and envy-freeness objectives and constraints, using consumption and comfort to represent heterogeneous needs. Their day-ahead schedules cover 24 hours, and their developing-country demand data are adapted from measured US household consumption. GridGuard instead makes hourly locality decisions from current observations and accumulated history, using illustrative sector profiles. It measures Jain fairness (Jain et al., 1984) of cumulative demand-normalized service and direct duration disparities. These quantities do not reproduce household utility or envy-freeness; a fairness reward term is not a hard equality guarantee.

Heggie et al. (2018) examine the efficiency cost of regional proportional-allocation targets in a Nigerian power-system model with transmission constraints and varying generation. They compare fairness over shorter and longer allocation periods. This is a useful precedent for interpreting fairness alongside delivered energy. GridGuard omits that electrical network and measures equality of locality service ratios rather than deviation from prescribed regional shares. Its tradeoff between fairness and utilization addresses a related question in a simpler model; the numerical results are not directly comparable.

Agarwal et al. (2021) explain how uncertainty and limited training runs affect reinforcement-learning conclusions. This motivates reporting all five independently trained policies rather than selecting the best final-test actor. Bootstrap reasoning (Efron and Tibshirani, 1993) supports retaining controller pairing and the dependence between shortage variants of the same underlying scenario.

2.9 Position of this study

The preceding eight themes establish that priority-aware optimization and fair rationing already have substantial precedents. This study asks a narrower question: under the same current information and critical-service constraints, what does imitation followed by PPO add to transparent allocation methods, and what service costs accompany any gain? The contribution is the implemented comparison and its evidence within a Sudan-inspired simulation, not a new fairness definition or a claim to have introduced fair load shedding.

The design follows from that question. Constrained Optimization and Fairness Rule provide stronger references than an unprotected fixed schedule. Critical service is enforced through admissible actions; fairness, duration and energy remain separate outcomes. History-only forecasting is evaluated independently because its predictions do not enter the controllers. The offline application makes the assumptions and comparisons inspectable.

3 Methodology

3.1 Simulation units and temporal resolution

The model uses the locality order Khartoum, Omdurman, Bahri, East Nile, Jebel Awlia, Karari and Ombada. Each locality contains Hospital, Water, Bakery, Residential and Commercial demand. The first three sectors are critical. These categories represent essential services while keeping the action space small enough to inspect.

An episode contains 24 steps, each representing one hour. Demand and supply are measured in MW at each step. Multiplying by the one-hour step duration gives energy in MWh; daily energy is the sum over the 24 steps. The model uses one shared supply pool and imposes no network distance or transfer-capacity cost between localities. Administrative geometry has no role in the calculations.

Figure 3.1 (p. 18) connects the common controller inputs, shared dispatch and outcome calculations. The forecasting branch is evaluated separately and supplies no future information to PPO.




Figure 3.1. Research workflow. Common synthetic inputs support matched control evaluation. Demand prediction is evaluated separately; forecasts are not fed into the controllers.

3.2 Synthetic demand

The nominal demand scale is 700 MW. It is divided among localities using the weights in Table 1 (p. 18). This is a normalization parameter, not a measured Khartoum demand or the simultaneous system peak: the sector profiles reach their maxima at different hours. Without random perturbations, the resulting system demand reaches approximately 579.99 MW at hour 19. Within each locality, sector coefficients scale these normalized hourly profiles. Appendix A.3 specifies the generator exactly.

Table 1. Independent illustrative locality and sector parameter groups.

Parameter group	Values
Locality demand weights	Khartoum 1.00; Omdurman 0.95; Bahri 0.85; East Nile 0.80; Jebel Awlia 0.70; Karari 0.75; Ombada 0.90
Sector base-peak coefficients	Hospital 0.08; Water 0.07; Bakery 0.05; Residential 0.55; Commercial 0.25

Every locality contains all five sectors. The two parameter groups are independent; their entries do not pair a locality with a particular sector.

Hospital demand is approximately constant. Water demand has morning and evening peaks, Bakery demand has early-morning and afternoon peaks, Residential demand has morning and stronger evening peaks, and Commercial demand peaks around midday. The generator uses deterministic normalized profiles, with independent uniform demand perturbations between -5% and $+5\%$. The sector coefficients are base peak shares; because profiles differ, instantaneous sector proportions vary over the day.

This construction gives every experiment an inspectable source of variation. It allows the same episode to be reproduced from its seed, and permits changes in shortage severity without changing the underlying random demand draw. It does not reproduce a measured Khartoum load curve. The parameters should therefore be read as research assumptions whose consequences can be examined, not estimates of actual energy requirements.

3.3 Available supply and shortage levels

Supply is derived from current total demand, a shortage fraction and a separate uniform perturbation between -5% and $+5\%$. The generator caps supply at 95% of demand to retain a shortage-only operating domain. The three shortage levels are defined in Table 2 (p. 19).

Table 2. Shortage construction.

Shortage level	Base supply fraction	Additional reduction
Mild	0.80	None
Moderate	0.65	Subtract 0.10 during hours 17-20
Severe	0.50	Subtract 0.15 during hours 16-21

A severity-neutral draw supplies the demand and supply disturbances for all three versions of an episode. The resulting Mild, Moderate and Severe scenarios are coupled: they share the same base randomness while applying different shortage transformations. This makes a severity comparison easier to interpret, but also means that the three versions are not statistically independent observations.

The default generator provides enough power to cover the modeled critical sectors under the defined perturbation limits. This property is important to the meaning of the critical-service constraint. When the constraint is satisfied, zero critical interruption is feasible by construction. Other supply conditions could make that requirement impossible; the controller has an explicit fallback for that case rather than an unconditional guarantee.

3.4 Service tiers and dispatch

The simulator recognizes three locality service tiers. Off requests no power. Critical Only requests Hospital, Water and Bakery demand. Full Service requests all five sectors. Let requested sector demand be q, available system supply be S, and total requested power be Q. The delivered load is calculated using one global factor:

$$\alpha = \min\left(1, \frac{S}{\max(Q, \varepsilon)}\right)$$

$$\text{delivered} = \alpha\,\text{requested}$$

Here ε is a small numerical safeguard. If requests fit within supply, they are delivered without scaling. If they exceed supply, every requested sector is reduced by the same proportion. All controllers use this exact dispatch calculation. In particular, dispatch does not silently restore critical demand after an excessive request. Critical protection is achieved by the constrained controllers' admissible choices before dispatch.

At each step the simulator records the requested and delivered sector loads, locality tiers and reward. Cumulative demand and cumulative served energy are updated for the next decision. The external demand and supply traces do not depend on the chosen actions. The action's consequences for subsequent decisions are the changed service history and previous tier.

3.5 Fixed Rotation

Fixed Rotation assigns Full Service to three consecutive localities for a three-hour block and switches the remaining four localities Off. The starting locality advances by three positions for each new block, wrapping around the seven-locality order. Given the hour, the schedule is deterministic. It does not inspect current demand, available supply, critical demand or cumulative service.

This rule provides a fixed-schedule baseline for evaluating adaptive allocation. Its transparency makes it possible to explain why a locality is selected at a given hour. However, it does not select Critical Only, and its Full Service requests can underuse or exceed current supply. The result is a baseline for this specified traditional scheduling strategy, not for the best achievable non-learning controller.

Because supply decreases under greater shortage, the rule's utilization ratio can rise even though the schedule itself is unchanged. A smaller denominator does not indicate adaptation. This is why utilization is interpreted alongside served energy and direct interruption outcomes.

3.6 Shared critical-service constraints

PPO and Constrained Optimization reserve critical demand in every locality whenever physically feasible. Their action space contains only Critical Only and Full Service. Seven binary choices produce $2^7 = 128$ joint assignments. Let C be total critical demand, b_i be the noncritical demand of locality i, and x_i indicate whether that locality receives Full Service. A candidate is admissible when:

$$x_i \in \{0, 1\}$$

$$C + \sum_{i=1}^{7} x_i b_i \leq S$$

The implementation evaluates this condition using the same requested-load reduction as the dispatcher, preserving the floating-point boundary. It does not add a hidden supply tolerance that could admit a request above availability. Infeasible candidates receive zero probability in the policy's categorical distribution.

If no candidate satisfies the condition, only the all-Critical-Only fallback is allowed. Dispatch then shares the insufficient supply proportionally, and the episode records the resulting critical interruption. The fallback is a declared response to infeasibility; it is not counted as successful satisfaction of the constraint.

The same feasibility mask is used for demonstrations, policy sampling, probability recomputation during PPO updates, validation and final inference. The mask therefore changes what the policy is trained to choose, rather than merely replacing an unwanted action after it has been selected. Within the feasible set, the network determines which localities receive the remaining noncritical supply.

3.7 Constrained Optimization

Constrained Optimization enumerates all 128 assignments defined above, filters by the same feasibility condition, applies shared dispatch and scores the canonical current-hour reward. It receives current demand, supply, cumulative demand and served energy, and previous tiers. Exact score ties select the lowest candidate index. It receives no future demand or supply. The computation remains on CUDA and evaluates every candidate rather than sampling a subset.

This method solves its immediate decision exactly. It does not solve the complete 24-hour schedule. Each choice changes the cumulative service and switching history seen at the next step, so maximizing immediate reward need not maximize daily reward or every public metric. PPO can demonstrate a benefit only through measured episode outcomes; it cannot exceed the exact one-step maximum for an identical state, objective and action set.

The historical Optimization controller searched all 2,187 assignments of Off, Critical Only and Full Service under proportional dispatch. Its earlier results are retained separately. The main comparator here uses the same 128 protected assignments as PPO, making the attribution clearer. Neither formulation is a proven full-horizon optimum.

3.8 Decision process, observation and network

The environment is a finite-horizon decision process with $T = 24$ and step duration $\Delta t = 1\,\mathrm{h}$. Write $d_{i,k,t}$ for sector demand in MW, S_t for available MW, $D^-_{i,t}$ and $E^-_{i,t}$ for locality cumulative demanded and served MWh before hour t, and $a_{i,t-1}$ for the previous tier. The full simulator state can be written as follows:

$$X_t = (t, d_t, S_t, D^-_t, E^-_t, a_{t-1}, \xi_t).$$

Here ξ_t denotes the exogenous scenario-generator state, including the fixed shortage regime and the random process that supplies later demand and availability. Including that state makes the simulator's transition well defined; it does not give the policy access to future samples. The controller uses the observed projection described below. This is a finite-horizon MDP formulation of the environment, not a proof that every compressed observation is a sufficient Markov state for every future real-world process.

For PPO and Constrained Optimization, $a_t \in \mathcal{A}_t$ is one of the 128 binary Critical Only/Full Service assignments surviving the mask in Section 3.6 (p. 20). The dispatch in Section 3.4 (p. 19) gives delivered sector power $y_{i,k,t}$. The action-dependent transitions are:

$$D^-_{i,t+1} = D^-_{i,t} + \Delta t \sum_k d_{i,k,t}, \qquad E^-_{i,t+1} = E^-_{i,t} + \Delta t \sum_k y_{i,k,t}.$$

The next previous-tier vector is a_t, and time advances by one hour. The generator advances ξ_t and supplies the next demand and supply independently of the action. Both cumulative vectors start at zero; the previous-tier vector starts Off, while the first-hour switching penalty is explicitly zero. At hour 24 the episode terminates, with no storage, terminal reward or carry-over into another episode. The policy seeks the expected sum of the hourly reward in Section 3.9 (p. 22) with discount $\gamma = 1$.

The policy observes 46 nonanticipative quantities. Here nonanticipative means using only information available at decision time; it does not mean causal identification. Four global features encode time using sine and cosine, current supply relative to demand, and supply relative to the fixed nominal system demand scale. Each locality contributes normalized current demand, its current critical-demand share, cumulative service ratio and previous service tier. These components form the original 32-value state representation. Seven cumulative-demand and seven cumulative- served-energy features complete the 46-value input.

The additional magnitudes matter because the same cumulative ratio can arise from different amounts of past demand. They are normalized using 24 times the fixed nominal demand scale of the corresponding locality. Their normalization does not use future episode demand. All features come from current observations and accumulated history; the policy receives no future supply, future demand, target-hour value or final evaluation outcome.

With $P_i = 700 w_i / \sum_j w_j$ MW as the fixed locality demand scale and $d_{i,t} = \sum_k d_{i,k,t}$, the four global inputs are $\sin(2\pi t/24)$, $\cos(2\pi t/24)$, $S_t / \max(\sum_i d_{i,t}, \varepsilon)$ and $S_t/700$. Each locality contributes $d_{i,t}/P_i$, its critical-demand fraction, $E^-_{i,t} / \max(D^-_{i,t}, \varepsilon)$ and $a_{i,t-1}/2$. Previous tiers are encoded as Off = 0, Critical Only = 1 and Full Service = 2; the binary x_i in Section 3.6 (p. 20) instead indicates an upgrade from Critical Only to Full Service. The final fourteen inputs are $D^-_{i,t}/(24 P_i \Delta t)$ and $E^-_{i,t}/(24 P_i \Delta t)$ for all seven localities. Thus every network input is dimensionless. Ratio denominators use the implementation's 10^{-8} numerical floor in their respective units; the floor is not an additional physical supply allowance.

Actor and critic use separate networks with two hidden layers of 256 $\tanh$ units. The actor produces 128 unnormalized action scores, or logits, one for each joint assignment. The critic predicts one scalar value. Hidden layers use orthogonal initialization; the actor output uses a small initialization gain. During training, an action is sampled from the masked distribution. During validation and final evaluation, the controller chooses the highest-logit feasible action, breaking exact ties by the lowest candidate index.

3.9 Reward and learning objective

The hourly reward retains the project's established objective:

$$r_t = \frac{5C_t + 2U_t + 2J_t - 0.25W_t - 3O_t}{9}$$

All five components are dimensionless. Let $q_{i,k,t}$ be requested MW, let $\mathcal{K}_c$ contain Hospital, Water and Bakery, and define total demand D_t, total requested power Q_t, delivered power Y_t and usable power P^u_t:

$$D_t = \sum_{i,k} d_{i,k,t}, \quad Q_t = \sum_{i,k} q_{i,k,t}, \quad Y_t = \sum_{i,k} y_{i,k,t}, \quad P^u_t = \min(S_t, D_t).$$

$$C_t = \frac{\sum_i \sum_{k \in \mathcal{K}_c} y_{i,k,t}}{\max(\sum_i \sum_{k \in \mathcal{K}_c} d_{i,k,t}, \varepsilon)}, \qquad U_t = \frac{Y_t}{\max(P^u_t, \varepsilon)}.$$

For fairness, use cumulative energy **after** dispatch at hour t:

$$z_{i,t} = \frac{E^-_{i,t+1}}{\max(D^-_{i,t+1}, \varepsilon)}, \qquad J_t = \frac{(\sum_i z_{i,t})^2}{7 \sum_i z^2_{i,t} + \varepsilon}.$$

$$W_0 = 0, \qquad W_t = \frac{1}{7}\sum_i \mathbf{1}[a_{i,t} \neq a_{i,t-1}] \quad (t > 0), \qquad O_t = \frac{\max(0, Q_t - S_t)}{\max(D_t, \varepsilon)}.$$

Thus C_t measures the hourly critical-service fraction, U_t measures usable-supply delivery, J_t measures equality of cumulative service ratios, W_t measures tier changes and O_t measures normalized oversubscription. The numerical safeguard is $\varepsilon = 10^{-8}$, with the corresponding units for each denominator. The reward normalizer 9 equals the sum of the positive weights; it does not convert the score to a percentage or a monetary value. Daily reward is $R = \sum_{t=0}^{23} r_t$; its ideal upper bound is approximately 24. Switching averages include the zero first-hour value, so the reported daily rate uses 24 hours rather than 23 transition opportunities.

The weights express the study's chosen priorities. They are not estimates of the monetary or social cost of interruption. For feasible masked actions, critical service is protected and oversubscription is absent, leaving the learner to balance use of the remaining supply, accumulated fairness and switching. A higher reward can still conceal a tradeoff among these components. The thesis therefore treats reward as a diagnostic of the training objective and presents public service outcomes separately.

PPO compares the probability of each sampled action under the updated policy with its probability under the rollout policy. Its clipped surrogate limits the objective's incentive for excessively large probability changes during an update. The probability ratio and clipped surrogate are:

$$\rho_t(\theta) = \frac{\pi_\theta(a_t \mid s_t)}{\pi_{\theta_{\text{old}}}(a_t \mid s_t)}$$

$$L^{\text{CLIP}}(\theta) = \mathbb{E}_t\Big[\min\Big(\rho_t(\theta)\widehat{A}_t,\ \text{clip}(\rho_t(\theta), 1-\epsilon_{\text{clip}}, 1+\epsilon_{\text{clip}})\widehat{A}_t\Big)\Big]$$

Here s_t and a_t denote the observed state and sampled feasible action, π_θ is the masked policy, and θ_{old} identifies the rollout policy. The advantage $\widehat{A}_t$ is normalized over the rollout, $\epsilon_{\text{clip}} = 0.2$, and $\mathbb{E}_t$ denotes an empirical minibatch mean. The implemented loss is minimized:

$$\mathcal{L}(\theta, \phi) = -L^{\text{CLIP}}(\theta) + 0.25\,\mathbb{E}_t\left[\left(V_\phi(s_t) - \widehat{R}_t\right)^2\right] - c_H\,\mathbb{E}_t[H(\pi_\theta(\cdot \mid s_t))]$$

V_ϕ is the critic, $\widehat{R}_t$ is the fixed value target computed by generalized advantage estimation (GAE), and H is the masked policy's entropy. The target uses the raw advantage, $\widehat{R}_t = A_t^{\text{raw}} + V_{\text{old}}(s_t)$, before advantage normalization. The squared-error coefficient is exactly 0.25: the value coefficient 0.5 multiplies half the mean squared error. The entropy coefficient c_H follows the schedule below. Stored masks, value targets and rollout probabilities remain fixed during these updates.

Generalized advantage estimation follows Schulman et al. (2016). For the complete 24-step episode, let $v_t = V_{\text{old}}(s_t)$ and set $v_{24} = 0$. The raw advantages are calculated backwards:

$$\delta_t = r_t + \gamma v_{t+1} - v_t, \qquad A_{24}^{\text{raw}} = 0, \qquad A_t^{\text{raw}} = \delta_t + \gamma\lambda A_{t+1}^{\text{raw}}.$$

Here $\gamma = 1$ matches the undiscounted daily score and $\lambda = 0.95$ controls the estimator's bias-variance tradeoff. The fixed critic target is $\widehat{R}_t = A_t^{\text{raw}} + v_t$. The actor uses the raw advantages centered and divided by their rollout population standard deviation plus 10^{-8}, over all $24 \times 256 = 6,144$ transitions. Neither the

target nor the recursion crosses an episode boundary. The value target is computed before advantage normalization.

3.10 Demonstrations and training procedure

Before reinforcement learning, each actor is initialized using demonstrations from a deterministic Fairness Rule. Among feasible actions within 0.005 of the best current-hour reward, it maximizes the minimum projected cumulative locality service ratio. Reward and then the lowest candidate index resolve ties. The tolerance was chosen in a prior study and is not retuned on the present experiment's validation or test outcomes.

Each run collects 455 demonstration episodes per shortage level, giving 1,365 episodes and 32,760 supervised states. Behavior cloning lasts ten epochs with minibatches of 1,024, including the last partial minibatch. Its loss combines masked action cross-entropy and 0.25 times the mean squared critic error against teacher return-to-go. A fresh PPO optimizer starts after this initialization. The retained behavior-cloning checkpoint makes the procedure's starting point inspectable.

Five training runs use seeds 1729, 2718, 3141, 5772 and 8111. Each run completes 3,000 iterations containing 256 full episodes, for 18,432,000 reinforcement-learning transitions per run and 92,160,000 across the five runs. Demonstration collection and evaluation are outside those totals. Independent scenario streams are used across runs, and separate random streams control initialization, action sampling and minibatch ordering. Table 3 (p. 24) collects the fixed configuration used by all five runs.

Table 3. PPO training configuration.

Setting	Value
Actor and critic hidden layers	256, 256
Actor input and output dimensions	46 and 128
Iterations per run	3,000
Episodes per iteration	256
Episode length	24 hours
PPO epochs per rollout	4
Minibatch size	1,024
Adam learning rate	0.0003 linearly to 0
Discount factor	1.0
GAE parameter	0.95
PPO clipping coefficient	0.2
Maximum gradient norm	0.5
Entropy coefficient	0.01 to 0.001

For zero-based PPO update index $k = 0, \ldots, 2999$, the learning rate and entropy coefficient are

$$\eta_k = 0.0003\left(1 - \frac{k}{2999}\right), \qquad c_H(k) = 0.01 + (0.001 - 0.01)\frac{k}{2999}.$$

Thus the last scheduled update has zero learning rate and entropy coefficient 0.001. The plots label this as completed iteration 3,000. Adam uses a numerical epsilon of 10^{-5}.

Each rollout uses 85 episodes per shortage level plus one rotating extra episode, giving equal severity exposure over 3,000 iterations. The training budget and checkpoint schedule are fixed before final evaluation.

3.11 Learned demand prediction

Ridge AR(3) fits each of the 35 locality-sector series using only observed demand at $t-3$, $t-2$ and $t-1$ to predict hour t. Seeds 42, 43 and 44 provide 256 training traces each: 768 traces and 16,128 targets per regression over hours 3 - 23.

Training-only means and population standard deviations normalize inputs, with a $10^{-8}\,\mathrm{MW}$ scale floor. Float64 ridge regression fits centered targets by minimizing mean squared residual plus a 0.001 coefficient penalty; the intercept is unpenalized. Predictions restore the target mean and clamp negatives to zero. Fitted parameters are retained.

Baselines use the same three-hour mean or last-hour persistence on identical targets. Evaluation uses 320 separate demand traces once each because shortage variants share demand. This forecast remains separate from PPO observations and the display projection.

Mean absolute error (MAE) and root mean squared error (RMSE) are reported in MW for locality-sector and system-total targets. System error sums the 35 signed residuals before taking absolute values or squares. Saved counts and error sums reconstruct pooled errors with the same target weighting.

4 Application implementation

4.1 Architecture and execution

GridGuard Khartoum separates scientific calculations from presentation. Domain objects define locality identities, sectors, units and valid tensor shapes. Scenario generation creates demand and supply. Controllers provide service tiers. The simulator applies the shared dispatch rules, and metric functions calculate outcomes from the resulting traces. A presentation layer then converts selected results into interface data.

The implementation uses Python 3.12, PyTorch 2.8 with CUDA 12.8, CuPy and PySide6. PyTorch (Paszke et al., 2019) executes batched generation, policy training, inference, dispatch and metrics. CuPy (Okuta et al., 2017) performs resampling and percentile calculations, sharing GPU arrays through the DLPack interchange interface. The scientific arrays remain on the GPU until the artifact or presentation transfer. This structure supports repeated matched experiments while keeping model calculations out of interface widgets.

The primary presentation and benchmark path requires the validated NVIDIA CUDA runtime. Startup checks the GPU environment and required model and evidence resources. When a required resource cannot be verified, the software reports the problem instead of presenting fabricated results. Small host-side checks support development and artifact assembly; they do not substitute a different scientific pipeline for the published GPU experiment.

4.2 The desktop workflow

The native application organizes the demonstration into Overview, Live Scenario and Results. The Overview introduces the localities, scope and available shortage levels. Live Scenario allows the presenter to choose a shortage level and seed, run a matched episode and inspect its hourly allocation. It uses the validation-selected PPO policy from training seed 8111 at iteration 2500, alongside Fixed Rotation and Constrained Optimization. Results retains the frozen five-run study; one live policy and scenario do not replace its matched-scenario averages.

The visual design uses an open pale canvas, restrained teal controls, clear typography and a contrasting selection color. The map, locality selector and time slider support inspection of one locality and hour without hiding the whole-day comparison. Textual service labels accompany color, and keyboard navigation provides access to the main pages and locality choices. The interface remains an explanatory tool: a polished map does not add physical realism to the underlying model.

Figure 4.1 (p. 27) shows locality context and navigation in the application overview. It is a software demonstration, not evidence of operation on the Khartoum electrical network.




Figure 4.1. Desktop overview. The seven-locality map and saved evidence support offline inspection of synthetic scenarios.

Figure 4.2 (p. 27) shows the selected locality, service tier and hourly PPO replay. The desktop demonstrates one validation-selected policy; the main study averages five independent runs.




Figure 4.2. Live Scenario inspection. The validation-selected seed-8111 checkpoint-2500 policy runs one matched episode. This demonstration is distinct from the frozen five-run results.

4.3 Offline geography and result handling

The locality display uses packaged administrative boundaries from the United Nations Office for the Coordination of Humanitarian Affairs (n.d.), with Nile river context from Natural Earth (n.d.). These assets allow the presentation to function offline and provide recognizable geographic orientation. They do not identify feeders, substations, supply routes or measured service territories. No geographic coordinate enters the policy's state or the simulator's dispatch calculation.

Live simulation runs away from the main interface event loop so that the window remains responsive. Once a complete episode is available, playback advances through already calculated frames. Moving the time slider does not retrain a model or alter the published benchmark. A live demonstration helps explain behavior on one episode; the main results rely on the separately evaluated matched scenario set.

Models and evidence are stored with explicit identities and SHA-256 checks. The constrained training study retains numeric weights rather than executable training checkpoint objects. Verification checks array shapes, finite values, model identity, scenario matching and metric consistency. These checks provide traceability, while the credibility of the scientific conclusion still depends on the validity of the model and study design.

4.4 Verification approach

Tests cover controller action rules, mask feasibility at the supply boundary, the critical-only fallback, reward and metric identities, terminal advantage estimation, stored action probabilities, checkpoint selection and independence of scenario splits. GUI checks cover page navigation, map interaction, selection, replay states and the minimum presentation layout. Real CUDA tests confirm the intended computation path.

The fifth research question is addressed through interface design and technical checks. No participant study measured comprehension or usability.

Independent replay provides a further check between selected model files and recorded results. It regenerates scenarios, executes saved controllers and compares actions and outcomes. The final verification status for the current experiment is summarized in Section 5.10 (p. 46); detailed hashes and reproduction references belong in Appendix A rather than interrupting the scientific argument.

5 Experimental design and results

5.1 Matched control evaluation

The main comparison includes Fixed Rotation, Constrained Optimization and five selected PPO actors. Five iteration-600 actors from the same training runs provide a secondary training-budget reference. All 12 methods receive identical inputs for each condition and use common dispatch and metrics. Final evaluation contains 960 conditions and 11,520 complete trajectories.

Training and demonstration scenario streams occupy separate ranges beginning at 4,000,000 and 4,500,000, with run-specific offsets. Validation uses seeds 122101 - 122105; final testing uses 122201 - 122210. Each seed generates 32 base draws with three coupled shortage variants. None of the final scenarios informs gradient updates, hyperparameters or checkpoint selection. The exact seed formulas and source bindings are retained in the protocol.

Table 4 (p. 29) distinguishes the selection set from the final-test set and counts coupled conditions separately from independent base draws.

Table 4. Validation and final-test scenario splits in the original focused study.

Evaluation element	Validation	Final test
Seed groups	5	10
Independent base draws	160	320
Shortage variants per draw	3	3
Matched conditions	480	960
Independently trained PPO runs	5	5

PPO inference uses deterministic highest-logit feasible actions. Variation arises from training differences and scenario generation, rather than repeated stochastic decisions at test time. The equally weighted five-run mean describes the learning procedure. The actor with the best final-test result is not substituted for it.

5.2 Validation selection and longer training

Each run is evaluated at iteration zero and every 100 iterations through 3,000. A checkpoint is eligible only when every validation condition has zero critical-outage locality-hours, zero critical-interruption locality-hours and zero power-balance violations, and fairness and utilization are each at least Fixed Rotation overall and at every shortage level. The eligible checkpoint with highest mean daily reward is selected; exact ties favor the earlier iteration. If none qualifies, the highest-reward fallback is identified explicitly and a positive primary claim is forbidden.

The rule is applied independently to all five runs. Selected weights and validation records are frozen before final testing. Constrained Optimization is a fixed comparator; no final-test-best actor, checkpoint or shortage-specific policy is selected. An optional validation-selected actor for demonstration never replaces the five-run result.

The iteration-600 snapshots belong to the same planned 3,000-iteration learning-rate and entropy schedule. They describe continuing that schedule, not an independently tuned short-budget method. A larger training budget creates an opportunity for improvement, but is not itself evidence of benefit.

5.3 Outcome definitions

Critical interruption occurs when positive critical demand receives less than 99% service during an hour. Summing across seven localities and 24 hours gives zero to 168 locality-hours. One locality-hour means one affected locality for one hour, not a system-wide clock hour. The retained evidence field named `critical_outage_locality_hours` uses this same 99% threshold; it is not a count of complete loss of critical service. The post-hoc audit separately counts complete critical outage when critical demand is positive and delivered critical power is exactly zero. Both definitions treat demand above $10^{-8}\,\mathrm{MW}$ as positive.

For locality i, cumulative service ratio $z_{i,t}$ equals cumulative served energy divided by cumulative demand. Jain fairness is calculated across the seven ratios at every hour, then averaged across all 24 hours:

$$J_t = \frac{\left(\sum_{i=1}^{7} z_{i,t}\right)^2}{7\sum_{i=1}^{7} z_{i,t}^2 + \varepsilon}$$

A high index indicates similar demand-normalized service, not necessarily Full Service. It is not only an end-of-day index. Utilization is the mean hourly ratio of delivered power to usable power, $\min(\text{supply}, \text{total demand})$, not a ratio of daily energy totals. Public critical-service ratio pools critical energy within an episode, whereas the reward uses each hour's critical-service fraction.

Table 5 (p. 30) defines the units and interpretation of the public outcomes.

Table 5. Evaluation outcomes, units and interpretation.

Outcome	Unit	Interpretation
Critical interruption	Locality-hours/day	Lower burden is favorable
Jain service fairness	Percent	Higher equality of cumulative service ratios
Supply utilization	Percent	Higher delivery of usable supply
Zero-service blackout	Locality-hours/day	Positive demand with exactly zero delivery
Blackout duration range / pairwise gap	Hours	Disparity in zero-service duration
Critical-interruption range / pairwise gap	Hours	Disparity in duration below 99% critical service
Longest blackout / critical interruption	Hours	Separate maximum locality streaks within the episode
Served / curtailed energy	MWh	Direct energy allocation
Switching rate	Mean hourly fraction	Operational proxy penalized in reward
Power-balance violation	Fraction of hours	Delivery above supply plus 0.001 MW
Daily reward	Unitless	Canonical objective diagnostic

Duration range is the maximum minus minimum locality duration. Pairwise gap averages absolute differences across all 21 unordered locality pairs. They are calculated within each episode before aggregation. Longest streaks stop at episode boundaries. Zero disparity can describe uniformly adequate

or uniformly poor service, so it is read alongside burden and energy. These direct measures assess blackout-duration inequality without relabeling Jain fairness.

5.4 Uncertainty and decision criteria

Effects are PPO minus the named comparator on matched conditions. Negative critical-interruption effects favor PPO; positive fairness and utilization effects favor PPO. Percentage measures use percentage-point differences. Unfavorable results and ties remain visible.

A hierarchical paired bootstrap uses 10,000 resamples with seed 20261024. It resamples the five training runs and the 32 base-draw clusters within each of the ten final-test seed groups. The same sampled clusters are shared across methods and training runs; each cluster retains its coupled Mild, Moderate and Severe variants. The two primary comparison claims use Bonferroni-adjusted 97.5% two-sided intervals, with linearly interpolated 1.25th and 98.75th percentile endpoints. Descriptive, per-run and secondary-budget intervals use 95% coverage. Shortage-specific intervals are exploratory; shortage mean guardrails remain part of the declared primary decisions.

Every reported PPO procedure mean weights the five selected runs equally, then weights all 960 conditions equally. Within a condition, fairness, utilization and switching are means over 24 hours, reward and locality-hour burdens are sums, and energy is integrated in MWh. For metric m, the overall paired effect is:

$$\widehat{\Delta}_m = \frac{1}{5 \times 960} \sum_{j=1}^{5} \sum_{c=1}^{960} \left(m_{j,c}^{\mathrm{PPO}} - m_{j,c}^{\mathrm{comparator}} \right).$$

The fixed and optimizer values repeat across training-run index j; for the budget comparison the comparator is the same run's iteration-600 actor. Severity means use the corresponding 320 conditions with the same equal-run weighting. Write L_m and U_m for interval endpoints, and $\Delta_{m,h}$ for the mean difference at shortage level h. A composite comparison passes only if **every** requirement below holds.

For **PPO versus Fixed Rotation**, the adjusted 97.5% endpoints must satisfy $U_{\text{critical interruption}} < 0$, $L_{\text{fairness}} > 0$ and $L_{\text{utilization}} > 0$. At each of Mild, Moderate and Severe, the mean critical-interruption difference must be at most zero and the fairness and utilization differences must each be at least zero. Each of the five selected PPO actors must have zero critical-outage locality-hours, zero critical-interruption locality-hours and zero power-balance violations in **every** final-test condition. All five validation selections must be eligible under Section 5.2 (p. 29). Fixed Rotation may have critical interruptions; reward is diagnostic and cannot substitute for these service requirements. This is a test of the complete constrained system, not the isolated effect of learning.

For **PPO versus Constrained Optimization**, the adjusted 97.5% endpoints must satisfy $L_R > 0$, $L_{\text{fairness}} \geq -0.002$ and $L_{\text{utilization}} \geq -0.002$. The ratio margin is 0.2 percentage points. At **each** shortage level, the reward mean difference must be nonnegative and the fairness and utilization mean differences must each be at least -0.002. Each selected PPO actor **and** Constrained Optimization must have zero critical-outage locality-hours, zero critical-interruption locality-hours and zero power-balance violations in every condition. All five validation selections must be eligible. The analysis separately reports whether the reward mean and adjusted lower endpoint exceed $+0.01$ daily reward. That practical reference does not waive any failed service requirement. Both the noninferiority margin and the reward reference are research choices, not validated operating standards.

For the **secondary additional-training comparison**, the paired 95% interval must have $L_R > 0$, $L_{\text{fairness}} \geq -0.002$ and $L_{\text{utilization}} \geq -0.002$. Each shortage must have nonnegative mean reward difference

and fairness/utilization differences of at least -0.002. Both the selected and iteration-600 actors must meet the same zero-interruption, zero-outage and zero-power-violation checks in every condition. All five selections must be eligible and each selected iteration must exceed 600. Otherwise the result is reported as a tradeoff, inconclusive comparison or earlier-checkpoint selection, as appropriate.

These rules, the training configuration and scientific source hashes were frozen in the 23 October 2026 protocol **before training and validation**. All five runs and their validation selections were frozen before generating or inspecting the final-test scenarios. This is a recorded internal protocol, not external preregistration or independent custody. The uncertainty describes this generator and five training runs; 960 conditions are not 960 independent policies. The later audit in Section 5.7 (p. 40) is explicitly post-hoc and does not change these original decision rules.

5.5 Main controller results

Table 6 (p. 32) compares all three procedures on common conditions. PPO values weight the five runs equally. Critical interruption, fairness and utilization lead the interpretation; duration, energy, switching and reward explain the behavior behind those outcomes.

Table 6. Final-test controller outcomes on 960 matched conditions; PPO averages five selected runs.

Outcome	Fixed Rotation	Constrained optimizer	PPO
Critical interruption (locality-hours)	102.05	0.00	0.00
Jain service fairness (%)	87.76	94.78	97.02
Supply utilization (%)	71.23	97.41	97.02
Daily reward	13.9688	23.4468	23.4967
Switching rate (%)	25.00	20.55	27.76
Critical service (%)	42.62	100.00	100.00
Zero-service blackout (locality-hours)	96.00	0.00	0.00
Power-balance violation rate	0.0000	0.0000	0.0000

Table 7 (p. 32) separates duration burdens and disparities from service-allocation fairness.

Table 7. Final-test interruption durations and disparities, averaged after calculation within each episode.

Duration outcome	Fixed Rotation	Constrained optimizer	PPO
Blackout duration range (hours)	3.000	0.000	0.000
Blackout mean pairwise gap (hours)	1.714	0.000	0.000
Longest blackout (hours)	6.000	0.000	0.000
Critical-interruption duration range (hours)	3.667	0.000	0.000
Critical-interruption mean pairwise gap (hours)	1.903	0.000	0.000
Longest critical interruption (hours)	8.000	0.000	0.000

Ranges and pairwise gaps are calculated within each 24-hour scenario before averaging. A zero duration disparity under shared critical protection is not evidence of equal Full Service. Mean available energy was 6709.05 MWh per condition. Mean served energy was 4551.33 MWh for Fixed Rotation, 6547.90 MWh for

the constrained optimizer and 6528.02 MWh for PPO. These energy totals differ from the reported mean of hourly utilization ratios.

Figure 5.1 (p. 33) displays the three main service outcomes with separate units. Critical protection and distribution quality are not compressed into one visual score.




Figure 5.1. Main controller outcomes. Results use 960 fresh matched test conditions. PPO is the equal-weight mean of five validation-selected policies. Each panel has its own units.

PPO - Fixed Rotation

Table 8 (p. 33) reports matched effects in the order shown above; the primary intervals are adjusted for the two-comparison family.

Table 8. Final-test paired effects: PPO - Fixed Rotation; adjusted 97.5% intervals.

Outcome	Mean difference	97.5% lower	97.5% upper
Critical interruption (locality-hours)	-102.0500	-102.0812	-102.0250
Jain service fairness (pp)	+9.2600	+9.1423	+9.3712
Supply utilization (pp)	+25.7815	+25.7017	+25.8594
Daily reward	+9.5279	+9.5184	+9.5357
Switching rate (pp)	+2.7639	+2.0601	+3.6639

PPO - Constrained Optimization

Table 9 (p. 34) reports matched effects in the order shown above; the primary intervals are adjusted for the two-comparison family.

Table 9. Final-test paired effects: PPO - Constrained Optimization; adjusted 97.5% intervals.

Outcome	Mean difference	97.5% lower	97.5% upper
Critical interruption (locality-hours)	+0.0000	+0.0000	+0.0000
Jain service fairness (pp)	+2.2368	+2.0955	+2.3731
Supply utilization (pp)	-0.3989	-0.4642	-0.3408
Daily reward	+0.0499	+0.0406	+0.0577
Switching rate (pp)	+7.2183	+6.5310	+8.1124

Figure 5.2 (p. 34) plots PPO minus Constrained Optimization effects with adjusted 97.5% intervals. The two primary comparisons both appear in Tables 8 and 9; this figure shows only the optimizer comparison and does not present validation learning curves.




Figure 5.2. Paired PPO effects against Constrained Optimization. Panels show critical interruption, Jain fairness, utilization and daily reward. Effects subtract the optimizer from PPO; intervals have 97.5% coverage for the two primary comparisons. Percentage outcomes use percentage-point differences.

The complete constrained PPO system met the predeclared improvement criterion against Fixed Rotation. This comparison includes differences in action choices and critical-service constraints, so it does not isolate the neural policy as the sole cause of the observed difference.

Against the constrained optimizer, the mean daily-reward difference was +0.0499 [+0.0406, +0.0577]. The full comparison criterion did not pass. Both controllers use the same critical-feasible action choices. The optimizer maximizes the current-hour objective exactly; PPO can trade a current decision against its consequences for later cumulative fairness and switching. Any whole-day advantage therefore concerns this nonanticipative myopic comparator and the specified reward, rather than a superior solution to the same exact optimization problem.

The corresponding fairness effect was +2.237 [+2.096, +2.373] percentage points, and utilization changed by -0.399 [-0.464, -0.341] percentage points. These outcomes distinguish service and efficiency effects from the weighted reward score.

Switching increased by +7.218 [+6.531, +8.112] percentage points, an unfavorable change. The fairness contribution outweighed both the utilization loss and extra switching penalty in the specified reward. Thus the trained procedure achieves fairer service allocation and a higher daily objective, with an efficiency and switching tradeoff.

In practical scale, the 0.0499 daily-score gain is 0.213% of the optimizer's 23.4468 score, or 0.208% of the approximate ideal daily bound of 24. Using the reward equation, the measured mean difference decomposes into +0.11930 from cumulative fairness, -0.02127 from utilization and -0.04812 from switching. Critical service and oversubscription contribute zero difference because both methods achieve full critical service without oversubscription on these conditions. These are arithmetic components of the chosen score, not independently identified causal effects.

The corresponding direct energy result is -19.88 MWh served per synthetic day: 6528.02 for PPO versus 6547.90 for the optimizer, from the same 6709.05 MWh available. PPO therefore leaves about 19.88 additional MWh unmet on average. This energy effect is calculated from the saved energy metrics; it is not a conversion of reward or of mean hourly utilization into MWh. The experiment does not measure the social value of the fairness gain, so it cannot establish that the score gain justifies the energy and switching costs in practice.

The optimizer reward difference also exceeded the earlier +0.01 daily-reward reference throughout its adjusted interval. That reference is a research convention; this simulation does not establish the operational value of a small score difference.

The unmet optimizer-comparison conditions were: severity service guardrails; utilization noninferiority.

All three shortage levels are reported in Section 5.6 (p. 35). Severity-specific intervals are exploratory, so a favorable subgroup does not replace the overall declared result. Zero blackout-duration disparities among critical-protected controllers also do not imply equal access to Full Service.

These comparisons assess allocation under the controllers' different protection rules. Zero blackouts under Critical Only do not imply equal Full Service; the shortage analysis therefore retains fairness, utilization and energy alongside interruption measures.

5.6 Shortage levels and learning progression

Mild conditions allow more Full Service combinations. The Severe shortage window restricts the number fitting within supply. Table 10 (p. 36) reports each level so a favorable overall mean cannot conceal a weaker condition.

Table 10. Final-test outcomes by shortage; 320 matched conditions per level and equal PPO run weights.

Shortage	Controller	Critical interruption (locality-hours)	Fairness (%)	Utilization (%)	Reward
Mild	Fixed Rotation	96.00	87.74	54.28	13.1911
Mild	Constrained optimizer	0.00	96.41	98.09	23.5881
Mild	PPO	0.00	97.99	98.12	23.6098
Moderate	Fixed Rotation	96.00	87.74	68.69	13.9600
Moderate	Constrained optimizer	0.00	95.00	98.02	23.4626
Moderate	PPO	0.00	97.21	97.52	23.5002
Severe	Fixed Rotation	114.15	87.80	90.73	14.7554
Severe	Constrained optimizer	0.00	92.94	96.13	23.2897
Severe	PPO	0.00	95.86	95.40	23.3801

Figure 5.3 (p. 37) shows each run's mean daily validation reward, Jain fairness and utilization, with selected checkpoints and the same-run iteration-600 reference. The largest reward and fairness gains occur early, followed by smaller improvements, while utilization declines. Thus the learning curves already show the tradeoff between reward and service examined on the final test. Differences between runs remain, supporting equal-run reporting rather than selection of one favorable test result. These are validation trajectories, not final-test performance at every training iteration.




Figure 5.3. Validation learning trajectories. Top: daily reward. Middle: Jain service fairness. Bottom: supply utilization. Each curve represents one training seed on fixed validation scenarios. Dots mark selected checkpoints; the dashed line marks iteration 600. These are not test results.

The TensorBoard diagnostics use the same recorded training values shown in the live monitor. Reward, policy loss, value loss, entropy, approximate KL divergence and clipping fraction are sampled every 25 PPO iterations, from iteration 25 to 3,000. Thin curves show the five runs; the darker mean and shaded band show the mean plus or minus one sample standard deviation. The band describes variation between training runs, not a confidence interval for final performance.

Each loss point is a minibatch-size-weighted mean over that update's four epochs, not a moving average over 25 updates. The value-loss panel reports half the mean squared error before its additional 0.5 weight. Training reward is the pre-update mean daily reward over the rollout's 256 episodes.

For a recorded metric $x_{k,j}$ from training run k at iteration j, the mean and sample variance are:

$$\bar{x}_j = \frac{1}{5}\sum_{k=1}^{5} x_{k,j}, \qquad s_j^2 = \frac{1}{4}\sum_{k=1}^{5}(x_{k,j} - \bar{x}_j)^2.$$

Figure 5.4 (p. 38) displays these unsmoothed training diagnostics, including the mean and sample-standard-deviation band. It is a training plot, distinct from the validation curves in Figure 5.3 (p. 37) and the final-test intervals in Figure 5.2 (p. 34).




Figure 5.4. TensorBoard training diagnostics. Rollout reward, policy loss, value loss, policy entropy, approximate KL and clipped fraction are recorded every 25 iterations without smoothing. The thick line is the five-run mean and shading is one sample standard deviation, not a confidence interval.

The validation-variance graph shows daily reward, Jain fairness and utilization over all 31 checkpoint evaluations, including the behavior-cloning starting point. It measures variability across independently trained policies on the same validation conditions. Fairness and utilization are converted to percentage points before calculating their variances; their axes therefore use squared percentage points. Figure 5.5 (p. 39) displays those variances. These descriptive curves do not replace the paired final-test intervals.




Figure 5.5. Between-run validation variance. Panels show sample variance of run-mean daily reward, fairness and utilization at 31 matched checkpoints. The denominator is four. Units are squared score or squared percentage points; this is not within-scenario variance or critic explained variance.

The curves show diminishing improvements in the specified objective. Across five runs, mean validation reward increased from 23.3196 after imitation to 23.4697 at iteration 600 and 23.4989 at iteration 3,000; 83.7% of that observed increase occurred within the first 600 iterations. The final 500 iterations added only 0.00144. Over the complete schedule, validation fairness rose from 93.12% to 97.00%, while utilization fell from 98.24% to 97.04%. These are common-iteration validation averages, not the selected actors' final-test results.

Between-run reward variance peaked at 7.31×10^{-4} at iteration 100 and ended at 7.99×10^{-5}, so the later plateau still contains differences between runs. The mean half-squared critic error fell from 0.00156 at the first recorded update to 0.000207 at iteration 3,000; entropy fell from 1.881 to 0.295 nats. Approximate KL and clipping fraction approach zero at the end partly because the scheduled learning rate reaches zero. These diagnostics support a description of the training trajectory, not proof of convergence to an optimal policy or removal of the observed utilization tradeoff.

Table 11 (p. 40) gives final-test rewards for validation-selected checkpoints, not the validation rewards used to choose them.

Table 11. Same-run final-test daily reward: iteration 600 versus the validation-selected actor.

Training seed	Selected iteration	Iteration-600 test reward	Selected-actor test reward	Difference
1729	2900	23.4497	23.4835	+0.0338
2718	3000	23.4654	23.4913	+0.0258
3141	2900	23.4699	23.5034	+0.0335
5772	3000	23.4781	23.5014	+0.0233
8111	2500	23.4732	23.5040	+0.0309

Table 12 (p. 40) gives the paired uncertainty for continuing the same training schedule.

Table 12. Final-test effects of selected actors minus same-run iteration-600 actors; descriptive 95% intervals.

Across-run outcome	Mean difference and 95% interval
Jain service fairness (pp)	+0.5895 [+0.5066, +0.6795]
Supply utilization (pp)	-0.2417 [-0.3165, -0.1908]
Daily reward	+0.0295 [+0.0255, +0.0332]
Switching rate (pp)	-1.6363 [-2.0580, -1.2294]

The full predeclared additional-training criterion did not pass. A larger budget alone therefore does not establish improvement on every declared requirement. Unmet conditions: severity service guardrails; utilization noninferiority. Daily reward changed by +0.0295 [+0.0255, +0.0332], while utilization changed by -0.242 [-0.317, -0.191] percentage points. The mean utilization loss is therefore about 0.24 percentage points, and its interval breaches the allowed 0.2-point loss.

The budget comparison is interpreted through its paired effects, service margins and selected iterations. A small score increase is not automatically a meaningful improvement in service. Unfavorable or inconclusive findings remain part of the result.

5.7 Post-hoc matched baseline and feasibility audit

The committee review prompted an additional comparison with Fairness Rule and a critical-aware rotating baseline. It reuses the original 960 final-test conditions and the five frozen selected PPO actors; no actor is retrained or selected using its results. This audit is post-hoc, not a fresh confirmatory holdout, and it does not change the original criteria in Section 5.4 (p. 31). Its purpose is to expose comparator dependence and separate critical protection from discretionary allocation.

Fairness Rule retains its teacher setting: among feasible actions within 0.005 of the highest immediate reward, it maximizes the minimum projected cumulative service ratio, then resolves ties by reward and candidate index. Critical-aware Fixed Rotation first requests the critical floor everywhere, then tries Full Service upgrades in fixed rotating locality order, retaining each upgrade only when it fits supply. The order advances by three localities every three hours. It uses no learned model and does not optimize reward. This comparator shares the critical floor, not the exact discretionary decisions of the original Off/Full Service schedule.

The follow-up evaluates nine methods: four deterministic rules/optimizers and the five frozen PPO actors, giving 8,640 nominal trajectories. It regenerates seeds 122201 - 122210 with 32 base draws and three coupled shortage levels. Input hashes, action hashes and per-condition metrics reproduce the seven

unchanged methods from the original experiment exactly. A separate frozen audit recipe precedes this execution; it is still post-hoc relative to the original results. No new primary pass/fail claim is registered.

Table 13 (p. 41) compares the five procedures. All four critical-protected procedures have zero critical interruption, zero complete critical outage and zero power violations in every nominal condition. Critical-aware rotation alone removes the original schedule's critical interruptions, showing that protection does not require learning. Differences in the remaining service outcomes concern how noncritical supply is allocated.

Table 13. Post-hoc matched baseline audit on the original 960 conditions; PPO is the equal mean of five frozen actors.

Procedure	Reward	Fairness (%)	Utilization (%)	Served (MWh)
Fixed Rotation	13.9688	87.76	71.23	4551.33
Critical-aware Fixed Rotation	23.2257	94.95	93.38	6286.39
Constrained Optimization	23.4468	94.78	97.41	6547.90
Fairness Rule	23.4865	96.15	97.32	6544.70
PPO	23.4967	97.02	97.02	6528.02

Table 14 (p. 41) reports PPO minus each added comparator. The paired hierarchical bootstrap uses 10,000 resamples with seed 20261031, equal run/condition weights and coupled shortage clusters. Its pointwise 95% intervals are descriptive; they do not replace the original adjusted 97.5% primary intervals.

Table 14. Post-hoc PPO effects against the two added baselines; mean differences and descriptive paired 95% intervals.

Outcome	PPO - critical-aware rotation	PPO - Fairness Rule
Daily reward	+0.2710 [+0.2631, +0.2782]	+0.0102 [+0.0024, +0.0172]
Fairness (pp)	+2.067 [+1.958, +2.172]	+0.864 [+0.747, +0.976]
Utilization (pp)	+3.638 [+3.573, +3.697]	-0.308 [-0.364, -0.255]
Served energy (MWh)	+241.63 [+236.89, +245.91]	-16.68 [-20.84, -12.99]
Switching rate (pp)	+4.994 [+4.355, +5.755]	+2.923 [+2.297, +3.682]

PPO improves fairness, utilization, served energy and reward over critical-aware rotation, although it switches more often. This is evidence of discretionary allocation improvement after sharing critical protection. It is not a pure learning ablation: action selection and the imitation-plus-PPO procedure also differ from the rotating rule.

Against its Fairness Rule teacher, PPO gains 0.0102 reward and 0.864 fairness percentage points, but serves 16.68 fewer MWh per day and loses 0.308 utilization percentage points. The reward interval's lower endpoint remains below the earlier +0.01 reference. The utilization interval is entirely below the earlier -0.2-point margin. These references provide context, not a newly declared confirmatory test. A positive pooled reward difference is insufficient to claim uniform superiority over the teacher or an operational improvement.

Exploratory reward differences against Fairness Rule vary by shortage: Mild -0.0207 [-0.0265, -0.0152]; Moderate -0.0133 [-0.0247, -0.0038]; Severe +0.0646 [+0.0556, +0.0737]. Thus the overall gain is concentrated in Severe conditions, with losses under Mild and Moderate shortage. Run-level results also vary: seed 1729 has a negative mean reward difference while the other four have positive means. All

severity and per-run records remain available in the audit artifact; the favorable subgroup does not replace the overall comparison.

The feasibility stress test retains the 320 base demand draws and replaces hourly supply with 75% or 25% of total critical demand. Each family has 320 conditions, with no artificial replication over the original shortage labels, giving 5,760 additional trajectories across nine methods. These are constructed infeasibility tests, not estimates of their frequency in Khartoum. Table 15 (p. 42) reports the resulting critical shortfall.

Table 15. Infeasible-critical-floor stress test; means over 320 demand conditions in each family.

Supply / critical demand	Procedure	Critical service (%)	Unmet critical (MWh)	Interruption (locality-h)	Complete outage (locality-h)
75%	All protected procedures	75.00	671.51	168	0
75%	Fixed Rotation	19.46	2163.33	168	96
25%	All protected procedures	25.00	2014.53	168	0
25%	Fixed Rotation	6.49	2511.80	168	96

All protected procedures means Critical-aware Fixed Rotation, Constrained Optimization, Fairness Rule and each PPO actor: their actions and outcomes coincide under the all-Critical-Only fallback. They fall back for all 24 hours and incur 168 locality-hours below 99% critical service, with zero complete critical outage. Their 75% and 25% service fractions follow the physical supply limit; high fairness and zero total blackouts do not mean adequate critical service. Every method records zero power-balance violations within the stated 0.001 MW tolerance. This verifies a defined response to infeasibility, not successful critical protection when supply is insufficient.

5.8 Learned forecasting results

The prediction experiment uses 320 demand traces from seeds 91001 - 91010, separate from the forecasting fit. Each method predicts hours 3 - 23, giving 235,200 locality-sector targets and 6,720 system targets. Common targets and training-only normalization prevent leakage through different windows or preprocessing.

Table 16 (p. 42) reports pooled errors on the common held-out target set.

Table 16. Forecast error on 320 held-out demand traces; 235,200 locality-sector and 6,720 system targets.

Forecast method	Cell MAE (MW)	Cell RMSE (MW)	System MAE (MW)	System RMSE (MW)
Three-hour trailing mean	2.3385	3.7436	42.7512	49.9759
One-hour persistence	1.3465	2.1776	24.3809	28.5917
Ridge AR(3)	0.6573	1.1882	9.3376	11.9242

Ridge AR(3) has the lowest error on all four measures. This demonstrates learned prediction benefit for the selected synthetic comparison, not real-demand calibration or superiority over every architecture. The figures are descriptive pooled errors; no forecast confidence interval is asserted.

Saved evidence retains fitted parameters and per-seed counts, absolute-error sums and squared-error sums, not the full runtime prediction arrays. Errors can be reconstructed from these sufficient statistics.

Forecasts remain separate from the policy and current display projection, so no controller improvement is attributed to them.

Figure 5.6 (p. 43) visualizes the same MAE and RMSE values from Table 16 (p. 42); it concerns prediction accuracy rather than the controller reward.




Figure 5.6. Held-out forecasting error. MAE and RMSE compare locality-sector and system-total targets on 320 held-out synthetic traces. Forecast evaluation is separate from the controller comparison.


5.9 Locality service and the learning-stage audit

The original final-test evidence also retains each locality's end-of-day service ratio: its total served MWh divided by its total demanded MWh over 24 hours. Figure 5.7 (p. 44) averages these ratios across the 960 matched conditions, with equal weights for the five selected PPO actors. It is a mean of per-condition ratios, not a pooled energy ratio or the hourly-mean Jain index used in the main results. No new scenarios or policies are introduced for this descriptive analysis.

PPO's mean endpoint service ranges from 54.83% for Jebel Awlia to 66.59% for Khartoum. Relative to the constrained optimizer, the mean ratio rises in Bahri, East Nile and Ombada, but falls in the other four localities. For example, it increases by 1.97 percentage points in East Nile and decreases by 2.42 points in Khartoum. Higher aggregate fairness therefore describes redistribution, not a service gain for every locality or 97% of demand being supplied.

The mean service ratio of the worst-served locality within each condition is 36.02% for Fixed Rotation, 44.90% for Constrained Optimization and 48.82% for PPO. Here the minimum is taken across the seven localities separately for each run and condition, before averaging; taking the minimum of the displayed locality means would answer a different question. PPO's 3.92-point improvement over the optimizer in this

endpoint measure coexists with the 19.88 MWh lower mean energy delivery already reported. This is an allocation tradeoff, not evidence about fairness within a locality or the social value of that tradeoff.



960 matched conditions; PPO weights five selected runs equally. Means of episode ratios.
Right: take the minimum within each condition before averaging.
These endpoint measures differ from hourly-mean Jain fairness and pooled energy ratios.

Figure 5.7. Locality service at the end of the day. Left: mean per-condition 24-hour served/demand ratios for the original 960 matched conditions; annotations show PPO minus Constrained Optimization in percentage points. Right: mean of the minimum locality ratio calculated within each condition. PPO weights its five validation-selected actors equally. These descriptive endpoint measures are distinct from hourly-mean Jain fairness and pooled energy ratios.

Fresh matched audit of the learning stage

The teacher comparison does not measure improvement over the imperfect cloned actor. A separate follow-up therefore compares each selected PPO actor with its own retained behavior-cloning (BC) initialization. The protocol was frozen before outcome generation, followed by an implementation-and-model freeze. The original findings were already known, so the motivation is post-hoc; fresh execution does not retroactively preregister the earlier studies. No policy was retrained, tuned or selected again.

Seeds 132201 - 132210 passed checks against retained training, demonstration, validation and evaluation metadata. Ten seeds provide 32 base draws each, giving 320 independent draws and 960 coupled Mild, Moderate and Severe conditions. None of their input hashes matches the 4,960 previous scenario hashes checked. Four fixed comparators, five BC actors and five selected PPO actors produce 13,440 trajectories on identical matched inputs.

The central contrast pairs actors within the five training runs. The hierarchical bootstrap uses 10,000 resamples with seed 20261031, resampling paired runs and base-draw clusters within ten seed strata. Sampled scenarios are shared across runs and methods, retaining all three coupled shortage variants. Means weight runs and conditions equally. The intervals are descriptive, pointwise and nominally 95%; they do not establish simultaneous superiority across outcomes or comparators. Table 17 (p. 45) reports the learning-stage effects.

Table 17. Fresh matched effects of selected PPO minus its own behavior-cloning initialization; mean differences and descriptive pointwise 95% intervals.

Outcome	Difference [95% interval]
Daily reward	+0.1801 [+0.1722, +0.1878]
Jain fairness (pp)	+3.914 [+3.775, +4.052]
Utilization (pp)	-1.213 [-1.261, -1.166]
Served energy (MWh/day)	-77.20 [-80.79, -73.85]
Switching rate (pp)	-5.404 [-6.084, -4.577]
Final minimum locality service (pp)	+4.887 [+4.410, +5.365]

All five run-level reward intervals and all three shortage-level reward intervals are positive. Nevertheless, utilization and served energy decrease in every shortage, with their intervals entirely below zero. Switching decreases overall, while its Severe-only interval crosses zero. Thus fine-tuning and selection improve the specified objective and several distribution measures relative to BC, with an energy cost. This contrast includes extra computation and validation checkpoint selection; it does not isolate the PPO algorithm, compare equal training budgets or establish that learning from scratch is necessary.

Table 18. Six procedures on the 960 fresh matched conditions; BC and PPO weight the five runs equally.

Procedure	Reward	Jain (%)	Util. (%)	Served (MWh)	Final min. (%)
Fixed Rotation	13.9705	87.76	71.25	4551.75	36.03
Critical-aware Fixed Rotation	23.2283	94.96	93.42	6287.17	51.72
Constrained Optimization	23.4430	94.72	97.41	6546.25	44.92
Fairness Rule	23.4858	96.16	97.32	6543.23	50.90
Behavior Cloning (BC)	23.3154	93.09	98.23	6603.25	43.93
PPO	23.4955	97.00	97.01	6526.04	48.81

Final minimum service in Table 18 (p. 45) is the lowest of seven end-of-day locality service ratios within each condition, averaged afterward. It is distinct from time-averaged Jain fairness and from the minimum of averaged locality ratios. **PPO's higher Jain fairness coexists with worse final service for the least-served locality than the teacher or critical-aware rotation.** The respective final-minimum effects are -2.086 [-2.517, -1.609] and -2.909 [-3.327, -2.448] percentage points. These adverse endpoints prevent a blanket equity claim.

Against Fairness Rule, the fresh reward difference is +0.0097 [+0.0016, +0.0170], with a mean below the earlier +0.01 reference. Served energy changes by -17.19 [-21.09, -13.73] MWh/day. Mild and Moderate reward effects favor the teacher; Severe favors PPO. The reference is context, not a new acceptance gate. The four fixed-comparator contrasts are replication diagnostics and replace none of the original primary decisions.

All protected methods, including BC, have zero critical interruption below 99% service, zero complete critical outage and zero power violations in every fresh condition. The separate validation receipt records exact replay of all 13,440 trajectories and CUDA reconstruction of means and intervals. The audit and receipts are retained as `data/evidence/thesis-learning-audit*`. These fresh seeds test the same

synthetic profiles and perturbations, not changed demand mechanisms or real-grid operation. Five training runs still limit uncertainty estimation; the original evidence remains unchanged.

5.10 Computation and verification

Five fresh training seeds completed 3,000 iterations each: 18,432,000 transitions per run and 92,160,000 overall. Total recorded training time was 35.98 minutes; final evaluation took 30.38 seconds. Validation selected iterations 2900, 3000, 2900, 3000, 2500 for seeds 1729, 2718, 3141, 5772, 8111, respectively. All five selections met the validation eligibility requirements. The final report uses the equal-run procedure mean rather than selecting the best performer on the final test.

Table 19 (p. 46) reports the validation scores used for selection; Table 11 (p. 40) separately reports those actors' final-test scores.

Table 19. Training cost and validation-selected checkpoints; reward is from validation, not the final test.

Training seed	Selected iteration	Validation reward	Training minutes
1729	2900	23.4855	7.23
2718	3000	23.4941	7.16
3141	2900	23.5051	7.19
5772	3000	23.5032	7.17
8111	2500	23.5070	7.22

The recorded runs used an NVIDIA GeForce RTX 5060 Laptop GPU with approximately 7.93 GiB of reported device memory, PyTorch 2.8.0 with CUDA 12.8, and CuPy 14.1.1. Training used float32, deterministic algorithms, disabled TF32, and the cuBLAS workspace setting `:4096:8`. These timings describe this hardware and execution configuration; they exclude the disclosed interrupted attempt and are not single-decision latency measurements.

Verification checks retained weights against validation records, common input identities across methods, action constraints and metric summaries. Statistical reconstruction checks intervals and decisions. Replay connects saved actors to regenerated inputs, recorded actions and outcomes. These checks address different failure modes; an evidence hash alone does not validate the scientific model.

6 Discussion

6.1 What AI and optimization contribute

The forecast and control studies provide separate evidence. Ridge AR(3) improves synthetic prediction; PPO is judged against Fixed Rotation and Constrained Optimization on the declared outcomes.

The optimizer selects the best feasible current action:

$$\arg\max_a r_t(s_t, a)$$

PPO learns a policy maximizing:

$$\mathbb{E}\left[\sum_{t=0}^{23} r_t\right]$$

PPO cannot exceed this one-step maximum at the same state. A daily gain can arise from changed service history and switching; no energy is stored. Section 5.5 (p. 32) quantifies the gain as 0.0499 reward units alongside about 19.88 fewer served MWh per synthetic day and increased switching. The reward weights value the fairness change sufficiently to raise the score, but the declared service criterion still rejects the comparison. Optimization therefore remains a credible choice when utilization and transparent decision rules matter. A composite score does not settle those priorities for operators.

Findings do not establish superiority to full-horizon optimization, model predictive control or all adaptive rules. Section 5.7 (p. 40) directly examines the current frozen actors against the Fairness Rule teacher and critical-aware rotation. The earlier negative teacher comparison remains separately identified in Appendix A.

The fresh audit in Section 5.9 (p. 43) makes the next distinction explicit. Relative to each run's own imitation-only actor, fine-tuning and validation selection increase daily reward by 0.1801 and Jain fairness by 3.914 percentage points, but reduce energy delivery by 77.20 MWh/day. This is a measured stage benefit for the chosen objective, with a service cost. It includes the additional training and checkpoint selection; it is not an equal-budget test isolating the PPO algorithm.

6.2 Critical protection and fair service

Critical protection comes from the mask and Critical Only. Default supply also permits a deterministic rule to protect these sectors. PPO allocates remaining supply; its Fixed Rotation advantage cannot be attributed solely to learning.

Equal partial service can produce high Jain fairness. Critical Only can remove blackouts while Residential and Commercial demand remains unmet. High utilization may repeatedly exclude a locality. Duration, burden and energy must be interpreted together.

The fresh endpoint analysis supplies a concrete counterexample: PPO has higher time-averaged Jain fairness than Fairness Rule and critical-aware rotation, but lower mean final service to the worst-served locality. The latter is 48.81% for PPO, 50.90% for the teacher and 51.72% for critical-aware rotation. Choosing an equity measure therefore changes which procedure appears preferable; these measures cannot resolve stakeholder priorities on their own.

No equipment wear, restoration delay or consumer switching cost is modeled. The 99% critical threshold and reward weights are research choices; operational priorities, facility requirements and tradeoffs need agreement.

6.3 Data and physical limitations

Synthetic profiles, fixed locality weights and demand-linked supply limit generalization. Fresh seeds prevent sample reuse but do not test changed demand patterns, prolonged damage or different shortage mechanisms.

Global supply omits network connectivity, feeder limits, losses, voltage and frequency constraints. Sector separation may be physically unavailable. Hourly, single-day decisions omit transients and multi-day disadvantage; administrative geometry supplies no electrical validation.

A more realistic simulation requires the operational data identified in Table 20 (p. 48).

Table 20. Data required for future physical and operational validation.

Required information	Purpose in a more realistic model	Present treatment
Metered locality and sector demand	Fit profiles and assess changing demand	Illustrative profiles and random perturbations
Independent generation and import availability	Represent actual supply limits and disruptions	Supply fraction derived from simulated demand
Facility inventory and essential operating loads	Define feasible critical protection	Aggregate Hospital, Water and Bakery categories
Recorded interruption timing and causes	Validate duration and service-history behavior	Modeled hourly allocations only
Feeders, capacities and switching permissions	Determine physically feasible service actions	Shared global supply and abstract tiers
Stakeholder priorities and vulnerability data	Assess burden and acceptable tradeoffs	Stated critical categories and locality metrics

These are required future data, not collected sources.

6.4 Learning and evaluation limitations

Five runs remain a small sample, and one recipe cannot establish performance across architectures, rewards or initializations. Conclusions concern this procedure and generator. Continuing training improved daily reward but reduced utilization by about 0.24 percentage points and failed the stated service margins (Section 5.6 (p. 35)). More computation therefore did not produce uniformly better service.

The action count grows as 2^N, requiring different representations and new feasibility tests at larger scales. The fresh comparison identifies the change from each saved imitation-only actor to its selected fine-tuned actor, but component attribution remains limited by checkpoint selection and unequal computation. Comparing training from scratch, further imitation and fine-tuning under equal budgets would test these mechanisms more directly. The new seeds replicate the same generator rather than testing a distribution shift, and the descriptive intervals do not establish familywise significance across all the additional outcomes.

Protocols and hashes support reproduction, not independent custody or field validation. Prior exploratory and unfavorable findings remain disclosed.

6.5 Implications for further work

Representative data and feasible network actions should precede planning with forecasts. Give competing methods equivalent forecasts and evaluate service under prediction error. Longer-horizon optimization and strong transparent rules should remain comparators.

The offline application meanwhile supports research by making assumptions, choices and matched outcomes understandable.

7 Conclusion

GridGuard Khartoum integrates shortage simulation, history-only prediction, critical-priority allocation, constrained optimization, PPO and offline communication. Its contribution is a reproducible comparison that identifies both objective gains and service costs. Ridge AR(3) separately improves synthetic prediction error over the selected simple baselines; its forecasts are not controller inputs.

On the original 960 matched conditions, the complete constrained PPO system met the declared comparison against Fixed Rotation. Critical protection follows from the action mask and sufficient supply, so the reduction from 102.05 to zero critical-interruption locality-hours is not a standalone demonstration that learning is necessary.

Against the constrained optimizer, PPO increased fairness by 2.24 percentage points and daily reward by 0.0499, with a 97.5% reward interval of [0.0406, 0.0577]. Both protected critical service. PPO used 0.40 percentage points less available supply and switched more often, so it failed the full declared service-guarded improvement criterion. The evidence therefore supports a measured benefit of this trained procedure in fairness and the daily objective against this current-hour optimizer, with an efficiency tradeoff. It does not establish universal superiority to optimization or an operationally preferable allocation.

Completing the planned fivefold training budget improved daily reward by 0.0295 relative to the same runs at iteration 600, but also reduced utilization by 0.24 percentage points. More training strengthened the learned objective without satisfying every service requirement.

The post-hoc audit strengthens the comparator analysis: PPO improves discretionary allocation over critical-aware rotation, but its 0.0102 reward advantage over Fairness Rule is accompanied by 16.68 fewer served MWh per day, lower utilization and more switching. Reward gains occur in Severe shortage while Mild and Moderate results favor the teacher. These findings do not establish uniform superiority or isolate the effect of PPO fine-tuning from imitation. Under inadequate critical supply, the fallback distributes the shortfall without exceeding capacity, while recording the unavoidable critical interruptions.

A separate fresh audit evaluates 13,440 trajectories on 960 new matched conditions. Against their own imitation-only initializations, the selected PPO actors gain 0.1801 daily reward, with a descriptive paired 95% interval of [0.1722, 0.1878], while serving 77.20 fewer MWh/day. The stage improves the chosen objective but does not dominate service outcomes: its final worst-locality service remains below the teacher and critical-aware rotation despite higher time-averaged Jain fairness. This evidence supports a bounded benefit from fine-tuning and selection, not a universal AI advantage.

The resulting software and evidence provide an inspectable academic decision-support system. The work does not claim national-grid calibration, operational readiness or universal AI superiority. Advancing toward those goals requires measured data, physically feasible actions and external engineering assessment.

Appendix A Supporting studies and reproducibility

A.1 Earlier comparisons

A previous constrained-PPO study evaluated five 600-iteration runs on a separate 960-condition test. PPO's mean daily reward was 23.44892, compared with 23.48759 for Fairness Rule. The difference was -0.03867 with a pointwise 95% interval of [-0.04425, -0.03319]. Both protected critical service in those default conditions. PPO improved reward and fairness over its behavior-cloning starting point but did not meet the full improvement criterion against Fairness Rule.

An earlier frozen-policy hybrid improved on constrained greedy allocation without beating Fairness Rule overall. The previous 2,187-action optimizer comparison also showed a tradeoff: Optimization had lower critical interruption and higher utilization, while the then-frozen PPO had higher Jain fairness. Those values concern different policies and scenario sets and are not mixed into the current main table. The longer training study does not retroactively reverse those findings.

A.2 Research objectives and evidence

The research questions in Section 1.2 (p. 12) connect model construction, prediction, protected allocation, matched evaluation and interpretation. Chapters 3 and 5 explain the data generation rules and the experiments; Section 6.3 (p. 48) identifies the operational data needed for a more realistic simulation.

The seven objectives are addressed through a Sudan-focused literature context; a seven-locality, five-sector simulator; learned forecasting and PPO decision support; critical-service tiers and constraints; comparisons with prediction baselines, priority rules and constrained optimization; matched evaluation against Fixed Rotation; and separate measures of downtime, service fairness, utilization and energy. The offline application makes these assumptions and results available for inspection.

This scope supports a synthetic software study. It does not turn illustrative parameters into measurements or make a favorable learning result a condition for a valid research contribution.

A.3 Exact synthetic generator

Let $h \in \{0, \dots, 23\}$ denote the hour, w_i the locality weights and b_k the sector coefficients in Table 1 (p. 18). Define a Gaussian-shaped component and the normalized sector profiles by

$$G(h; \mu, \sigma) = \exp\left[-\frac{1}{2}\left(\frac{h-\mu}{\sigma}\right)^2\right], \qquad p_k(h) = \frac{g_k(h)}{\max_{u \in \{0,\dots,23\}} g_k(u)}.$$

The normalization uses the 24 integer hours, not the maximum over continuous time. In Table 21 (p. 52), each peak is written as $(\text{amplitude}, \mu, \sigma)$, with μ and σ in hours; $g_k(h)$ is the constant plus the stated Gaussian components.

Table 21. Parameters of the unnormalized synthetic sector profiles.

Sector	Constant	First peak	Second peak
Hospital	0.95	None	None
Water	0.45	(0.35, 6, 2)	(0.40, 18, 2.5)
Bakery	0.35	(0.60, 5, 1.5)	(0.45, 16, 2)
Residential	0.40	(0.30, 7, 2)	(0.65, 20, 3)
Commercial	0.25	(0.75, 13, 4)	None

Hospital's normalized profile is therefore constant at one. With independent uniform draws $u_{i,k,h}, v_h \in [0,1)$, the nominal locality scale and perturbed demand are

$$P_i = 700\frac{w_i}{\sum_j w_j}\ \text{MW}, \qquad d_{i,k,h} = P_i b_k p_k(h)\,[1 + 0.05(2u_{i,k,h} - 1)].$$

Let $D_h = \sum_{i,k} d_{i,k,h}$. Supply for shortage level ℓ is

$$S_{\ell,h} = \min\{D_h f_\ell(h)\,[1 + 0.05(2v_h - 1)],\ 0.95D_h\}.$$

The fractions are $f_{\text{Mild}}(h) = 0.80$; $f_{\text{Moderate}}(h) = 0.65 - 0.10\mathbf{1}[17 \le h < 21]$; and $f_{\text{Severe}}(h) = 0.50 - 0.15\mathbf{1}[16 \le h < 22]$. The same demand and supply draws are reused for all three shortage variants of a base condition. Each call first draws the demand array and then the supply array from the seeded CUDA generator. The nominal study uses these defaults without demand or supply overrides.

The bounded noise also explains why the nominal generator can protect critical demand. Write C_h^0, N_h^0 for unperturbed critical and noncritical demand, and $q_{\ell,h} = 0.95 f_\ell(h)$. The 95%-of-demand cap cannot bind under these defaults because $0.80 \times 1.05 < 0.95$. The lowest real-arithmetic supply margin over critical demand is bounded by

$$S_{\ell,h} - C_h \ \ge\ (q_{\ell,h} - 1)1.05C_h^0 + q_{\ell,h}0.95N_h^0.$$

Evaluating all 24 hours gives minimum margins of approximately 114.16 MW, 74.02 MW and 32.57 MW for Mild, Moderate and Severe, respectively. This is an analytical envelope of the stated generator, evaluated using its frozen profiles, not a new sampled experiment or a guarantee for actual electricity supply. The separate infeasibility stress tests deliberately violate this nominal construction.

A.4 Evidence and reproducibility

The project source and review package are available in the GitHub repository. The reviewer guide identifies the current thesis, presentation, GUI captures and evidence. The original submission state preceding this revision is retained at commit `10ecbb425ddb05e36e602505a160a46345a4e635`; historical release evidence and later follow-up analyses remain separately labelled. Reproducing the scientific runs requires the documented CUDA environment; checking the supplied file manifest requires only Python.

The source literature review is retained at `docs/source/literature-review-authors.docx`, with bibliographic and claim checks recorded in `docs/LITERATURE_REVIEW_AUDIT.md`. The current control

protocol is `docs/FOCUSED_PPO_PROTOCOL.md`. The research archive also retains the forecasting study, earlier optimization comparisons and previous teacher comparison alongside their supporting evidence.

The separately hashed `data/evidence/committee-baseline-audit.json` records the post-hoc teacher, critical-aware rotation and infeasibility comparisons, including paired, per-run and shortage-specific results. It preserves the original model identities and exact replay of unchanged methods. Its descriptive 95% intervals and later audit recipe do not replace the original protocol or adjusted primary intervals.

The new `docs/THESIS_LEARNING_AUDIT_PROTOCOL.md` was fixed before the fresh execution, after the original findings were known. `data/evidence/thesis-learning-audit.json` contains all 14 methods on 960 new conditions; its separate validation receipt records exact replay and independent CUDA metric reconstruction. No policy was retrained or reselected. The endpoint plot and numerical generator/training interpretations are derived from the original evidence in `docs/assets/focused-study/locality-allocation.json` and `interpretation-details.json`, with source and figure hashes. These additions remain separate from the original benchmark shown in the app and defense slides.

Model weights, configuration, source identities and scenario/action hashes bind each experiment to its evidence. Current, historical and live results remain distinct. An interrupted initial training attempt was retained and restarted under the same frozen configuration; the training log records it separately, and completed-run timings exclude that attempt. No final-test results were consulted to restart or select training.

Training and evaluation elapsed times describe experimental cost, not single-decision latency. Comparing controller speed would require common hardware, batch size and synchronization rules; this study makes no speed-superiority claim.

Appendix B Source code and review package

The complete project source and review documents are available in the GridGuard Khartoum GitHub repository. The repository README is the entry point for the thesis, presentation, current GUI captures and reviewer guide. It also distinguishes current evidence from historical release artifacts.

The `src/gridguard/` package contains the domain model, scenario generation, dispatch, controllers, metrics, forecasting and PySide6 interface. The `tests/` directory contains unit, integration, GPU, GUI and packaging checks. `pyproject.toml` and `uv.lock` define the project and locked dependencies. `tools/` and `scripts/` provide reproducible study, document and packaging commands; `data/evidence/` and `data/model/` retain the scientific results and policy identities used by the application.

The core paths include `domain.py` for the canonical reward, `simulation.py` for shared dispatch and transitions, `constrained_ppo.py` for protected PPO actions, `focused_training.py` for the five-run procedure, `focused_results.py` for current-study integrity, and `scenarios.py` for synthetic inputs. These modules are under `src/gridguard/`; scientific calculations are separate from the UI.

From the repository root, `python tools/verify_review_package.py` checks the submitted file manifest using only the Python standard library. To run the application, install the locked Python 3.12 environment with `uv sync --locked --extra dev --extra docs`, check the NVIDIA CUDA runtime with `uv run --no-sync gridguard-doctor`, and launch `uv run --no-sync gridguard-desktop`. The initial installation needs a package cache or internet access; the installed application runs offline. The README and `SUBMISSION_README.md` document the full GPU tests and Windows build procedure.

References

Afzal, S., Mokhlis, H., Illias, H.A., Mansor, N.N. and Shareef, H. (2020) 'State-of-the-art review on power system resilience and assessment techniques', *IET Generation, Transmission & Distribution*, 14(25), pp. 6107 - 6121. https://doi.org/10.1049/iet-gtd.2020.0531.

Agarwal, R., Schwarzer, M., Castro, P.S., Courville, A. and Bellemare, M.G. (2021) 'Deep reinforcement learning at the edge of the statistical precipice', *Advances in Neural Information Processing Systems*, 34. Available at: https://arxiv.org/abs/2108.13264.

Al-Rikabi, I.J., Omara, A.A.M., Abuelnour, M.A., Abuelnuor, A.A.A., Mohamed, A.E. and Ismail, N.A. (2025) 'Renewable energy in Sudan: Current status and future prospects', *Engineering Reports*, 7(1), e13116. https://doi.org/10.1002/eng2.13116.

Basheir, R.H. and Abdelrahman, M.S. (2022) 'The electricity crisis in Sudan: Between quick-fixes and opportunities for a sustainable energy transition', *Transnational Institute*, 14 October. Policy essay. Available at: https://www.tni.org/en/article/the-electricity-crisis-in-sudan.

Bedi, J. and Toshniwal, D. (2018) 'Empirical mode decomposition based deep learning for electricity demand forecasting', *IEEE Access*, 6, pp. 49144 - 49156. https://doi.org/10.1109/ACCESS.2018.2867681.

Chen, H., Zhuang, J., Zhou, G., Wang, Y., Sun, Z. and Levron, Y. (2023) 'Emergency load shedding strategy for high renewable energy penetrated power systems based on deep reinforcement learning', *Energy Reports*, 9, pp. 434 - 443. https://doi.org/10.1016/j.egyr.2023.03.027.

Efron, B. and Tibshirani, R.J. (1993) *An introduction to the bootstrap*. Chapman and Hall/CRC. https://doi.org/10.1201/9780429246593.

García, J. and Fernández, F. (2015) 'A comprehensive survey on safe reinforcement learning', *Journal of Machine Learning Research*, 16(42), pp. 1437 - 1480. Available at: https://jmlr.org/papers/v16/garcia15a.html.

Glavic, M. (2019) '(Deep) reinforcement learning for electric power system control and related problems: A short review and perspectives', *Annual Reviews in Control*, 48, pp. 22 - 35. https://doi.org/10.1016/j.arcontrol.2019.09.008.

Heggie, A., Eager, D., McKinnon, K. and van der Weijde, A.H. (2018) 'Power rationing in a long-term power shortage', *Energy Policy*, 121, pp. 202 - 210. https://doi.org/10.1016/j.enpol.2018.06.025.

Huang, Q., Huang, R., Hao, W., Tan, J., Fan, R. and Huang, Z. (2020) 'Adaptive power system emergency control using deep reinforcement learning', *IEEE Transactions on Smart Grid*, 11(2), pp. 1171 - 1182. https://doi.org/10.1109/TSG.2019.2933191.

Huang, S. and Ontañón, S. (2022) 'A closer look at invalid action masking in policy gradient algorithms', *The International FLAIRS Conference Proceedings*, 35. https://doi.org/10.32473/flairs.v35i.130584.

Irwin, B.R., Hoxha, K. and Grépin, K.A. (2020) 'Conceptualising the effect of access to electricity on health in low- and middle-income countries: A systematic review', *Global Public Health*, 15(3), pp. 452 - 473. https://doi.org/10.1080/17441692.2019.1695873.

Jain, R., Chiu, D.-M. and Hawe, W.R. (1984) *A quantitative measure of fairness and discrimination for resource allocation in shared computer systems*. DEC Research Report TR-301. Available at: https://arxiv.org/abs/cs/9809099.

Jenkins, K., McCauley, D., Heffron, R., Stephan, H. and Rehner, R. (2016) 'Energy justice: A conceptual review', *Energy Research & Social Science*, 11, pp. 174 - 182. https://doi.org/10.1016/j.erss.2015.10.004.

Ji, Y., Wang, J., Xu, J., Fang, X. and Zhang, H. (2019) 'Real-time energy management of a microgrid using deep reinforcement learning', *Energies*, 12(12), 2291. https://doi.org/10.3390/en12122291.

Larik, R.M., Mustafa, M.W. and Aman, M.N. (2019) 'A critical review of the state-of-art schemes for under voltage load shedding', *International Transactions on Electrical Energy Systems*, 29(5), e2828. https://doi.org/10.1002/2050-7038.2828.

Natural Earth (n.d.) *1:10m rivers and lake centerlines*. Version 5.0.0. Public-domain geographic dataset. Available at: https://www.naturalearthdata.com/downloads/10m-physical-vectors/10m-rivers-lake-centerlines/ (Accessed: 31 October 2026).

Nduhuura, P., Garschagen, M. and Zerga, A. (2021) 'Impacts of electricity outages in urban households in developing countries: A case of Accra, Ghana', *Energies*, 14(12), 3676. https://doi.org/10.3390/en14123676.

Nti, I.K., Teimeh, M., Nyarko-Boateng, O. and Adekoya, A.F. (2020) 'Electricity load forecasting: A systematic review', *Journal of Electrical Systems and Information Technology*, 7, article 13. https://doi.org/10.1186/s43067-020-00021-8.

Okuta, R., Unno, Y., Nishino, D., Hido, S. and Loomis, C. (2017) 'CuPy: A NumPy-compatible library for NVIDIA GPU calculations', *Workshop on Machine Learning Systems at NIPS 2017*.

Oluwasuji, O.I., Malik, O., Zhang, J. and Ramchurn, S.D. (2020) 'Solving the fair electric load shedding problem in developing countries', *Autonomous Agents and Multi-Agent Systems*, 34, article 12. https://doi.org/10.1007/s10458-019-09428-8.

Paszke, A., Gross, S., Massa, F. et al. (2019) 'PyTorch: An imperative style, high-performance deep learning library', *Advances in Neural Information Processing Systems*, 32.

Poudel, S. and Dubey, A. (2019) 'Critical load restoration using distributed energy resources for resilient power distribution system', *IEEE Transactions on Power Systems*, 34(1), pp. 52 - 63. https://doi.org/10.1109/TPWRS.2018.2860256.

Ramchurn, S.D., Vytelingum, P., Rogers, A. and Jennings, N.R. (2012) 'Putting the smarts into the smart grid: A grand challenge for artificial intelligence', *Communications of the ACM*, 55(4), pp. 86 - 97. https://doi.org/10.1145/2133806.2133825.

Rosales-Asensio, E., Elejalde, J.L., Pulido-Alonso, A. and Colmenar-Santos, A. (2022) 'Resilience framework, methods, and metrics for the prioritization of critical electrical grid customers', *Electronics*, 11(14), 2246. https://doi.org/10.3390/electronics11142246.

Sarwar, S., Mokhlis, H., Othman, M., Muhammad, M.A., Laghari, J.A., Mansor, N.N., Mohamad, H. and Pourdaryaei, A. (2020) 'A mixed integer linear programming based load shedding technique for improving the sustainability of islanded distribution systems', *Sustainability*, 12(15), 6234. https://doi.org/10.3390/su12156234.

Schulman, J., Moritz, P., Levine, S., Jordan, M.I. and Abbeel, P. (2016) 'High-dimensional continuous control using generalized advantage estimation', *International Conference on Learning Representations*. Available at: https://arxiv.org/abs/1506.02438.

Schulman, J., Wolski, F., Dhariwal, P., Radford, A. and Klimov, O. (2017) *Proximal policy optimization algorithms*. arXiv:1707.06347. https://doi.org/10.48550/arXiv.1707.06347.

United Nations Office for the Coordination of Humanitarian Affairs (n.d.) *Sudan administrative boundaries (COD-AB)*. Revision v03. Humanitarian Data Exchange. Geographic dataset valid from 31 August 2020; CC BY 3.0 IGO. Available at: https://data.humdata.org/dataset/cod-ab-sdn. The archived download URL and SHA-256 identity are retained in `src/gridguard/assets/map/map-provenance.json`.

Vázquez-Canteli, J.R. and Nagy, Z. (2019) 'Reinforcement learning for demand response: A review of algorithms and modeling techniques', *Applied Energy*, 235, pp. 1072 - 1089. https://doi.org/10.1016/j.apenergy.2018.11.002.

Wang, C., Yu, H., Chai, L., Liu, H. and Zhu, B. (2021) 'Emergency load shedding strategy for microgrids based on dueling deep Q-learning', *IEEE Access*, 9, pp. 19707 - 19715. https://doi.org/10.1109/ACCESS.2021.3055401.

World Bank (2025) *Accelerating sustainable and clean energy and digital access transformation in Sudan (P507788)*. Project Information Document, Appraisal Stage, Report PIDIA01286, 1 May. Available at: https://documents1.worldbank.org/curated/en/099050125112514628/pdf/P507788-6a843250-44f5-47da-9f07-c6b1269a091f.pdf.