



Overview				Site	
Inspect N	52876	Page:	1/1		
Job No	14035				
Customer	AECOM				
Contact	Anth Warren	Date	02/04/2024		
Tel	07553 196353				
				OLDHAM DO	
				21 HAMILTON STREET	
				OLDHAM	
				OL1 1AA	

Pass

ISI Equipment No	Make / Model	Serial No	Client ID
29032024011	Door Powered Verticle		0000156137

Asset Photograph

Capture photograph of Asset, including asset number	See Photo 1
---	-------------

Hazard Priority and Findings

Intolerable - Defects requiring immediate action	None
Substantial - Defects requiring attention within a time period	None
Moderate - Other defects requiring attention	shutter electrical feed no longer working, door used manually now
Tolerable - Observations	None



General Comments

None

Engineer

Liam Weeder