



| Overview | | | | Site | |
|-----------|--------------|-------|------------|--------------|--|
| Inspect N | 53116 | Page: | 1/2 | | |
| Job No | 14058 | | | | |
| Customer | AECOM | | | | |
| Contact | Anth Warren | Date | 03/04/2024 | | |
| Tel | 07553 196353 | | | | |
| | | | | STAFFORD DO | |
| | | | | NEWPORT ROAD | |
| | | | | STAFFORD | |
| | | | | ST16 1AA | |

Pass

| ISI Equipment No | Make / Model | Serial No | Client ID |
|------------------|-------------------|-----------|------------|
| RM230224084 | Compressor Static | | 0000685889 |

Asset Photograph

| | |
|---|------------------|
| Capture photograph of Asset, including asset number | See Photos 1 & 2 |
|---|------------------|

Hazard Priority and Findings

| | |
|--|---|
| Intolerable - Defects requiring immediate action | None |
| Substantial - Defects requiring attention within a time period | None |
| Moderate - Other defects requiring attention | None |
| Tolerable - Observations | asset number to be clearly marked, this vessel requires a thorough examination with a written scheme under the PSSR regulations |



| General Comments | General |
|------------------|---------|
| None | None |

Engineer

Liam Weeder

L. W.

Comments