SAUDI ARAI	BIAN OIL COMPANY (Saudi Aramco)	G. I. NUMBER	Approved
GENERAL II	NSTRUCTION MANUAL	1001	.100
ISSUING ORG	. POWER DISTRIBUTION DEPARTMENT	ISSUE DATE 03/19/2002	REPLACES New
SUBJECT:	RESPONSIBILITY FOR POWER SYSTEM OPERATION AND MAINTENANCE AT SUPPORT SERVICES AND COMMUNITY FACILITIES	APPROVAL	PAGE NUMBER Page 1 of 7

CONTENT: This General Instruction outlines the areas of responsibility for the operation and maintenance of the Saudi Aramco electrical power systems at support services and community facilities. It covers Saudi Aramco operating areas within the eastern province (Udhailiyah, Abqaiq, Dhahran, Ras Tanura and Tanajib) excluding Saudi Aramco Government Built Schools. The text includes:

- 1.0 PURPOSE
- 2.0 DEFINITIONS
- 3.0 PROPONENCY
- 4.0 OPERATION
- 5.0 MAINTENANCE
- 6.0 WORK PERMIT
- 7.0 GENERAL TERMS

1.0 PURPOSE:

1.1 To establish & define area of responsibilities for the proponency, operation and maintenance of the Company's power systems at support services and community facilities. This will ensure safe and reliable operation and maintenance of Saudi Aramco power systems at support services and community facilities.

2.0 **DEFINITIONS:**

For the purpose of this instruction, the following terms will be used:

- 2.1 **Distribution Substation:** A step-down, step-up or switching substation, located at the load center, fed either from a receiving substation or from another distribution substation.
- 2.2 **High Voltage:** 1000V and above.
- 2.3 **Facility's Perimeter:** Any physical border enclosing assets owned by a facility department such as a fence, wall, building etc.
- 2.4 **Low Voltage:** Less than 1000V.
- 2.5 **Maintenance:** Any work performed using Saudi Aramco work order system including preventive maintenance, routine maintenance and emergency work.
- 2.6 **Operation:** Monitoring, controlling, and switching of electrical circuits (on/off) using the proper devices.

* CHANGE	** ADDITION	NEW INSTRUCTIONS	COMPLETE REVISION □

SAUDI ARA	BIAN OIL COMPANY (Saudi Aramco)	G. I. NUMBER	Approved
GENERAL INSTRUCTION MANUAL		1001.100	
ISSUING ORG	. POWER DISTRIBUTION DEPARTMENT	ISSUE DATE 03/19/2002	REPLACES New
SUBJECT:	RESPONSIBILITY FOR POWER SYSTEM OPERATION AND MAINTENANCE AT SUPPORT SERVICES AND COMMUNITY FACILITIES	APPROVAL	PAGE NUMBER Page 2 of 7

- 2.7 **Receiving Substation/Switchgear:** A substation/switchgear directly receiving power from source distribution network.
- 2.8 **Power Circuit Breaker:** Withdrawable and maintainable circuit breakers that are not molded-case (e.g., where protection relays are not part of the breaker structure).
- 2.9 **Process Equipment:** Equipment directly involved in the process of proponent facilities such as rotating machines, welding machines, furnaces, appliances, etc.
- 2.10 **Protective Relaying**: Typically, this is equipment used to detect and isolate defective lines, defective apparatus, or other dangerous or intolerable conditions, through the input of Voltage Transformers (VT's) and Current Transformers (CT's). In this document, the words "Protective Relaying" will also include, Ammeters, Voltmeters, KW meters, KVar meters, synchronizing circuits, and transfer schemes associated with protection relays under PDD's maintenance.
- 2.11 **Source Distribution Network:** A network utilized for distribution of power to different customers.
- 2.12 **Support Services Facilities:** Non-industrial facilities providing services such as communities, office buildings, warehouses, clinics, hospitals, A/C plants, communication facilities, sewage treatment plants, non-industrial water wells, and mechanical shops located in non-industrial plants.
- 2.13 **Utility Services:** Saudi Aramco utility services under the responsibilities of Dhahran Utility Department, Northern Area Community Department or Southern Area Community Department.

3.0 **PROPONENCY:**

- 3.1 The Power Distribution Department (PDD) shall be the proponent of:
 - 3.1.1 All residential substations and substations located external to and feeding multiple buildings or customers such as those located at the Dhahran core area.
 - 3.1.2 Source distribution network cables or bus ducts feeding distribution substations up to but excluding the first receiving equipment (e.g., switches, transformers & breakers).
 - 3.1.3 All overhead power distribution systems regardless of voltage levels.
 - 3.1.4 All source distribution network equipment.

	3.1.1	7 III Source distribution	network equipment.	
* CHANGE		** ADDITION	NEW INSTRUCTIONS	COMPLETE REVISION □

SAUDI ARAI	BIAN OIL COMPANY (Saudi Aramco)	G. I. NUMBER	Approved
GENERAL II	NSTRUCTION MANUAL	1001	.100
ISSUING ORG	. POWER DISTRIBUTION DEPARTMENT	ISSUE DATE 03/19/2002	REPLACES New
SUBJECT:	RESPONSIBILITY FOR POWER SYSTEM OPERATION AND MAINTENANCE AT SUPPORT SERVICES AND COMMUNITY FACILITIES	APPROVAL	PAGE NUMBER Page 3 of 7

- 3.2 Community or Support Services departments shall be the proponent of:
 - 3.2.1 All substations and equipment located within the facility's perimeter.

4.0 **OPERATION:**

- 4.1 The Power Distribution Department shall be responsible for the operation of:
 - 4.1.1 The first main incomer and tie breakers of double-ended receiving switchgear inside the facility's perimeter regardless of voltage level.
 - 4.1.2 All high voltage systems at support services & community facilities except for equipment (including breakers) dedicated for the proponent's operation as stated below (section 4.2).
 - 4.1.3 Overhead power lines and pole mounted electrical power equipment regardless of voltage level.
- 4.2 Proponent departments shall be responsible for the operation of:
 - 4.2.1 Electrical equipment dedicated for the facility's operation such as process equipment, feeder breakers, incomer & tie breakers of a non-receiving switchgear (i.e., not directly receiving power from the source distribution network), Motor control centers (MCC's), motors, generators etc.
 - 4.2.2 All low voltage systems within the proponent's facility except for the first main incomer and tie breakers of double-ended receiving switchgears. This shall include the low voltage feeder breakers, motors, etc.
 - 4.2.3 Proponents may seek area utility services or third party to operate equipment under proponent responsibility. Details of such arrangement are outside the scope of this GI.

5.0 MAINTENANCE:

- 5.1 Power Distribution Department shall be responsible for the maintenance of the following equipment:
 - 5.1.1 All high voltage systems at community and support services facilities.

* CHANGE ** ADDITION NEW INSTRUCTIONS ■ COMPLETE REVISION □

Saudi Aramco 718	80 (2/2002)			
SAUDI ARAE	BIAN OIL C	COMPANY (Saudi Aramco)	G. I. NUMBER	Approved
GENERAL IN	ISTRUCTION	ON MANUAL	1001	100
			ISSUE DATE	REPLACES
ISSUING ORG. POWER DISTRIBUTION DEPARTMENT				
CLIDIECT:	DECDONCI		03/19/2002	New
SUBJECT:		BILITY FOR POWER SYSTEM OPERATION AND ANCE AT SUPPORT SERVICES AND COMMUNITY	APPROVAL	PAGE NUMBER
	FACILITI			Page 4 of 7
	5.1.2	Low voltage first main incomer and tie breakers of double inside the facility's perimeter.	e-ended receiving	ng switchgear
	5.1.3	The low voltage bus ducts connecting the main transformers to the incomer breakers of double-ended receiving switchgear. Low voltage cables up to the main breaker of the premises at Saudi Aramco communities (residential houses) except for cable terminations at the equipment end.		
	5.1.4			
	5.1.5	Overhead power lines and associated equipment, regulaciation.	ardless of volta	ge level and
	5.1.6	Re-lamping and repairing of pole-mounted light fixtur above accessible by bucket trucks.	es at a height	of 20 feet or
	5.1.7	All protective relaying excluding molded case circuit breakers with built-in no micro-processor protection. Direct Current (D.C.) systems dedicated for protective relays including battery bank and chargers.		
	5.1.8			
	5.1.9	Supervisory Control And Data Acquisition (SCADA) exclusively used by Power Distribution Department.	devices and fa	ult recorders
	5.1.10	Uninterruptible Power Supply (UPS) system at Dhahran Building).	Core area (Tow	er & EXPEC
5.2	Area Ut	ility Services shall be responsible for maintenance of the fo	ollowing:	
	5.2.1	All low voltage equipment except for low voltage incomended receiving switchgears and as described in section 5		ers of double-
5.2.2 All low voltage bus ducts or cables that are not directly receiving power fro distribution network. This shall include cable terminations at equipment end.				
	5.2.3 Proponent organizations shall be responsible for maintenance of equipment idea in item 5.2.1 and 5.2.2 above for areas outside area utility services' jurisdiction as Tanajib area.			

* CHANGE ** ADDITION NEW INSTRUCTIONS COMPLETE REVISION □

SAUDI ARA	BIAN OIL COMPANY (Saudi Aramco)	G. I. NUMBER	Approved
GENERAL II	NSTRUCTION MANUAL	1001	.100
ISSUING ORG	. POWER DISTRIBUTION DEPARTMENT	ISSUE DATE 03/19/2002	REPLACES New
SUBJECT:	RESPONSIBILITY FOR POWER SYSTEM OPERATION AND MAINTENANCE AT SUPPORT SERVICES AND COMMUNITY FACILITIES	APPROVAL	PAGE NUMBER Page 5 of 7

6.0 WORK PERMIT:

This section specifies requirements that are additional to, or modifications of, those in G.I. 2.100, "Work Permit System." Where requirements of G.I. 2.100 are not discussed in this section, the requirements as specified in G.I. 2.100 are to be enforced.

- Work permits shall be written for all maintenance work on power distribution systems of 480V or greater. This requirement prescribes that such systems are declared restricted areas (refer to G.I. 2.100, §2.1). This is a minimum requirement, i.e., power distribution systems of less than 480V may also be declared restricted areas by proponent management.
- 6.2 The issuer of the work permit shall be from the organization that operates the equipment. This requirement differs somewhat from G.I. 2.100 which assumes that the proponent organization operates the equipment (refer to G.I. 2.100, §2.2). This may not be the case for power distribution systems.
- 6.3 The issuer of the work permit shall be responsible for ensuring that the requirements of G.I. 6.012, "Isolation, Lockout and Use of Hold Tags," are met.
- 6.4 If the issuer is not from the proponent organization:
 - 6.4.1 The issuer and the receiver must be from distinct operations and maintenance organizations.
 - 6.4.2 The proponent organization must concur on the work permit. This ensures that the proponent organization is aware of the maintenance work and the potential impact to their operation.

7.0 GENERAL TERMS:

- 7.1 Operation and maintenance personnel must adhere to all corporate and departmental safety rules and regulations, especially work permit, switching, tagging and lockout procedures.
- 7.2 In case of a relay operation under PDD's maintenance responsibility, the circuit shall NOT be re-energized unless authorized by PDD. The operating organization shall immediately report to the PDD power/local dispatcher all trips initiated by these protective relays.
- 7.3 The equipment operating organization is responsible for inspection of equipment for which it has operating responsibility.

* CHANGE	** ADDITION	NEW INSTRUCTIONS	COMPLETE REVISION □

SAUDI ARA	BIAN OIL COMPANY (Saudi Aramco)	G. I. NUMBER	Approved
GENERAL IN	NSTRUCTION MANUAL	1001	.100
		ISSUE DATE	REPLACES
ISSUING ORG.	POWER DISTRIBUTION DEPARTMENT	03/19/2002	New
SUBJECT:	RESPONSIBILITY FOR POWER SYSTEM OPERATION AND	APPROVAL	PAGE NUMBER
	MAINTENANCE AT SUPPORT SERVICES AND COMMUNITY FACILITIES		Page 6 of 7

- 7.4 Proponent organization shall be responsible for the inspection of substation buildings, air conditioning units, fences, yard etc.
- 7.5 PDD shall furnish reports and relevant information to the proponent department on major electrical equipment failures/anomalies for which PDD has operating and/or maintenance responsibilities.
- 7.6 Proponent departments shall release equipment for maintenance as per schedule to meet maintenance cycle requirements.
- 7.7 Maintenance organization shall provide a two-week notification request prior to taking equipment out of service for scheduled maintenance. A one week request is provided for normal repair maintenance. Emergency jobs shall be attended to immediately.
- 7.8 It is the responsibility of the proponent to remove all damaged/unneeded electrical assets from the plant. Maintenance organization shall be informed of the asset retirement or change in location.
- 7.9 Maintenance organization shall witness the pre-commissioning of all electrical equipment under its maintenance area of responsibility as defined in this instruction.
- 7.10 It is the responsibility of the equipment operating organization, as specified in this instruction, to ensure one-line diagrams and operating instructions are kept up-to-date.
- 7.11 For equipment under joint operation (such as the receiving switchgears) between PDD and an other organization, it shall be the responsibility of both PDD and the operating organization to maintain the operating instruction and on-line diagrams.
- 7.12 It is the responsibility of the equipment maintenance organization, as specified in this instruction, to ensure that maintenance manuals and schematic drawings are kept up-to-date.
- 7.13 For equipment under joint maintenance (such as the receiving switchgears) between PDD and an other organization, it shall be the responsibility of both PDD and the maintenance organization to maintain the maintenance instruction and schematic drawings.
- 7.14 Proponents shall ensure proper housekeeping of all substations under their proponency.
- 7.15 Maintenance organization shall provide assistance to project organizations in commissioning of new switchgear or modifications to the existing switchgear and motor control line-ups on low priority work-order basis for equipment under its maintenance responsibility. Additions, modifications or adjustments to equipment and circuitry shall remain project's responsibility

* CHANGE ** ADDITION NEW INSTRUCTIONS ■ COMPLETE REVISION □

Saudi Aramco 718	0 (2/2002)		
SAUDI ARAE	BIAN OIL COMPANY (Saudi Aramco)	G. I. NUMBER	Approved
GENERAL INSTRUCTION MANUAL		1001.100	
		ISSUE DATE	REPLACES
ISSUING ORG.	POWER DISTRIBUTION DEPARTMENT	03/19/2002	New
SUBJECT:	RESPONSIBILITY FOR POWER SYSTEM OPERATION AND MAINTENANCE AT SUPPORT SERVICES AND COMMUNITY	APPROVAL	PAGE NUMBER
	FACILITIES		Page 7 of 7
	(i.e., pre-commissioning). PDD will provide trip protective evaluation of control schemes.	relay settings	and assist in
7.16	Maintenance organization shall provide recommendations of sp power system repairs.	are parts and e	equipment for
RECOMME	NDED BY:		
Manager, Power Distr	ibution Department		
APPROVED	BY:		
Vice Preside Supply, Plan	nt, nning & Terminal		
Executive Di Safety & Ind	irector, Iustrial Security		
Executive Di Industrial So			
Executive Di Saudi Aram			
Executive Di Medical Ser	·		
Executive Di Community,	rector, Buildings & Office Services		
Vice Preside Information			
Vice Preside Project Man			

* CHANGE ** ADDITION NEW INSTRUCTIONS ■ COMPLETE REVISION □