

# Application of computational fluid dynamics and process modelling to investigate low-load operation of a subcritical utility-scale boiler.

**Brad T. Rawlins\***  
Ph.D. Candidate  
Department of Mechanical  
Engineering  
University of Cape Town  
Email: rwlbra001@myuct.ac.za

**Ryno Laubscher**  
Associate Professor  
Department of Mechanical  
Engineering  
Stellenbosch University  
Email: rlaubscher@sun.ac.za

**Pieter Rousseau**  
Professor  
Department of Mechanical  
Engineering  
University of Cape Town  
Email: pieter.rousseau@uct.ac.za

*To enable the inclusion of intermittent renewable energy sources on existing power grids requires base-load coal-fired power plants to operate flexibly, including fast load changes and continuous low-load operation. Low-load operation of a 620 MWe sub-critical boiler is analysed with the aid of a co-simulation methodology that incorporates a detail three dimensional computational fluid dynamics (CFD) model together with a one dimensional process model. A discretized one dimensional model of the water/steam circuit was developed for the furnace, the radiant superheaters and the convective/back pass heat exchangers. This is coupled with a detailed CFD model incorporating the furnace and radiant superheaters using a Eulerian-Eulerian reference frame. The coupled model is used to investigate the combustion stability, water/steam side effects, and the radiant heat exchanger operational limits for six different burner firing arrangements at a low boiler load of 32% of Maximum Continuous Rating. The results show that certain firing arrangements can lead to a high risk of fire-side corrosion and overheating of heat exchanger components. Based on analyses of combustion stability, boiler efficiency and the safe operation of heat exchanger components, a mixed firing arrangement with a higher secondary air mass flowrate for non-firing burners was selected as the best operational strategy at this low load for the boiler under investigation.*

## Nomenclature

### Variables

$A$	Area [ $m^2$ ]
$A_p$	Particle surface area [ $m^2$ ]
$A_{pn}$	Projected particle surface area [ $m^2$ ]
$A_c$	Carbon pre-exponential factor [ $s^{-1}$ ]
$A_{vol}$	Volatile pre-exponential factor [ $s^{-1}$ ]
$d_p$	Particle diameter [ $m$ ]
$E$	Fluid total energy [ $J/kg$ ]
$E_{a,c}$	Carbon activation energy [ $J/kmol$ ]
$E_{a,vol}$	Volatile activation energy [ $J/kmol$ ]
$E_p$	Particle emission power [ $W/m^3$ ]
$f_{heat}$	Near surface char oxidation fraction [–]
$f_p$	Forward scattering factor [–]
$G$	Incident radiation [ $W/m^2$ ]
$g$	Gravitational constant [ $m/s^2$ ]
$h_{fg}$	Enthalpy of evaporation [ $J/kg$ ]
$h_M$	Mixture enthalpy [ $J/kg$ ]
$h_{rxn}$	Enthalpy of reaction [ $J/kg$ ]
$J_k$	Species diffusion flux [ $m^2/s$ ]
$m_{0,vol}$	Original mass of volatiles [ $kg$ ]
$m_{char}$	Mass of carbon [ $kg$ ]
$m_{evap}$	Mass of moisture [ $kg$ ]
$m_{vol}$	Mass of volatiles [ $kg$ ]
$N_p$	Number of particles [–]
$P$	Perimeter [ $m$ ]
$p$	Pressure [ $Pa$ ]
$p_{O_2}$	Partial pressure of $O_2$ [ $Pa$ ]
$\dot{Q}_{conv}$	Convective heat transfer rate [ $W$ ]

\*Corresponding author

$\dot{Q}_{rad}$	Radiative heat transfer rate [W]
$\dot{Q}_w$	Wall heat transfer rate [W]
$q_{wall}$	Wall heat flux [W/m <sup>2</sup> ]
$R$	Universal gas constant [J/molK]
$R_c$	Carbon reaction rate [s <sup>-1</sup> ]
$R_{diff}$	Diffusion reaction rate [s <sup>-1</sup> ]
$R_{vol}$	Volatile reaction rate [s <sup>-1</sup> ]
$S$	Mass source term[kg/m <sup>3</sup> ]
$S_m$	Momentum source term [N/m <sup>3</sup> ]
$S_h$	Energy source term [W/m <sup>3</sup> ]
$S_k$	Species source term [kg/m <sup>3</sup> ]
$T_g$	Gas temperature [K]
$T_p$	Particle temperature [K]
$T_{wall,i}$	Wall temperature [K]
$T_{water}$	Water temperature [K]
$t$	Time [s]
$U_i$	Over heat transfer coefficient [W/m <sup>2</sup> K]
$u$	Velocity [m/s]
$V$	Volume [m <sup>3</sup> ]
$Y_k$	Species mass fraction [kg/kg]
$x$	Quality [–]
<b>Greek Variables</b>	
$\alpha_g$	Gas absorption coefficient [m <sup>-1</sup> ]
$\alpha_H$	Mixture void fraction [–]
$\alpha_p$	Particle absorption coefficient [m <sup>-1</sup> ]
$\epsilon_p$	Particle emissivity [–]
$\rho$	Gas density [kg/m <sup>3</sup> ]
$\rho_{eff}$	Effective density [kg/m <sup>3</sup> ]
$\rho_g$	Gas density [kg/m <sup>3</sup> ]
$\rho_l$	Liquid density [kg/m <sup>3</sup> ]
$\rho_M$	Mixture density [kg/m <sup>3</sup> ]
$\rho_p$	Particle density [kg/m <sup>3</sup> ]
$\sigma_{SB}$	Stefan-Boltzmann constant [W/m <sup>2</sup> K <sup>4</sup> ]
$\sigma_p$	Particle scattering coefficient [m <sup>-1</sup> ]
$\phi$	Scalar variable [–]
<b>Abbreviations</b>	
<i>MCR</i>	Maximum continuous rating
<i>CFPP</i>	Coal fired power plant
<i>CFD</i>	Computational fluid dynamics
<i>SH</i>	Superheater
<i>EE</i>	Eulerian-Eulerian
<i>WSGGM</i>	Weighted sum of gray gas model
<i>RTE</i>	Radiative transport equation
<i>HHV</i>	Higher heating value
<i>DAF</i>	Dry ash free
<i>AR</i>	As-received
<i>PA</i>	Primary air
<i>SA-AH</i>	Secondary air - air heater
<i>SA</i>	Secondary air
<i>RH</i>	Reheater
<i>ATT</i>	Attemperator
<i>EC</i>	Economiser

## 1 Introduction

The use of coal-fired power plants (CFPP) for electricity generation is intended to be phased out to reduce the rate of climate change. However, the move to sustainable generation sources poses great challenges for developing countries due to the long transition times and costs involved [1]. Due to the abundance of coal resources present in Southern Africa, CFPPs are still the dominant power generation source, with approximately 80% of the energy needs being met using CFPPs [2].

The integration of renewable energy sources will push CFPPs from primarily base load operation to a mid-merit/flexible operating protocol, which includes prolonged operation at low-loads. Long term deviation from design conditions can lead to operational inefficiencies affecting combustion stability [3], an increase in harmful emissions [4], and the localised overheating of heat exchangers due to insufficient cooling being provided by the internal working fluid [5].

While full scale testing or experimentation on CFPPs is deemed too expensive to pursue, mathematical models that can accurately capture the thermal response of boilers at varying loads can be used to determine the safe and efficient operating limits [6]. Computational fluid dynamics (CFD) allows for the modelling of full-scale CFPP boilers, at steady-state operating conditions. CFD simulations have been successfully used to model a variety of CFPP boiler types [7, 8] and cover various aspects such as pollution control [9, 10], gas-solid flow effects [11] and boiler retrofitting [8, 12].

Recent CFD studies investigating low-load operation of CFPP boilers have focused on the combustion stability, harmful emissions and the gas flow-solid flow interactions [13]. The works of Belosevic et al [14] found that the low-load operation of boilers considerably affects the flow and temperature fields, the flame geometry, chemical reactions and concentrations of combustion products.

Hernik et al [3] investigated the effects of using different mill system configurations at a minimum boiler load of 40%. The most favourable mill system configuration was selected based on the case that exhibited suitable combustion stability and emission of harmful substances. Similarly, Chang et al [4] investigated the various firing arrangements of a 630 MWe tangentially fired boiler. A burner angle of -15 ° was found to be the optimal arrangement resulting in the best compromise between combustion stability and lower emissions. The aforementioned research specifically investigated combustion and gas-side effects.

Various one-dimensional (1-D) process modelling approaches have also been used by researchers to investigate the water and gas side heat transfer interactions. These studies are usually aimed at investigating a transient event, such as a sudden disturbance, start-up, or boiler load ramping [15]. Due to the non-uniformities found in CFPP furnaces which are composed of complex combustion dynamics, gas-solid interactions and radiation heat transfer phenomena, 1-D process models can not resolve the fireside with sufficient accuracy. However it can adequately resolve the waterside

energy and momentum transport in a computationally inexpensive manner.

The use of coupled simulations has proven to solve the deficiencies of a full 1-D process model by coupling the fire-side CFD results to a 1-D water side model. Laubscher and Rousseau [16] conducted a comprehensive numerical study on the impact of particle radiation properties for high ash coals using ANSYS Fluent v19.2® and Flownex SE®, while Yu et al [17] used a coupled simulation methodology to estimate the superheater (SH) metal temperatures of a 660 MWe tangentially-fired coal boiler.

However, to the authors' knowledge, the integration of a 1-D process model with a detail CFD model has not been used to investigate the steam side operational performance of a CFPP boiler specifically at low-load. The goal of the current work is therefore to investigate the effect of burner firing configuration on various process parameters such as steam temperatures, spray water flowrates and metal temperatures at low-load, using a detailed CFD model on the gas side coupled to a comprehensive process model on the water/steam side.

To establish the accuracy of the CFD modelling approach a validation study was first conducted at loads of 100%, 80% and 60% Maximum Continuous Rating (MCR) and compared to actual plant measurements. Thereafter the model was applied to simulate the boiler operation at 32% of MCR with six different firing configurations.

## 2 Mathematical model

### 2.1 Computational fluid dynamics modelling

The present CFD work makes use of a Eulerian-Eulerian approach to capture the distribution of solid and gaseous phase properties such as mass fractions and velocities. The approach is similar to that of the mixture model supplied in ANSYS Fluent v19.5®, where a single momentum equation is solved for the different phases in the heterogeneous mixture. The main difference between the model applied in the current work and the standard mixture model is that the latter solves a single energy equation, whereas the former solves two energy equations, one for the gas phase and another for the solid phase. This is an important feature as it allows the adequate resolution of the temperature-dependent solid fuel combustion processes such as devolatilization and char oxidation, and accurate prediction of particulate radiative heat transfer. Typically, in solid fuel combustion processes the particulate temperature is higher than the surrounding gas temperatures due to the energy release from surface combustion, and incident radiation.

#### 2.1.1 Fluid flow, turbulence and combustion modelling

The flue gas-side was modelled using a Eulerian framework. The species transport modelling approach was used to approximate the mixture of chemical species in the gas phase. This approach solves a species continuity equation for each constituent present in the mixture. To reduce the computational burden, it was assumed that the various pro-

cesses were in steady-state. The governing equations for the gas phase are written below in their respective Reynolds averaged forms. Mass conservation:

$$\frac{\partial}{\partial x_i}(\rho \bar{u}_i) = S \quad (1)$$

Momentum conservation:

$$\frac{\partial}{\partial x_i}(\rho_{eff} u_i u_j) + \frac{\partial \bar{p}}{\partial x_j} = \frac{\partial}{\partial x_i} \left[ \mu \left\{ \frac{\partial u_j}{\partial x_i} + \frac{\partial u_i}{\partial x_j} - \frac{2}{3} \delta_{ij} \frac{\partial u_i}{\partial x_i} \right\} \right] + \frac{\partial}{\partial x_i}(-\rho \overline{u'_i u'_j}) + S_m \quad (2)$$

Energy conservation:

$$\frac{\partial}{\partial x_i}(u_i[\rho E + p]) = \frac{\partial}{\partial x_j} \left[ \lambda \frac{\partial T_g}{\partial x_j} \right] + S_h \quad (3)$$

Species transport:

$$\frac{\partial}{\partial x_i}(\rho u_j Y_k) = -\frac{\partial}{\partial x_j}(\vec{J}_k) + \sum_r R_{j,r} + S_k \quad (4)$$

$k = 1, 2, 3 \dots N$

To correctly account for the particle inertial effects on the gas phase convection, the model makes use of an effective density which is defined as follows:

$$\rho_{eff} = \frac{\rho_p \rho_p (\phi_{mp} + 1)}{\rho \phi_{mp} + \rho_p} \quad (5)$$

In the present study the realizable k-ε turbulence model was utilized to address the turbulence closure problem. This model has been successfully used by researchers ([14,7,5]), in modelling the effects of coal-fired swirl burners. The model generally produces higher accuracy results, when compared to the standard k-ε model, for problems incorporating swirling and separating flows.

The process of coal combustion comprises of four sequential steps namely, inert heating and evaporation of moisture, devolatilization, char oxidation and gas phase reactions. Equations (6) and (7) show the single rate kinetic model utilized in this study, to model the devolatilization process.

$$\frac{dm_{vol}}{dt} = R_{vol}(m_{0,vol} - m_{vol}) \quad (6)$$


$$R_{vol} = A_{vol} \exp\left(\frac{E_{a,vol}}{RT_p}\right) \quad (7)$$

$$A_{vol} = 2 \times 10^5 [s^{-1}], \quad E_{a,vol} = 6.7 \times 10^7 [J/kmol]$$

A devolatilization temperature of 553 K [18] along with the kinetic parameters (Eqn. 7) of Sheng et al [19] were utilized in the present study.

The char oxidation process is modelled using the diffusion-kinetics limited model developed by Baum and Street [20], which is given in Eqn. (8). The product species of the char oxidation reaction was set to  $CO$  as shown in Eqn. (9).

$$\frac{dm_{char}}{dt} = -A_p p_{O_2} \frac{R_{diff} R_c}{R_{diff} + R_c} \quad (8)$$



The diffusion and kinetic rates of Eqn. (8) are defined in Eqn. (10) and Eqn. (11) with the kinetic parameters again taken from the works of Sheng et al [19].

$$R_{diff} = \frac{5 \times 10^{-12}}{d_p} \left( \frac{T_g + T_p}{2} \right)^{0.75} \quad (10)$$

$$R_c = A_c \exp \left( \frac{E_{a,c}}{RT_p} \right) \\ A_c = 0.0053 [kg/m^2 s Pa], \quad E_{a,c} = 8.37 \times 10^7 [J/kmol] \quad (11)$$

The turbulence-chemistry interactions of the gas phase reactions were approximated using the eddy-dissipation-finite rate model used in ANSYS Fluent v19.5® which calculates three rates, namely chemical reaction rate, turbulent production eddies dissipation rate and reaction eddies dissipation rate. It then applies the minimum of the three for the source terms calculations. A description of the CFD gas phase reactions of the boiler under consideration, using the same coal, was previously published in the works of Laub-scher and Rousseau [6].

## 2.1.2 Particle modelling

The particles are modelled using a Eulerian reference frame, similar to the studies of Knaus et al [21] and Benim et al [22]. Both successfully used a Eulerian-Eulerian (EE) model to capture the characteristics of coal combustion and furnace heat transfer with adequate accuracy. The pseudo particle mass concentrations transported into the domain are modelled using the general scalar field transport equation with the necessary modifications to account for heat and mass transport [23]. The pseudo-particles scalar fields are used to define the fuel characteristics based on the proximate analysis composition, namely consisting of moisture, volatile matter, fixed carbon and ash. The scalar field equations are provided in Tab. 1.

The energy transport of the pseudo particle phase, is captured by defining a particle phase energy balance equa-

Table 1. Scalar field equation descriptions

Variable	Description	Transport equation
$\phi_{mp0}$	Original/initial mass of particles	$\frac{\partial}{\partial x_i} (\rho u_i \phi_{mp0}) = 0$
$\phi_M$	Moisture present in particles	$\frac{\partial}{\partial x_i} (\rho u_i \phi_M) = \frac{1}{V} \frac{dm_{evap}}{dt}$
$\phi_{VM}$	Volatile matter present in particles	$\frac{\partial}{\partial x_i} (\rho u_i \phi_{VM}) = \frac{1}{V} \frac{dm_{vol}}{dt}$
$\phi_{FC}$	Fixed carbon present in particles	$\frac{\partial}{\partial x_i} (\rho u_i \phi_{FC}) = \frac{1}{V} \frac{dm_c}{dt}$
$\phi_{ASH}$	Ash present in particles	$\frac{\partial}{\partial x_i} (\rho u_i \phi_{ASH}) = 0$
$\phi_{hp}$	Enthalpy of particle	Equation (12)

tion, which in turn uses the particle enthalpy.

$$\frac{\partial}{\partial x_i} (\rho u_i \phi_{hp}) = (f_{heat} \frac{dm_c}{dt} h_{rxn} + \dot{Q}_{rad} + \dot{Q}_{conv} - \frac{dm_{evap}}{dt} h_{fg}) \frac{1}{V} \quad (12)$$

The equation accounts for all the processes associated with energy transport to the particle, namely convection ( $\dot{Q}_{conv}$ ), radiation ( $\dot{Q}_{rad}$ ), latent heat transport ( $\frac{dm_{evap}}{dt} h_{fg}$ ) and near surface char oxidation ( $f_{heat} \frac{dm_c}{dt} h_{rxn}$ ). This gives the model the ability to track the particle temperature in the domain, which distinguishes it from the thermal equilibrium approach incorporated by previous studies using an EE approach [22, 24, 25]. The particle temperature is important in describing the sequential steps found in modelling combustion processes, especially at low boiler loads where mixing and ignition become problematic. To solve the additional transport equations and their source terms, user defined functions utilized by ANSYS Fluent, were developed using the C/C++ programming language.

## 2.2 Heat transfer modelling

Radiation heat transfer is the dominant form of heat transfer found in industrial furnaces [26] and is solved by applying the gray-participating-gas and particle medium configuration of the radiation transport equation (RTE) [27] shown in Eqn. (13).

$$\frac{dI(\vec{r}, \hat{s})}{ds} = \alpha_g \frac{\sigma_{SB} T_g^4}{\pi} - (\alpha_g + \alpha_p + \sigma_p) I(\vec{r}, \hat{s}) + \frac{\sigma_p}{4\pi} \int_{4\pi} I(\vec{r}, \hat{\Omega}) \Phi d\Omega \quad (13)$$

In the present work the RTE is solved using the P1 model. Ranade and Gupta [18] illustrated minimal differences between the two common radiation models (namely

the P1 and discrete ordinates (DO)) for the resultant wall heat transfer rate values when modelling a 210 MWe CFPP boiler. The P1 radiation model can include the effects of particle absorption ( $\alpha_p$ ) and scattering ( $\sigma_p$ ) as well as gas mixture absorption ( $\alpha_g$ ). The P1 model transport variable is the incident radiation flux ( $G$ ), and can be written for a particle laden domain as:

$$\frac{\partial}{\partial x_i} \left( \Gamma \frac{\partial G}{\partial x_i} \right) = (\alpha_g + \alpha_p) G - 4 (\alpha_g \sigma_{SB} T_g^4 - \pi E_p) \quad (14)$$

$$\Gamma = \frac{1}{\alpha_g + \alpha_p + \sigma_p}$$

The flue gas absorptivity was calculated using the domain based weighted sum of gray gas model (WSGGM) using the coefficients determined by Smith et al [28]. The WSGGM accounts for the radiation emitted by tri-atomic gases, namely  $CO_2$ ,  $H_2O$  and  $SO_2$  present in the flue gas stream. The Eulerian description of the terms  $\alpha_p$ ,  $\sigma_p$  and  $E_b$  are determined using the effective number of particles ( $N_p = \rho \phi_{mp0} V / (\rho_p \pi \bar{d}_p^3 / 6)$ ) present in a cell. The equations for the radiative properties are given in Eqn. (15) through Eqn. (17).

$$\alpha_p = \frac{\epsilon_p A_{pn} N_p}{V} \quad (15)$$

$$\sigma_p = \frac{(1 - \epsilon_p)(1 - f_p) A_{pn} N_p}{V} \quad (16)$$

$$E_p = \frac{\epsilon_p \sigma_{SB} T_p^4 A_{pn} N_p}{V} \quad (17)$$

It is important to note that variable properties for ( $\epsilon_p$ ) and ( $f_p$ ) were used, that are based on the correlations of Lockwood et al [29] and Yin [30] respectively.

### 2.3 Process simulation model

A 1D discretized model of the furnace evaporator, platen SH, final SH, and subsequent downstream heat exchangers was developed using Flownex SE® 2021. The data transfer between the two models makes use of a one-way approach, where the CFD simulation data is transferred to the Flownex process model when convergence of each case is achieved, a further explanation of the coupling interface is given in Section 3.1. The model simulates the internal convection heat transfer inside the tubes and the conduction through the tube walls. The model is able to simulate the attemperation flows and momentum transport through the steam/water circuit. The heat exchangers were modelled using a homogeneous two-phase mixture approach, which assumes that the fluid properties, phase velocities and temperatures are uniform per cross-sectional area. The homogeneous mixture fraction and mixture density are defined in Eqn. (18) and

Eqn. (19) respectively.

$$\alpha_H = \frac{\rho_l x}{\rho_l x + \rho_g (1 - x)} \quad (18)$$

$$\rho_M = (1 - \alpha_H) \rho_l + \alpha_H \rho_g \quad (19)$$

Applying the mixture density the following transport equations are solved per process model component;

$$\frac{\partial}{\partial t} (\rho_M A) + \frac{\partial}{\partial s} (\rho_M A u) = 0 \quad (20)$$

$$\frac{1}{A} \frac{\partial}{\partial t} (\rho_M A u) + \frac{1}{A} \frac{\partial}{\partial s} (\rho_M A u^2) = - \frac{\partial p}{\partial s} - \frac{\tau_w P}{A} - \rho_M g \frac{\partial z}{\partial s} \quad (21)$$

$$\frac{\partial}{\partial t} (\rho_M h_M) + \frac{1}{A} \frac{\partial}{\partial s} (\rho_M A u h_M) + \frac{1}{2} \frac{\partial}{\partial s} (\rho_M u^2) + \frac{1}{2A} \frac{\partial}{\partial s} (\rho_M A u^3) = \frac{\partial p}{\partial t} + \frac{\dot{Q}_w}{V} - g \rho_M u \frac{\partial z}{\partial s} \quad (22)$$

The process model is used to determine the required attemperation flow rates to achieve the exit steam conditions, boiler efficiency, and steam generation for each case. The results of this model aid in determining the best firing combination of burner rows for continuous low-load operation, and the effects on the water-side of the boiler system.

### 3 Case study boiler description & set-up

In this section the numerical model configuration, for both the CFD and process model, will be explained, covering the boiler geometry, the process model set-up, the various modelling inputs (i.e. fuel characteristics and boundary conditions) and the numerical solution strategy.

#### 3.1 Geometry & process model set-up

The modelled boiler is a two-pass sub-critical power boiler with a furnace depth of 13.77 [m], width of 14.01 [m] and height of 64 [m]. The CFD geometric model (of Fig. 1) makes use of a symmetry plane at half the width of the furnace. This was done to reduce the cell count of the numerical mesh. Both the platen and final SH are modelled as solid wall panels, with transverse pitches of 1.143 [m] and 0.8 [m] respectively. There are three levels of burners located on both the front and rear walls at heights of 11.9 [m], 19.3 [m] and 26 [m]. Figure 1 shows the modelled half of the furnace along with the locations of the platen SH, final SH, boundary walls (front, rear and side) and the domain outlet and inlets.

The boiler furnace is fed by six mills, each supplying a pulverised fuel and primary air (PA) mixture to a burner




Fig. 1. Boiler geometry and layout




Fig. 2. Burner layout and mesh details




Fig. 3. Process model of boiler set-up including the downstream convective components using Flownex SE® 2021

row consisting of six opposing wall mounted swirl burners. The swirl vanes were not modelled in this study, rather an axial and tangential velocity component were used for the secondary air (SA) inlets with these values being obtained from a detailed burner model supplied by the burner manufacturer, which included the vanes. The fuel/PA mixture is injected through the inner annulus of the burner while the SA air is fed through the outer annulus as seen in Fig. 2.

The CFD wall boundary conditions were modelled using ANSYS Fluent v19.5®'s convection boundary condition type, which requires the internal free stream temperature, the internal heat transfer coefficient, wall thicknesses and material conductivities. Being a flux boundary condition the wall heat flux ( $\dot{q}_{wall}$ ) can be calculated using Eqn. 23.

$$\dot{q}_{wall} = U_i(T_{wall,i} - T_{water}) \quad (23)$$

The overall heat transfer coefficient (U) is subsequently determined using the following expression.

$$U_i = \left( \frac{1}{h_{int}} + \frac{t_{wall}}{\lambda_{wall}} + \frac{t_{ash}}{\lambda_{ash}} \right)^{-1} \quad (24)$$

A 1D process model was used to estimate the furnace, platen and final SH internal heat transfer coefficients and internal temperatures for the low load case. For the validation cases the experimental data from site was used to estimate the mean water temperature in the heat exchangers.

The process model of the boiler configuration is shown in Fig. 3. The process model includes all the heat exchangers up to and downstream of the final SH, which include the secondary reheater (RH2), primary SH (SH1), primary reheater (RH1), economiser (EC) and the SA air heaters (SA-AH). The model includes all the relevant attemperators (ATT1, ATT2 and ATT-RH), inlets and outlets. The process model is used to determine the required attemperation flowrates and water/steam side thermal response. The furnace water-walls are represented by a single lumped pipe flow component and forms part of the natural circulation system that includes the downcomers and steam drum. As with the furnace walls, the platen and final SHs are similarly represented by a single lumped parameter pipe flow component, interconnected with nodes that introduce the attemperation flows to the water/steam side.

The coupling interface between the simulation models are the heat-exchanger external tube surfaces, namely the furnace, platen and final SH walls. The CFD heat loads are used as energy sources for these components as indicated in Fig. 3. The furnace heat load to the evaporator walls determines the circulation rate through the evaporator. The steam drum separates the gas from the liquid, with the liquid water being recirculated through the evaporator and the saturated vapour (steam) being sent through the main steam line for superheating. Thus the steam generation is calculated. Furthermore, the CFD flue-gas results (i.e. composition, mass flow and temperature) exiting the final SH are used as boundary values for the heat exchangers downstream of the final

SH (SH3), as shown in Fig. 3. The steam flow boundary values for the RH and EC sections are fixed inlet mass flows and temperatures with the corresponding outlets set to a fixed pressure.

Figure 4 illustrates the heat exchanger component process model. This component is used for the heat exchangers downstream of SH3 (refer to Fig. 3). The component model accounts for the radiative (gas and direct), convective and conduction heat transfer mechanisms to and from the gas-side and steam-side control volumes, as well as between up- and downstream heat exchangers on the gas side. The total heat transferred to the water-side control volume can be written as the sum of the absorbed direct radiation and the combined convective and gas radiative heat transfer (i.e.  $\dot{Q}_{steam} = \dot{Q}_{abs} + \dot{Q}_{cr}$ ). The external heat transfer coefficient, from the flue-gas to the heat-exchanger walls makes use of the Gnielinski correlation [31] for the various heat-exchanger tube arrangements. Figure 4 incorporates the direct radiative interactions in each heat-exchanger. It shows that the portion of direct radiation from the preceding heat exchanger that is not absorbed is joined by the bypass radiation ( $\dot{Q}_{bypass}$ ) of the flue-gas control volume which together make up the direct radiation passed on to the downstream components.

### 3.2 Model inputs

Table 2 presents the coal characteristics utilized in the current study along with the higher heating value (HHV) of the fuel.

Table 2. Utility boiler fuel characteristics

Fuel constituent	Fraction	Unit
<i>Ultimate analysis - (DAF)</i>		
Carbon	0.7753	kg/kg <sub>fuel</sub>
Hydrogen	0.0415	kg/kg <sub>fuel</sub>
Nitrogen	0.0181	kg/kg <sub>fuel</sub>
Oxygen	0.1474	kg/kg <sub>fuel</sub>
Sulphur	0.0175	kg/kg <sub>fuel</sub>
<i>Proximate analysis - (AR)</i>		
Fixed carbon	0.340	kg/kg <sub>fuel</sub>
Volatile matter	0.196	kg/kg <sub>fuel</sub>
Ash	0.4090	kg/kg <sub>fuel</sub>
Moisture	0.0550	kg/kg <sub>fuel</sub>
<b>Energy content - (DAF)</b>		
Higher heating value	15070	kJ/kg <sub>fuel</sub>

For a boiler load 32% MCR the current operational protocol is to use the bottom front and rear burner rows to meet the low-load demand during start-up. For this study six cases




Fig. 4. Heat-exchanger component model

are simulated with the following three burner firing configurations being investigated:

1. Bottom front and rear row burners are fired (Case 1 & Case 4)
2. Middle front and rear row burners are fired (Case 2 & Case 5)
3. Bottom front and middle rear row burners are fired (Case 3 & Case 6)

Table 3. Case 1 to 6 model inputs on a per burner basis.

Active burners	Cases 1 - 3	Cases 4 - 6
<b>Fuel flowrate</b> [kg/s]	3.14	3.14
<b>PA flowrate</b> [kg/s]	4.95	4.95
<b>SA flowrate</b> [kg/s]	14.85	14.85
Non firing burners		
<b>SA flowrate</b> [kg/s]	5.0	2.5
Input air temperatures		
<b>PA</b> [K]	373	373
<b>SA</b> [K]	520	510
<b>Excess air coefficients</b>	1.37	1.32

A secondary air flow rate of 5 kg/s is typically fed through the non-firing burners, to ensure sufficient cooling of the burner and mixing of fuel and air in the combustion chamber, with these three cases numbered 1, 2 and 3. The result is a high air-fuel ratio in the furnace, which leads to higher boiler dry gas loss. To lower this loss, this study will investigate the effect of reducing the air-fuel ratio by lowering the non-firing burner SA flowrate from 5 to 2.5 kg/s,

with these three cases numbered 4, 5 and 6. Two permutations of the SA flowrate, at the non-firing burners, are used for each of the firing configurations mentioned above. Table 3 shows the input conditions for Cases 1 to 6. This data was obtained via conventional boiler mass and energy balance calculations.

### 3.3 Numerical solution strategy

A numerical mesh consisting of approximately 6 million cells was used for the CFD simulations of this current study. To ensure that the results are grid size independent, simulations were also performed for mesh sizes of 3.5 million and 10 million cells during the validation study, discusses in Section 4.1. To ensure numerical stability during simulation the aspect ratio and mesh orthogonality quality where kept below 20 and above 0.2 respectively.

The CFD simulations were performed using ANSYS Fluent v19.5<sup>®</sup> pressure-based solver. The pressure-momentum coupling utilised the SIMPLE method. Second-order upwinding was used to discretize the momentum, energy and species equations, whereas PRESTO! was used to discretize the pressure equation. The scalar field equations used a second-order upwind scheme.

The spatial discretization for all fields (except pressure) was set to first-order upwind for the first 1000 iterations to ensure a stable solution, after which the discretization order was increased to the above mentioned criteria. For all cases the maximum mass imbalance was 0.024 [kg/s] for a total gas flowrate of 190 [kg/s], and a heat imbalance of 1770 [kW] for a total heat input of 283 [MW]. The remaining fields were solved till convergence.

## 4 Results & discussion

### 4.1 Model validation

The validation of the proposed model was conducted for three steady-state MCR loads of 100%, 80% and 60%



respectively. Actual plant measurements were used to calculate the thermal heat loads of the three heat exchangers, namely the furnace, platen and final SH, to quantify the accuracy. The model inputs and thermal boundary conditions can be obtained from the studies conducted by Laubscher and Rousseau [6, 32], where using the same boiler of the present study, they evaluated the thermal performance of the heat exchanging components at full and reduced boiler loads.

Figure 5 shows that the calculated overall heat loads are in good agreement with the measured values where the model results are within the associated uncertainty range in all but one case. The simulation systematically under predicts the furnace heat loads, with a maximum percentage error of 2%, while predominating overpredicting the platen SH loads, with a maximum percentage error of 7%.

The CFD model was further validated by comparing the  $CO_{ppm}$  and  $X_{O_2}$  measurements against the CFD results. The probe measurements were taken at a furnace height of 37.5 [m] near the center of the boiler during full load (100% MCR) operating conditions. The probe is inserted from the side walls to a depth of 4.5 [m], and measurements were taken every 0.5 [m].

Figure 6 shows the averaged measurement values compared to the CFD predictions. It can be seen that the CFD model can resolve the  $CO_{ppm}$  and  $X_{O_2}$  concentrations at the given probe location with sufficient accuracy.

#### 4.2 Simulation results for various burner firing arrangements at 32% MCR

The temperature and velocity profiles for the various firing arrangements are shown in Fig. 7 and Fig. 8 respectively. With the middle burner rows firing (Cases 2 and 5) a substantial cold region is formed in the lower half the furnace, resulting in the lowest heat uptake. This is further exacerbated when considering Tab. 5 where it is illustrated that the mid-firing arrangements produce the lowest steam flow rates resulting in the lowest boiler efficiencies. The bottom firing arrangement (Cases 1 and 4) results in a high temperature zone located in the bottom half on the burner, while the mixed firing arrangement (Cases 3 and 6) results in an even distribution of high temperature gases across the furnace domain (Fig. 7). This leads to the highest steam generation rate in the furnace and boiler efficiency as shown in Tab. 5.

Table 4. Furnace exit conditions and SH wall temperatures

		Cases					
		1	2	3	4	5	6
<i>Furnace exit</i>							
<b>Exit temperature [K]</b>		1168	1230	1215	1208	1306	1298
<b>Unburnt carbon [(<math>\times 10^{-3}</math>) %]</b>		1.83	1.94	1.54	1.81	1.89	1.62
<i>Platen SH</i>							
<b>Max wall temperature [°C]</b>		477	492	481	480	493	490
<b>Mean wall temperature [°C]</b>		439	453	446	454	442	451
<i>Final SH</i>							
<b>Max wall temperature [°C]</b>		602	624	608	595	626	612
<b>Mean wall temperature [°C]</b>		520	523	517	512	520	511

Figure 9 illustrates the heat flux profiles for the simulated cases. Both cases 1 and 4 highlight high heat flux zones near the burner inlets which, in the presence of high temperatures and incomplete combustion near these regions, can lead to high-temperature corrosion [1]. An even distribution of heat fluxes is seen in Cases 3 and 6 with minimal localised heat flux concentrations being observed. Cases 2 and 5 show that most of the heat is absorbed in the upper half of the boiler with Case 5 showing a higher heat flux on the rear wall. This could be due the use of a lower SA flowrate leading to higher velocity profiles developing closer to the rear wall, as seen in Fig. 8. With this in mind a lower SA flowrate, in general leads to hot gases and velocity profiles impinging closer to the furnace walls, which can be seen in Cases 4, 5 and 6 of Fig. 7 and Fig.8 respectively. With high gas temperatures and high velocity impingement, Cases 4, 5 and 6 (of Fig. 9) experience concentrated heat fluxes around the burner inlets in comparison to corresponding Cases 1, 2 and 3.




Fig. 5. Comparison of experimentally calculated and model heat loads for the furnace, platen SH and final SH




Fig. 6. Measured and predicted  $CO_{ppm}$  (a) and  $X_{O_2}$  (b) concentrations

The works of Dugum et al [1], highlights the issue of high-temperature corrosion caused by significant levels of  $CO$  ( $X_{CO}$  0.01 - 0.1) and no-free  $O_2$  near regions of high wall temperatures. For low-load operation this phenomenon becomes important to avoid since combustion instability can lead to these non-ideal circumstances. Figure 10 shows the  $CO$  molar concentration in the domain located on an iso-surface set 1600 [K]. The figures generally highlight the lo-

Table 5. Process model control parameters

	Cases					
	1	2	3	4	5	6
<b>Main steam flowrate [kg/s]</b>	175.8	172.9	180.5	180.2	179.1	184.1
<b>Main steam exit temp [°C]</b>	535	535	535	535	535	535
<b>RH steam flow rate [kg/s]</b>	158.2	155.6	162.5	162.2	161.2	165.6
<b>RH steam exit temp [°C]</b>	524	527	531	512	510	520
<b>Boiler efficiency [%]</b>	85.3	84.1	87.9	87.2	85.9	89.1
<b>ATT1 [kg/s]</b>	10.4	16.9	13.9	7.9	5.5	10.9
<b>ATT2 [kg/s]</b>	1.7	3.8	4.2	3.8	3.6	4.2
<b>ATT-RH [kg/s]</b>	0.0	0.0	0.0	0.0	0.0	0.0

cation and distribution of the flame core for each case. Cases 1 and 4 illustrate the highest likelihood of high-temperature corrosion occurring near the furnace hopper, due to the high concentration and temperatures in that region.

Investigating the combustion stability for all the cases, the symmetry and offset vertical probe plots (as highlighted in Fig. 1) are given in Fig. 11. Cases 2 and 5 illustrates the highest  $X_{O_2}$  concentration in the lower half of the burner since there is minimal combustion occurring. The unburnt carbon content and exit flue-gas temperatures for each case are reported in Tab. 4. With the use of the middle burners (Cases 2 and 5) the highest exit temperature and unburnt carbon content is observed, since the flame core is located in the upper half of the furnace leading to the least possibility of complete combustion due to the shorter residence time. Cases 3 and 6 exhibit the best characteristics with the least




Fig. 7. Temperature fields for Cases 1 through 6 [(a)-(f)]

amount of unburnt carbon content being observed. It is important to note the effects of a lower SA mass flow rate has on the furnace exit conditions for non-firing burners, which generally leads to a hotter exit gas temperature as seen with Cases 4 to 6.

The external tube metal temperatures, shown in Tab. 4 were calculated using Eqn. 25, which takes into account the temperature drop due to the ash deposit present on platen and final SH. Fouling thermal resistances of 0.0067 and 0.015 [ $m^2K/W$ ] were used for the platen and final SH respectively.

$$T_{metal} = T_{wall} - \left( \frac{\dot{q}_{SH} t_{ASH}}{\lambda_{ASH}} \right) \quad (25)$$

For the platen and final SH the maximum surface temperature are observed for Cases 2 and 5. For comparison, at 100% MCR load the maximum and mean temperatures reported for the platen and final SH are 500 & 446 [ $^{\circ}C$ ] and 623 & 531 [ $^{\circ}C$ ] respectively, with the final SH operating in the materials creep range [6]. Thus, continued operation using the firing arrangement of Cases 2 and 5, could lead to SH failure.

Using the process model of Fig. 3 and the results of the CFD simulations the important process control parameters were determined. Table 5 summarizes the results with the highest boiler efficiencies observed for Cases 3 and 6. With a lower SA flowrate Cases 4 to 6 exhibit a higher boiler effi-




Fig. 8. Velocity fields for Cases 1 through 6 [(a)-(f)]

ciency due to the decrease in dry gas losses, when compared to Cases 1 to 3. All cases exhibit adequate control of the main steam exit temperature by use of ATT1 and ATT2. The exit temperature of the reheaters, for all Cases, are determined to within the 20 [°C] tolerance for the intermediate turbine inlet conditions, as stipulated in the design C-schedules for the plant. However, with the lack of ATT-RH control, a sudden decrease in steam generation can lead to RH overheating and possible RH failure. Considering all of the above, Cases 3 and 6 are seen as the best firing arrangements for continuous low-load operation at a load of 32% MCR.

Table 6 shows the radiative heat percentage of the total heat input into each heat-exchanger for Cases 3 and 6. It can be seen that heat transfer to the furnace and radiant SHs are dominated by radiation, with approximately  $\pm 10\%$  being transferred via convection at low-load. Considering the convective pass heat exchangers (RH2 through to the EC, refer to Figure 3) the convective heat transfer becomes more apparent as seen with the reduction in radiative heat transfer percentage. Case 6 involves less convective heat transfer due to the SA flowrate for non-firing burners. This will reduce the total amount of flue-gas flowing through the boiler, thereby reducing the convective heat transfer.






Fig. 9. Heat fluxes profiles for Cases 1 through 6 [(a)-(f)]

## 5 Conclusions

The present study demonstrates the use of a coupled CFD/process model to study the effects of burner configuration at a boiler load of 32% MCR. A validation case was first performed for the CFD model, which showed adequate results for heat fluxes to the walls, with a general tendency of the model to under-predict the heat fluxes to the furnace. The model also showed sufficient accuracy in determining the combustion characteristics at the 100% MCR load.

The subsequent analysis results show that using a burner arrangement that raises the position of the flame core (Cases 2 and 5) increases the exit flue-gas temperature and runs the

risk of final SH failure due to overheating. This firing arrangement also results in a higher unburnt carbon percentage at the exit flue-gas stream and therefore the lowest boiler utilization efficiency.

Operation of the boiler using firing arrangements of Cases 1 and 4 also results in a lower boiler utilization efficiency and exit flue-gas temperature compared to Cases 3 and 6. Higher  $X_{CO}$  concentrations are observed near the bottom half of the furnace, along with high temperatures, which can lead to a high risk of fire side corrosion occurring at continuous low-load operation.

The mixed firing arrangements, of Cases 3 and 6, ex-




Fig. 10. CO molar fraction ( $X_{CO}$ ) concentrations for Cases 1 through 6 [(a)-(f)] on a temperature iso-surface of 1600 [K]

hibit the best boiler utilization efficiencies. Cases 3 and 6 display the best  $X_{CO}$  molar concentration distribution which highlights the minimal likelihood of inducing fire-side corrosion in the furnace when utilizing this firing configuration. A 4.8% decrease in unburnt carbon percentage is observed when operating using Case 3 in relation to Case 6. The predicted re-heater exit steam temperature of Case 3 is substantially closer to the desired temperature of 535 [°C], thus allowing for better control.

Based on analyses of combustion stability, boiler efficiency and the safe operation of heat exchanger components, Case 3 is considered to be the best operational strategy at this low load for the boiler under investigation.

#### Acknowledgements

The authors would like to thank the Eskom EPPEI program for financially supporting the present study and acknowledge the computational resources provided by the Centre for High Performance Computing (CHPC), South Africa.

#### References

- [1] Dugum, A., and Hanjalić, K., 2019. "Numerical simulation of coal-air mixture flow in a real double-swirl burner and implications on combustion anomalies in a utility boiler". *Energy*, **170**, pp. 942–953. doi:10.1016/j.energy.2018.12.121.
- [2] Eskom Power Generation, accessed June 18, 2020. <http://www.eskom.co.za/ElectricityGeneration.aspx>.




Fig. 11.  $CO_{PPM}$  [(a) and (b)] and  $X_{O_2}$  [(c) and (d)] line plots on symmetry and offset vertical probe lines

Table 6. Radiative heat transfer percentage for Cases 3 and 6

	Case 3	Case 6
Furnace [%]	89.2	88.9
Platen SH (SH2) [%]	92.5	93.4
Final SH (SH3) [%]	93.5	94.0
RH2 [%]	47.6	52.2
SH1 [%]	37.2	40.7
RH1 [%]	18.7	21.5
EC [%]	5.4	6.5

[3] Hernik, B., and Zabłocki, W., 2020. “Numeri-

- cal research of combustion with a minimum boiler load”. *Archives of Thermodynamics*, **41**(4), pp. 93–114. doi:10.24425/ather.2020.135855.
- [4] Chang, J., Wang, X., Zhou, Z., Chen, H., and Niu, Y., 2021. “CFD modeling of hydrodynamics, combustion and NOx emission in a tangentially fired pulverized-coal boiler at low load operating conditions”. *Advanced Powder Technology*, **32**(2), pp. 290–303. doi:10.1016/j.appt.2020.12.008.
- [5] Modliński, N., Szczepanek, K., Nabagło, D., Madejski, P., and Modliński, Z., 2019. “Mathematical procedure for predicting tube metal temperature in the second stage reheater of the operating flexibly steam boiler”. *Applied Thermal Engineering*, **146**(October 2018), pp. 854–865. doi:10.1016/j.applthermaleng.2018.10.063.
- [6] Laubscher, R., and Rousseau, P., 2019. “CFD

- study of pulverized coal-fired boiler evaporator and radiant superheaters at varying loads”. *Applied Thermal Engineering*, **160**. doi:10.1016/j.applthermaleng.2019.114057.
- [7] Laubscher, R., and Rousseau, P., 2019. “Numerical investigation into the effect of burner swirl direction on furnace and superheater heat absorption for a 620 MWe opposing wall-fired pulverized coal boiler”. *International Journal of Heat and Mass Transfer*, **137**, pp. 506–522. doi:10.1016/j.ijheatmasstransfer.2019.03.150.
- [8] Gu, J., Liu, Q., Zhong, W., and Yu, A., 2020. “Study on scale-up characteristics of oxy-fuel combustion in circulating fluidized bed boiler by 3D CFD simulation”. *Advanced Powder Technology*, **31**(5), pp. 2136–2151. doi:10.1016/j.appt.2020.03.007.
- [9] Du, Y., Wang, C., Lv, Q., Li, D., Liu, H., and Che, D., 2017. “CFD investigation on combustion and NO<sub>x</sub> emission characteristics in a 600 MW wall-fired boiler under high temperature and strong reducing atmosphere”. *Applied Thermal Engineering*, **126**(x), pp. 407–418. doi:10.1016/j.applthermaleng.2017.07.147.
- [10] Fan, J., Qian, L., Ma, Y., Sun, P., and Cen, K., 2001. “Computational modeling of pulverized coal combustion processes in tangentially fired furnaces”. *Chemical Engineering Journal*, **81**(1-3), pp. 261–269. doi:10.1016/S1385-8947(00)00212-6.
- [11] Chen, S., He, B., He, D., Cao, Y., Ding, G., Liu, X., Duan, Z., Zhang, X., Song, J., and Li, X., 2017. “Numerical investigations on different tangential arrangements of burners for a 600 MW utility boiler”. *Energy*, **122**(x), pp. 287–300. doi:10.1016/j.energy.2017.01.093.
- [12] He, B., Zhu, L., Wang, J., Liu, S., Liu, B., Cui, Y., Wang, L., and Wei, G., 2007. “Computational fluid dynamics based retrofits to reheater panel overheating of No. 3 boiler of Dagang Power Plant”. *Computers and Fluids*, **36**(2), pp. 435–444. doi:10.1016/j.compfluid.2005.09.005.
- [13] Jiang, Y., Lee, B.-H., Oh, D.-H., and Jeon, C.-H., 2021. “Optimization of operating conditions to achieve combustion stability and reduce NO<sub>x</sub> emission at half-load for a 550-MW tangentially fired pulverized coal boiler”. *Fuel*, **306**(February), p. 121727. doi:10.1016/j.fuel.2021.121727.
- [14] Belošević, S., Tomanović, I., Crnomarković, N., and Milićević, A., 2019. “Full-scale CFD investigation of gas-particle flow, interactions and combustion in tangentially fired pulverized coal furnace”. *Energy*, **179**. doi:10.1016/j.energy.2019.05.066.
- [15] Alobaid, F., Mertens, N., Starkloff, R., Lanz, T., Heinze, C., and Eppel, B., 2017. “Progress in dynamic simulation of thermal power plants”. *Progress in Energy and Combustion Science*, **59**, pp. 79–162. doi:10.1016/j.pecs.2016.11.001.
- [16] Laubscher, R., and Rousseau, P., 2020. “Numerical investigation on the impact of variable particle radiation properties on the heat transfer in high ash pulverized coal boiler through co-simulation”. *Energy*, **195**, p. 117006. doi:10.1016/j.energy.2020.117006.
- [17] Yu, C., Xiong, W., Ma, H., Zhou, J., Si, F., Jiang, X., and Fang, X., 2019. “Numerical investigation of combustion optimization in a tangential firing boiler considering steam tube overheating”. *Applied Thermal Engineering*, **154**(2), pp. 87–101. doi:10.1016/j.applthermaleng.2019.03.074.
- [18] Ranade, V., and Gupta, D., 2015. *Computational modeling of pulverized coal fired boilers*, 1 ed. Taylor & Francis, Boca Raton.
- [19] Sheng, C., Moghtaderi, B., Gupta, R., and Wall, T. F., 2004. “A computational fluid dynamics based study of the combustion characteristics of coal blends in pulverised coal-fired furnace”. *Fuel*, **83**(11-12), pp. 1543–1552. doi:10.1016/j.fuel.2004.02.011.
- [20] Baum, M., and Street, P., 1971. “Predicting the combustion behaviour of coal particles”. *Combustion science and Technology*, **3**(43), p. 231.
- [21] Knaus, H., Schnell, U., and Klaus, R., 2001. “On the modelling of coal combustion in a 550MWe coal fired utility boiler”. *Progress in Computational Fluid Dynamics*, **1**, pp. 194–207.
- [22] Benim, A. C., Eppel, B., and Krohmer, B., 2005. “Modelling of pulverised coal combustion by a Eulerian-Eulerian two-phase flow formulation”. *Progress in Computational Fluid Dynamics*, **5**(6), pp. 345–361. doi:10.1504/PCFD.2005.007067.
- [23] Versteeg, H., and Malalasekera, W., 2007. *Introduction to Computational Fluid Dynamics, The finite volume method*, second ed. Pearson Prentice Hall. doi:10.1002/9781119369189.
- [24] Vicente, W., Ochoa, S., Aguilón, J., and Barrios, E., 2003. “An Eulerian model for the simulation of an entrained flow coal gasifier”. *Applied Thermal Engineering*, **23**(15), pp. 1993–2008. doi:10.1016/S1359-4311(03)00149-2.
- [25] Cai, J., Handa, M., and Modest, M. F., 2015. “Eulerian-Eulerian multi-fluid methods for pulverized coal flames with nongray radiation”. *Combustion and Flame*, **162**(4), pp. 1550–1565. doi:10.1016/j.combustflame.2014.11.023.
- [26] Basu, P., Kefa, C., and Jestin, L., 2000. *Boilers and burners: Design and theory*, 1 ed. Springer, New York.
- [27] Modest, M. F., 2013. *Radiative Heat Transfer*, third ed. Academic Press, Kidlington, Oxford, U.K. doi:10.1016/j.neuroscience.2014.03.010.
- [28] Smith, T., Shen, Z., and Friedman, J., 1982. “Evaluation of Coefficients for the Weighted Sum of Gray Gases Model”. *ASME Journal of Heat transfer*, **104**, pp. 602–608.
- [29] Lockwood, F., Rizvi, S., and Shah, N., 1986. “Comparative predictive experience of coal firing”. *Proceedings of the Institution of Mechanical Engineers*, **200**, pp. 79–87. doi:10.1243/PIME.
- [30] Yin, C., 2015. “On gas and particle radiation in pulver-



- ized fuel combustion furnaces”. *Applied Energy*, **157**, pp. 554–561. doi:10.1016/j.apenergy.2015.01.142.
- [31] Gnielinski, V., 2016. “Heat transfer in cross-flow around single rows of tubes and through tube bundles”. In *VDI Heat Atlas*. Springer-Verlag, Berlin, pp. 756–760.
- [32] Laubscher, R., and Rousseau, P., 2020. “Coupled simulation and validation of a utility-scale pulverized coal-fired boiler radiant final-stage superheater”. *Thermal Science and Engineering Progress*, **18**(August 2019), p. 100512. doi:10.1016/j.tsep.2020.100512.