



AUSTRALIAN
**GLASS &
WINDOW**
ASSOCIATION

2026 WINDOW COMPLIANCE CERTIFICATE - HOUSING

Housing is defined as a Class 1 or 10 building as defined by the National Construction Code (NCC) within the geometric limitations specified in AS 4055.

Accredited Company/Membership No.: Logikhaus Pty Ltd AGWA #32561

Is a participating member of the AGWA Accreditation Program, is committed to the Industry Code of Conduct and has met the requirements of the annual AGWA Compliance Audit.

Client Name:

Site Address:

Delivered on:

The windows and doors have been manufactured to comply with the Australian Window Standard AS 2047:2014 and Glass Standard AS 1288:

☐ 2006 ☒ 2021 (including human impact requirements) and National Construction Code energy efficiency, bushfire and fall prevention requirements as specified by the purchaser.

Wind Loads N Ratings						
Window Rating (AS 4055)	Serviceability Limit State (SLS) Pa		Ultimate Limit State (ULS) Pa		Water Penetration Resistance State (WPR) Pa	
	General	Corner	General	Corner	Non-Exposed	Exposed
☐ N1	400	600	600	900	150	200
☐ N2	400	600	900	1300	150	200
☐ N3	600	800	1400	2000	150	200
☐ N4	800	1200	2000	3000	200	300
☐ N5	1200	1800	3000	4500	300	450
☐ N6	1600	2500	4000	6000	450	600

Energy Performance Ratings, AFRC Results:	
U Value, U_w	1.6
Solar Heat Gain Co-efficient, SHGC _w	0.31
☐ Refer to attached schedule	
Basix/NatHERS Certificate Number:	

Bushfire:	
☐ BAL LOW (Not Applicable)	☒ Tested (AS 1530.8.1)
☐ BAL 12.5	☐ Prescriptive (AS 3959)
☐ BAL 19	
☐ BAL 29	
☐ BAL 40	
☐ BAL FZ	

Wind Loads C Ratings						
Window Rating (AS 4055)	Serviceability Limit State (SLS) Pa		Ultimate Limit State (ULS) Pa		Water Penetration Resistance State (WPR) Pa	
	General	Corner	General	Corner	Non-Exposed	Exposed
☐ C1	600	800	1800	2700	150	300
☐ C2	800	1200	2700	4000	200	300
☐ C3	1200	1800	4000	5900	300	450
☐ C4	1600	2500	5300	8000	400	600

Corner Windows Item Numbers:

Fall Prevention:	
☒ Windows Restricted to max 125mm	
☐ Fall Prevention Screens	
☐ Not Required	
☐ By Others	
Item Number:	

Acoustics
Acoustic Rating (Rw):

Notes:

Signed:

(Builder/Installer)

Date:

The builder/installer certifies that the windows and doors supplied have been installed correctly in accordance with the requirements of the National Construction Code and the human impact glass located in the correct openings.

Signed:

(Company supplying the Windows and Doors)

Date: 2 Jun 2026