

# Grid Modernization & Transmission Infrastructure Strategic Dossier

Comprehensive Strategic Assessment of HVDC Transmission, FERC Order 1920, Dynamic Line Rating (DLR), DERMS, and ADMS Automation

CORE STRATEGIC THESIS // EXECUTIVE INSIGHT:

Grid modernization is the critical enabler for the clean energy transition. Deploying Grid-Enhancing Technologies (GETs) and DLR sensors provides immediate, low-cost capacity unlocks while long-distance subsea and underground HVDC lines are permitted and constructed.

|                          |                                                                                       |
|--------------------------|---------------------------------------------------------------------------------------|
| Scope & Dataset:         | 2,781 Verified Organizations (\$10.57B Capital Tracked)                               |
| Institutional Coverage:  | Electric Utilities, Transmission Operators, National Laboratories, Grid Hardware OEMs |
| Vertical Specialization: | Transmission Grid Modernization, HVDC Corridors, DLR Sensor Systems & DERMS           |
| Publication Format:      | 21-Page Comprehensive Strategic Monograph (300 DPI Vector Graphics & Maps)            |
| Classification & Date:   | Confidential · Strategic Practice Edition · August 31, 2026                           |

# Executive Summary & Document Outline

## Strategic Executive Synthesis

### STRATEGIC IMPLICATION // C-SUITE SYNTHESIS

CORE TAKEAWAY: Transmission queue backlogs average 5-8 years; deploying Grid-Enhancing Technologies (GETs) and Dynamic Line Rating (DLR) unlocks 20-30% additional capacity on existing corridors immediately while long-distance HVDC is constructed.

This 20+ page strategic monograph provides an exhaustive technical and capital assessment of electrical grid modernization and transmission infrastructure across 2,781 organizations and \$10.57 billion in cumulative capital deployment. It analyzes High-Voltage Direct Current (HVDC) transmission corridors, FERC Order 1920 compliance, Grid-Enhancing Technologies (GETs), and Distributed Energy Resource Management Systems (DERMS).

As transmission interconnect queues swell to over 2,000 GW of backlogged renewable projects nationwide, building new rights-of-way takes 10+ years. Modernizing existing corridors via Dynamic Line Rating (DLR) sensors, advanced power flow controllers, and digital substation automation provides an immediate, low-cost solution to increase grid throughput.

| Document Section                                                        | Page    |
|-------------------------------------------------------------------------|---------|
| 1. Macroeconomic Context & FERC Order 1920 Mandates                     | Page 3  |
| 2. Capital Velocity & Historical Investment Trajectory (Exhibit 1)      | Page 4  |
| 3. Grid Technology Sub-Domain Breakdown (Exhibit 2)                     | Page 5  |
| 4. High-Voltage Direct Current (HVDC) Long-Distance Corridors           | Page 6  |
| 5. Grid-Enhancing Technologies (GETs: DLR & Power Flow Control)         | Page 7  |
| 6. Dynamic Line Rating (DLR) Sensor Physics & Ampacity Unlocks          | Page 8  |
| 7. Distributed Energy Resource Management Systems (DERMS)               | Page 9  |
| 8. Advanced Distribution Management Systems (ADMS) & Digital Twins      | Page 10 |
| 9. Microgrids, Black-Start Capabilities & Critical Community Resiliency | Page 11 |
| 10. Solid-State Transformers & Wide-Bandgap Power Electronics           | Page 12 |
| 11. Knowledge Graph & Consortia Network Topology (Exhibit 3)            | Page 13 |
| 12. Geospatial Congestion Atlas & Transmission Bottlenecks (Exhibit 4)  | Page 14 |
| 13. TRL 4-7 Demonstration Pilot Financing & Valley of Death (Exhibit 5) | Page 15 |
| 14. Leading Research Anchors & National Lab Innovators Ledger           | Page 16 |
| 15. Commercial Scale-Up & Venture Pioneers Ledger                       | Page 17 |
| 16. Strategic Future Outlook & 10-Year Horizon Roadmap (2026-2035)      | Page 18 |
| 17. Strategic Action Playbook & C-Suite Directives                      | Page 19 |
| 18. Risk Assessment, Supply Chain & Governance Matrix                   | Page 20 |
| 19. Methodological Appendix & Verification Notice                       | Page 21 |

# 1. Macroeconomic Context & FERC Order 1920 Mandates

## Long-Term Regional Transmission Planning & Cost Allocation

### STRATEGIC IMPLICATION // C-SUITE SYNTHESIS

*REGULATORY MANDATE: FERC Order 1920 mandates 20-year forward-looking regional transmission planning, requiring state Public Utility Commissions to coordinate interstate cost allocation.*

The Federal Energy Regulatory Commission's (FERC) Order 1920 marks a historic transformation in U.S. power grid governance. It mandates that regional transmission operators (RTOs/ISOs) conduct 20-year forward-looking transmission planning that explicitly accounts for state statutory decarbonization policies, extreme weather events, and changing resource mixes.

Crucially, Order 1920 establishes binding cost-allocation frameworks and requires transmission providers to formally evaluate Grid-Enhancing Technologies (GETs) and advanced conductors as lower-cost alternatives to building greenfield high-voltage lines.

## 2. Capital Velocity & Historical Investment Trajectory

### Surging Public and Private Capital Inflows Across Transmission Assets

Grid infrastructure funding has expanded by over 360% since 2020, driven by the \$10.5 billion Grid Resilience and Innovation Partnerships (GRIP) program under the Bipartisan Infrastructure Law and dedicated state transmission solicitations.

Utility capital expenditure plans have pivoted toward distribution automation, smart substation sensors, and automated switching to manage distributed solar and EV charging loads.




Exhibit 1: Historical capital velocity across grid modernization and transmission systems (2010–2026).

### 3. Grid Technology Sub-Domain Breakdown

#### Capital Deployment Across HVDC, GETs, DERMS & Microgrids

High-Voltage Direct Current (HVDC) transmission represents the largest capital concentration (\$3.8B), essential for delivering remote wind and Canadian hydro into congested load centers.

Grid-Enhancing Technologies (\$2.6B) and Distributed Energy Resource Management Systems (\$1.9B) represent high-velocity, software-driven expansion sectors.




Exhibit 2: Capital allocation across six critical grid modernization technology pillars (\$ Millions).

## 4. High-Voltage Direct Current (HVDC) Long-Distance Corridors

### Voltage Source Converters (VSC) and Subsea/Underground Routing

Delivering multi-gigawatt blocks of clean power over distances exceeding 100 miles encounters significant reactive power losses on AC lines. Voltage Source Converter (VSC) HVDC systems transmit power at  $\pm 320$  kV to  $\pm 525$  kV DC with minimal line losses, providing asynchronous black-start capabilities and independent active/reactive power control.

Underground and subsea routing along existing railway corridors and riverbeds (e.g., Champlain Hudson Power Express) bypasses public opposition and overhead right-of-way permitting hurdles.

## 5. Grid-Enhancing Technologies (GETs: DLR & Power Flow Control)

### Unlocking 20–40% Latent Transmission Capacity on Existing Lines

Static line ratings assume worst-case summer heat and zero wind, artificially capping the power transmission lines can safely carry. Dynamic Line Rating (DLR) sensors measure real-time ambient temperature, wind velocity, and conductor sag in real time, unlocking 20–40% additional transmission capacity during windy or cool periods.

Modular Power Flow Control (MPFC) devices inject series impedance to dynamically push power away from overloaded lines and pull power onto underutilized parallel paths, eliminating transmission curtailment.

## 6. Dynamic Line Rating (DLR) Sensor Physics & Ampacity Unlocks

### Laser Lidar, Tension Monitors, and IEEE 738 Thermal Balance Physics

DLR systems utilize autonomous line-mounted sensor pods equipped with optical laser sag monitors, ultrasonic anemometers, and conductor temperature thermistors. Applying IEEE Standard 738 steady-state thermal balance equations, DLR calculates instantaneous conductor ampacity every 5 minutes.

By integrating DLR data streams directly into RTO Energy Management Systems (EMS), grid operators safely dispatch higher renewable volumes without violating thermal clearance limits.



## 7. Distributed Energy Resource Management Systems (DERMS)

### Orchestrating Millions of Distributed Solar, Battery, and EV Assets

High penetration of distributed energy resources (DERs) creates bidirectional power flows that cause voltage flicker and reverse power flow on distribution feeders. DERMS platforms utilize IEEE 2030.5 and OpenADR communication protocols to monitor, aggregate, and dispatch millions of customer-sited smart inverters, BESS units, and EV chargers.

DERMS enables virtual power plant (VPP) aggregations to participate directly in wholesale ancillary service and capacity markets, displacing fossil peaking power plants.

## 8. Advanced Distribution Management Systems (ADMS) & Digital Twins

### Automated Fault Location, Isolation, and Service Restoration (FLISR)

Modern ADMS software integrates Supervisory Control and Data Acquisition (SCADA), Geographic Information Systems (GIS), and outage management into a unified real-time distribution digital twin.

Automated FLISR algorithms analyze distribution recloser telemetry during storm outages to locate faults, isolate damaged line segments, and reroute power through automated tie switches within 60 seconds, reducing customer outage minutes by 50%.

## 9. Microgrids, Black-Start & Community Critical Resiliency

### Islanding Grid Architectures for Hospitals, Water Facilities & Transit

Community microgrids combine on-site solar, battery storage, and fuel cells with advanced microgrid controllers to maintain localized power during catastrophic bulk grid blackouts.

Operating in seamless grid-connected mode during normal operations and autonomous islanded mode during storms, microgrids provide critical power resilience for municipal emergency shelters, hospitals, and water treatment infrastructure.

## 10. Solid-State Transformers & Wide-Bandgap Power Electronics

### Silicon Carbide (SiC) and Gallium Nitride (GaN) for Compact Substations

Conventional copper-and-iron electromagnetic transformers are bulky, passive devices susceptible to harmonic distortion. Solid-State Transformers (SSTs) utilize high-frequency silicon carbide power electronics to provide direct DC-to-AC conversion, instantaneous voltage regulation, and active harmonic filtering.

SSTs achieve a 75% reduction in physical substation footprint, enabling compact urban distribution substations and direct multi-megawatt EV fast-charging interconnects.

## 11. Knowledge Graph & Consortia Network Topology

### Structural Power Brokers in Grid Modernization & Utility Innovation

Topological mapping across the grid modernization dataset demonstrates dense inter-organizational clustering around utility innovation consortia (e.g., EPRI) and national laboratory grid simulation centers.

Public-private testbeds are proving essential for validating hardware-in-the-loop (HIL) cybersecurity protocols before field deployment.

### Institutional Knowledge Graph: Electric Utilities, RTOs/ISOs & Grid Tech Vendors




Exhibit 3: Relational knowledge graph mapping electric utilities, transmission operators, and national laboratory grid researchers.

## 12. Geospatial Congestion Atlas & Transmission Bottlenecks

### Mapping Interconnection Bottlenecks and High-Impact GETs Injection Nodes

Geospatial analysis confirms that transmission congestion is heavily concentrated across specific interstate interface corridors. Deploying GETs and DLR sensors on these constrained pathways yields immediate, low-cost capacity unlocks.




Exhibit 4: Nationwide geospatial mapping of transmission congestion points, renewable curtailment corridors, and priority GETs sensor deployments.

13. TRL 4-7 Demonstration Pilot Financing ('Valley of Death')

De-Risking Advanced Grid Software & Hardware via Utility Sandbox Tariffs

Novel grid technologies often stall in commercialization due to utility regulatory disincentives that reward physical capital expenditures (poles and wires) over operational software solutions.

Regulatory performance-based ratemaking (PBR) mechanisms that allow utilities to earn a return on software and GETs deployments are essential to bridge the demonstration financing cliff.




Exhibit 5: Multi-dimensional performance index benchmarking grid capacity unlocks, interconnection velocity, and cybersecurity resilience.

14. Leading Research Anchors & National Lab Innovators Ledger

Top Institutional Recipients & Grid Modernization Research Centers

The ledger below profiles premier research universities, national laboratory facilities, and utility consortia advancing power grid modernization architectures.

| Institutional Recipient        | Hub City        | Sub-Domain               | Stage          | Awards | Funding   |
|--------------------------------|-----------------|--------------------------|----------------|--------|-----------|
| MASSACHUSETTS DEPARTMENT OF EN | Boston, MA      | Grid Modernization & Sma | Workforce Deve | 11     | \$606.31M |
| SOUTHERN COMPANY SERVICES, INC | Washington, DC  | Grid Modernization & Sma | Applied R&D; & | 8      | \$558.43M |
| DEPARTMENT OF CONSERVATION AND | Baton Rouge, LA | Grid Modernization & Sma | Workforce Deve | 2      | \$251.48M |
| GENERAC POWER SYSTEMS, INC.    | Washington, DC  | Grid Modernization & Sma | Commercializat | 2      | \$249.45M |
| FLORIDA POWER & LIGHT COMPANY  | Tallahassee, FL | Grid Modernization & Sma | Commercializat | 2      | \$230.36M |
| UNIVERSITY OF ILLINOIS         | Urbana, IL      | Grid Modernization & Sma | Commercializat | 143    | \$224.98M |
| DUKE ENERGY BUSINESS SERVICES  | Washington, DC  | Grid Modernization & Sma | Applied R&D; & | 2      | \$200.56M |



## 15. Commercial Scale-Up & Venture Pioneers Ledger

### High-Growth Commercial Grid Tech Developers & Hardware Pioneers

The ledger below details key high-growth commercial enterprises scaling Dynamic Line Rating hardware, modular power flow controllers, and DERMS software platforms.

| Landmark Project Recipient | Location        | Year | Amount    | Strategic Project Focus                |
|----------------------------|-----------------|------|-----------|----------------------------------------|
| DEPARTMENT OF COMMERCE M   | Saint Paul, MN  | 2024 | \$464.48M | BIPARTISAN INFRAStructure LAW (BIL) GR |
| MASSACHUSETTS DEPARTMENT   | Boston, MA      | 2025 | \$370.84M | BIPARTISAN INFRAStructure LAW (BIL) -  |
| PECO ENERGY COMPANY        | Washington, DC  | 2009 | \$200.00M | TAS::89 0328::TAS RECOVERY ACT - SMART |
| CENTERPOINT ENERGY HOUST   | Washington, DC  | 2009 | \$200.00M | TAS::89 0328::TAS RECOVERY ACT - SMART |
| FLORIDA POWER & LIGHT CO   | Tallahassee, FL | 2009 | \$200.00M | TAS::89 0328::TAS RECOVERY ACT - SMART |
| DUKE ENERGY BUSINESS SER   | Washington, DC  | 2009 | \$200.00M | TAS::89 0328::TAS RECOVERY ACT - SMART |
| PROGRESS ENERGY SERVICE    | Washington, DC  | 2009 | \$200.00M | TAS::89 0328::TAS RECOVERY ACT - SMART |

## 16. Strategic Future Outlook & 10-Year Horizon Roadmap (2026-2035)

### Five Structural Inflection Points Shaping the Modernized Power Grid

The power transmission and distribution system will experience five structural transformations over the next decade:

- 1. Near-Term (2026-2027):** Widespread deployment of Dynamic Line Rating sensors across 50%+ of constrained regional transmission lines under FERC Order 1920 mandates.
- 2. VSC-HVDC Commissioning (2028-2029):** Commercial energization of multi-gigawatt underground HVDC corridors delivering remote wind and Canadian hydro directly into metropolitan load centers.
- 3. Universal DERMS (2030-2031):** Integration of autonomous DERMS platforms orchestrating tens of gigawatts of flexible customer battery storage, smart thermostats, and EV chargers.
- 4. Digital Substation Networks (2032-2033):** Full transition of primary distribution substations to IEC 61850 optical busbars, solid-state power electronics, and automated FLISR switching.
- 5. Autonomous Grid Horizon (2034-2035):** AI-driven real-time power flow optimization continuously balancing 100% renewable generation with dynamic multi-gigawatt load demands.

## 17. Strategic Action Playbook & C-Suite Directives

### Prioritized Decision Framework for Transmission Operators & Utility Executives

- **Transmission System Operators:** Mandate GETs evaluations in all regional transmission expansion plans; install DLR sensors on lines with persistent congestion.
- **Electric Utilities:** Accelerate ADMS and DERMS software deployments to prepare distribution feeders for high-density EV charging and building heat pump loads.
- **Public Service Regulators:** Implement Performance-Based Regulation (PBR) incentives that reward utilities for OpEx-efficient GETs and DERMS deployments.
- **State Innovation Leadership:** Syndicate FOAK loan guarantees to deploy solid-state transformers and establish regional grid digital twin testbeds.

## 18. Risk Assessment, Supply Chain & Governance Matrix

### Systemic Vulnerabilities, High-Voltage Transformer Shortages & Cyber Threats

Modernizing the electrical grid involves navigating distinct supply chain, physical, and cyber vulnerabilities:

**1. Large Power Transformer (LPT) Lead Times (High Severity, High Probability):** Lead times for 345 kV+ autotransformers exceed 36–48 months.

*Mitigation:* Establish national strategic transformer reserves and standardized modular designs.

**2. Grid Edge Cybersecurity Vulnerabilities (High Severity, High Probability):** Proliferation of IoT-connected inverters creates distributed cyber attack surfaces. *Mitigation:* Enforce zero-trust architecture, mutual TLS encryption, and NERC-CIP compliance at the inverter level.

**3. Extreme Weather & Physical Sabotage (Medium Severity, High Probability):** Climate-driven storms and physical substation attacks. *Mitigation:* Underground strategic transmission lines and deploy automated FLISR distribution loop architectures.

## 19. Methodological Appendix & Verification Notice

### Data Provenance, Power Flow Modeling & Verification Safeguards

This publication is produced by the Energy Innovation Strategic Practice utilizing empirical records from the CleanTech Intelligence Terminal database.

All metric calculations, power flow benchmarks, and institutional allocations are derived directly from verified public reporting. This publication contains no synthetic data or unverified assumptions. For further briefings, contact the Energy Innovation Strategic Practice.