

5 4 3 2 1

9 8 7 6

SERIAL PORT 4

EN	PF	86BFT	86RS	TRIP	BREAKER		
					CLOSE	52A	MOD
FAULT	LOAD	UBAL	FLASH	THERM	A	B	C
BREAKER FAILURE MODE				FAILED POLE			

TARGET RESET	METER	EVENTS	STATUS	OTHER	SET	CNTRL	GROUP
LAMP TEST	CANCEL	SELECT	◀	▶	▲	▼	EXIT

SEL-352

BREAKER FAILURE RELAY

CLOSING CONTROL RELAY

DATA RECORDER

SELogiC™ CONTROL EQUATIONS

EN

Relay Enabled

PF

Pending Breaker Failure

86BFT

Lockout Relay Trip

86RS

Lockout Relay Reset

TRIP

Trip Received

CLOSE

Close Received

52A

Breaker Closed

MOD

MOD Closed

FAULT

Fault Clearance Failure

LOAD

Load Clearance Failure

UBAL

Pole Discordance

FLASH

Breaker Flashover

THERM

Thermal Overload

A

Phase A Failed

B

Phase B Failed

C

Phase C Failed

SEL

SCHWEITZER ENGINEERING LABORATORIES

PULLMAN WASHINGTON USA

⚠

W A R N I N G

REMOVAL OF THIS PANEL EXPOSES CIRCUITRY WHICH MAY CAUSE ELECTRICAL SHOCK THAT CAN RESULT IN INJURY OR DEATH

U.S. Patents 5,041,737 5,157,575 5,317,472

Other Patents Pending

196-0201