

Uspesno preprečen požar pri pregrevanju in požaru na kablilnih kotlovnici v objektu delovne enote klavnice.





Kmečka zadruga Sevnica z.o.o., 8290 Sevnica, Savska cesta 20c

tel.n.c. 07 81 63 600, direktor 07 81 63 620, fax 07 81 63 617

št. vp. v SRG 2/23-00 pri Okrož. sod. Krško, MŠ 5106079, DŠ 16125177, ID. št. za DDV: SI16125177

TRR pri BK 10100-0028110013 ali TRR pri NLB 02379-0017284454

**Podjetje / Company:** Kmečka zadruga Sevnica z.o.o.

**Objekt / Building:** Objekt na Cesti na Grad 14, 8290 SEVNICA

Building on Cesta na Grad 14, 8290 SEVNICA

## **REFERENCA O USPEŠNEM DELOVANJU GASILNE AMPULE BONPET**

## **REFERENCE ABOUT SUCCESSFUL FIRE EXTINGUISHING WITH AMPOULE BONPET**

**Opis dogodka:** pregrevanje kotlovnice v objektu delovne enote klavnice; dne, 18. 5. 2007

**The event:** overheating of boiler room in a building of working slaughterhouse, on 18. 5. 2007

### **OPIS DELOVANJA:**

Gasilna ampula Bonpet je bila nameščena na steni kotlovnice, kjer je prišlo do pregrevanja v kotlu za toplo vodo. Prišlo je do znatnega pregrevanja v prostoru in do topljenja v samem kotlu, kar je povzročilo aktivacijo ampule Bonpet, ki je znatno ohladila kotel ter s tem preprečila požar na oljnem gorilcu, kar je razvidno iz priložene fotografije.

Gasilna ampula Bonpet je uspešno opravila svoje delo in s tem preprečila večjo gospodarsko škodo na celotnem objektu.

### **DESCRIPTION OF THE OPERATION:**

Automatic fire extinguisher ampoula Bonpet was installed on the wall of the boiler room where came to overheating in the boiler for warm water. It came to considerable overheating in that place and to melting in the boiler which caused activation of the ampoule Bonpet. Ampoule Bonpet cooled the boiler significantly off and made fire impossible to spread on to the oil burner what is visible from the attached photography.

Ampoule Bonpet has successfully done its work and made larger economic loss on entire building impossible.

Priloga / Enclosed:

- fotografija / photo

**Referenco potrjuje / Confirmed by:**

Joško KOVAČ, univ. dipl. inž.  
direktor



Kmečka zadruga  
Sevnica z.o.o.  
8290 Sevnica  
Savska cesta 20c 1

Sevnica, 29.5.2007