



Job	Truss	Truss Type	Qty	Ply	LOVING SHOP ADDITION
1700059	A01	FINK	11	1	Job Reference (optional)

Western Truss, Flagstaff, AZ

8.020 s Sep 13 2016 MiTek Industries, Inc. Thu May 25 08:57:54 2017 Page 1
ID:Ktpkz7K01b9eIM?VXL?UAyzuVae-0Fxb0_eMoQ?Bjk65freTFxqdWqPkesIEy4vV_fzD_3x



Scale = 1:47.2



9-5-4	15-10-12	25-4-0
9-5-4	6-5-8	9-5-4

Plate Offsets (X,Y)-- [2:0-1-10,Edge], [6:0-1-10,Edge], [8:0-4-0,0-3-0]

LOADING (psf)	SPACING-	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 40.0	2-0-0	TC 0.35	Vert(LL)	-0.15 2-9	>999	240	MT20	169/123
(Roof Snow=40.0)	Plate Grip DOL 1.15	BC 0.59	Vert(TL)	-0.40 2-9	>751	180		
TCDL 10.0	Lumber DOL 1.15	WB 0.62	Horz(TL)	0.10 6	n/a	n/a		
BCLL 0.0 *	Rep Stress Incr YES	Matrix-SH						
BCDL 10.0	Code IRC2012/TPI2007						Weight: 106 lb	FT = 20%

LUMBER-

TOP CHORD 2x6 SPF 1650F 1.5E
BOT CHORD 2x4 SPF 1650F 1.5E
WEBS 2x4 WW Stud/Std

BRACING-

TOP CHORD
BOT CHORD

Structural wood sheathing directly applied or 5-1-5 oc purlins.
Rigid ceiling directly applied or 9-3-9 oc bracing.

MiTek recommends that Stabilizers and required cross bracing be installed during truss erection, in accordance with Stabilizer Installation guide.

REACTIONS. (lb/size) 2=1724/0-5-8 (min. 0-2-11), 6=1724/0-5-8 (min. 0-2-11)

Max Horz 2=-115(LC 15)
Max Uplift 2=-390(LC 10), 6=-390(LC 11)
Max Grav 2=1729(LC 17), 6=1729(LC 18)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

TOP CHORD 2-3=-2886/643, 3-4=-2322/518, 4-5=-2322/518, 5-6=-2886/644
BOT CHORD 2-9=-584/2534, 8-9=-244/1707, 6-8=-470/2534
WEBS 3-9=-775/342, 4-9=-149/750, 4-8=-149/750, 5-8=-775/343

NOTES-

- Wind: ASCE 7-10; Vult=115mph (3-second gust) V(IRC2012)=91mph; TCDL=6.0psf; BCDL=6.0psf; h=33ft; Cat. II; Exp C; partially; MWFRS (envelope) gable end zone; cantilever left and right exposed; end vertical left and right exposed; Lumber DOL=1.33 plate grip DOL=1.33
- TCLL: ASCE 7-10; Pf=40.0 psf (flat roof snow); Category II; Exp C; Fully Exp.; Ct=1.1
- Unbalanced snow loads have been considered for this design.
- This truss has been designed for greater of min roof live load of 16.0 psf or 1.00 times flat roof load of 40.0 psf on overhangs non-concurrent with other live loads.
- This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- * This truss has been designed for a live load of 40.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
- Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) except (jt=lb) 2=390, 6=390.
- This truss is designed in accordance with the 2012 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.

LOAD CASE(S) Standard

Job	Truss	Truss Type	Qty	Ply	LOVING SHOP ADDITION
1700059	A02	GABLE	1	1	Job Reference (optional)

Western Truss, Flagstaff, AZ

8.020 s Sep 13 2016 MiTek Industries, Inc. Thu May 25 08:57:55 2017 Page 1

ID:Ktpkz7K01b9eIM?VXL?UAYzuVae-URV3EKf_Zk72LuhHCY9io9NrdDtINRqNAke2W5zD_3w





Plate Offsets (X,Y)-- [2:0-2-0,0-1-6], [10:0-3-0,Edge], [18:0-2-0,0-1-6], [24:0-2-8,0-3-0]																			
LOADING (psf)		SPACING-		2-0-0		CSI.		DEFL.		in (loc)		l/defl		L/d		PLATES		GRIP	
TCLL	40.0	Plate Grip DOL	1.15	TC	0.13	Vert(LL)	0.01	19	n/r	120	MT20	169/123							
(Roof Snow=40.0)		Lumber DOL	1.15	BC	0.10	Vert(TL)	0.01	19	n/r	120									
TCDL	10.0	Rep Stress Incr	YES	WB	0.12	Horz(TL)	0.00	18	n/a	n/a									
BCLL	0.0 *	Code IRC2012/TPI2007		Matrix-SH															
BCDL	10.0																		
												Weight: 129 lb		FT = 20%					

LUMBER-			BRACING-	
TOP CHORD	2x6	SPF 1650F 1.5E	TOP CHORD	Structural wood sheathing directly applied or 6-0-0 oc purlins. Rigid ceiling directly applied or 10-0-0 oc bracing.
BOT CHORD	2x4	SPF 1650F 1.5E	BOT CHORD	
OTHERS	2x4	WW Stud/Std		
<div>MiTek recommends that Stabilizers and required cross bracing be installed during truss erection, in accordance with Stabilizer Installation guide.</div>				

REACTIONS. All bearings 25-4-0.

(lb) - Max Horz 2=-115(LC 15)

Max Uplift All uplift 100 lb or less at joint(s) 32, 31, 30, 29, 28, 25, 24, 23, 22, 21 except 2=-114(LC 6), 18=-121(LC 7), 33=-129(LC 10), 20=-127(LC 11)

Max Grav All reactions 250 lb or less at joint(s) 32, 31, 30, 29, 28, 25, 24, 23, 22, 21 except 2=495(LC 1), 18=495(LC 1), 27=282(LC 3), 26=282(LC 4), 33=348(LC 1), 20=348(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

WEBS 3-33=-285/168, 17-20=-285/166

- NOTES-**
- Wind: ASCE 7-10; Vult=115mph (3-second gust) V(IRC2012)=91mph; TCDL=6.0psf; BCDL=6.0psf; h=33ft; Cat. II; Exp C; partially; MWFRS (envelope) gable end zone; cantilever left and right exposed ; end vertical left and right exposed; Lumber DOL=1.33 plate grip DOL=1.33
 - Truss designed for wind loads in the plane of the truss only. For studs exposed to wind (normal to the face), see Standard Industry Gable End Details as applicable, or consult qualified building designer as per ANSI/TPI 1.
 - TCLL: ASCE 7-10; Pf=40.0 psf (flat roof snow); Category II; Exp C; Fully Exp.; Ct=1.1
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for greater of min roof live load of 16.0 psf or 1.00 times flat roof load of 40.0 psf on overhangs non-concurrent with other live loads.
 - All plates are 2x4 MT20 unless otherwise indicated.
 - Gable requires continuous bottom chord bearing.
 - Gable studs spaced at 1-4-0 oc.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 40.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 32, 31, 30, 29, 28, 25 , 24, 23, 22, 21 except (jt=lb) 2=-114, 18=121, 33=129, 20=127.
 - This truss is designed in accordance with the 2012 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.

LOAD CASE(S) Standard